



ML16174A054

# ***Seabrook Public Meeting – ASR Update***

---

**Nuclear Regulatory Commission - Region I  
Hampton, NH  
June 21, 2016**



# ***NRC Staff***

- Raymond Lorson, Director, DRS
- Fred Bower, DRP Branch Chief
- Mel Gray, DRS Branch Chief
- Doug Broaddus, NRR Branch Chief
- Brian Wittick, NRR Branch Chief
- Angela Buford, Structural Engineer, NRR
- Bill Cook, Sr. Reactor Analyst
- Paul Cataldo, Sr. Resident Inspector



# ***AGENDA***

- 2015 Safety Performance Overview
- ASR Inspections
- ASR and License Renewal Status
- ASR License Amendment Request
- Question and Answer Session
- Closing Remarks



# Seabrook 2015 Assessment Summary

- Operated safely and in a manner that preserved the public health and safety and protected the environment
- Licensee Response Column
- 5,470 hours of inspection and related activities.
- All Green Performance Indicators
- 2 Green Findings



# NRC Inspections of Seabrook Structures Affected by ASR

- NRC specialist inspections completed every six months
- NRC issued a violation in 2016 for not evaluating ASR effects of bulk deformation in Containment Enclosure Building and Underground Equipment Vault Wall Cracks
  - Violation of very low safety significance because structural capability was maintained
  - Written response required due to repetitiveness
  - NRC will complete inspection to assess effectiveness of actions to prevent recurrence





# License Renewal Status Update

- Need reasonable assurance that ASR aging effects can be adequately managed
- License renewal safety review is ongoing; regulatory decision on the application has not been finalized
- Remaining schedule milestones, including 2<sup>nd</sup> ACRS Subcommittee meeting, are “to be determined”



# License Renewal Status Update

- NextEra submitted latest ASR Monitoring Aging Management Program (AMP) on Dec 3, 2015
- ASR continues to be an Open Item, primarily due to building deformation and macro-cracking manifestations
- Public meeting with NextEra at NRC HQ on April 28, 2016, discussed ASR open issues
- NextEra intends to submit a revised ASR Monitoring AMP in August 2016




# ASR License Amendment Request

- Pre-application public meeting with NextEra held June 15, 2016.
  - NextEra stated it intends to submit an ASR license amendment request (LAR) in July 2016.
  - The LAR will request to revise Seabrook's design basis
  - Texas test data is intended to demonstrate that American Concrete Institute code acceptance criteria are met (within limits) for ASR-affected structures.





# NRC License Amendment Process





# NRC Social Media Channels



- Web: <http://www.nrc.gov/>
- Blog: <http://public-blog.nrc-gateway.gov/>
- Flickr: <http://www.flickr.com/photos/nrcgov/>
- Twitter: <https://twitter.com/#!/nrcgov>
- YouTube: <http://www.youtube.com/user/NRCgov>
- Questions?