

3.11 Environmental Qualification of Mechanical and Electrical Equipment

This section presents information to demonstrate that the mechanical and electrical portions of the engineered safety features, the reactor protection systems, and selected portions of the post-accident monitoring system are capable of performing their designated functions while exposed to applicable normal, abnormal, test, accident, and post-accident environmental conditions. The information presented includes identification of the equipment required to be environmentally qualified and, for each item of equipment, the designated functional requirements, definition of the applicable environmental parameters, and documentation of the qualification process employed to demonstrate the required environmental capability. The seismic qualification of mechanical and electrical equipment is presented in [Section 3.10](#). The portions of post-accident monitoring equipment required to be environmentally qualified are identified in [Table 7.5-1](#).

3.11.1 Equipment Identification and Environmental Conditions

3.11.1.1 Equipment Identification

A complete list of environmentally qualified electrical and mechanical equipment that is essential to emergency reactor shutdown, containment isolation, reactor core cooling, or containment and reactor heat removal, or that is otherwise essential in preventing significant release of radioactive material to the environment, is provided in [Table 3.11-1](#). [A list of environmentally qualified electrical and mechanical equipment and a summary of electrical and mechanical equipment qualification results are maintained as part of the equipment qualification file, as outlined in Appendix 3D.](#) The equipment qualification file is maintained during the equipment selection and procurement phase as defined in [subsection 3.11.5](#).

RN-15-139

3.11.1.2 Definition of Environmental Conditions

[Appendix 3D](#) identifies applicable normal, abnormal, and design basis accident environmental conditions conforming to General Design Criterion 4. These environmental conditions are associated with various plant areas by an environmental zone, as noted in [Table 3D.5-1](#) and [Table 3.11-1](#).

For mild environments, the area conditions do not change as the result of an accident. There are no degrading environmental effects that lead to common mode failure of the equipment. The qualification of mechanical and electrical equipment located in a mild environment is demonstrated by conducting the plant surveillance activities carried out during the operational phase of the plant.

The environmental conditions identified in [Appendix 3D](#) are defined as follows.

Normal operating environmental conditions are defined as those conditions existing during routine plant operations for which the equipment is expected to be available on a continuous basis to perform required functions.

Abnormal environmental conditions are those plant conditions for which the equipment is designed to operate for a period of time without accelerating normal periodic tests, inspections, and maintenance schedules for that equipment. The maximum and minimum conditions identified as the abnormal condition are based on the design limits for the affected areas.

Design basis accident (DBA) and post-design basis accident conditions are those plant conditions resulting from various postulated equipment and piping failures during which the equipment identified in [Table 3.11-1](#) must operate without impairment of the function. The design basis accident and post-design basis accident conditions are discussed in [Appendix 3D](#).

Compatibility of equipment with the specified environmental conditions is achieved by the following.

Systems and components required to mitigate the consequences of a design basis accident or to perform safe shutdown operation are qualified to remain functional after exposure to the environmental conditions in [Table 3D.5-5](#).

Environmentally qualified equipment exposed to a harsh environment has a qualified life goal of 60 years. Demonstration of qualified life by test or test and analysis is provided to address applicable aging effects. For critical components susceptible to aging, a qualified life is established that includes the effects of the total integrated radiation dose experienced at their respective locations within the plant. When a 60-year qualified life is not achievable, a shorter qualified life is established, and a replacement program is implemented.

For equipment located in a mild environment, a design life goal is established by using known significant aging mechanisms and reliability data.

Equipment qualification takes into account the most severe environmental conditions resulting from the design basis high-energy line break. Included in these conditions are the short-term peak transient temperature following a main steam line break (MSLB) and a radiation exposure and temperature due to a loss of coolant accident (LOCA) within the reactor containment.

Postulated high-energy line failures as defined in [subsection 3.6.2.1.2](#) are assumed in areas where high-energy lines greater than 1 inch are routed. Essential equipment is protected against the effects of jet impingement ([subsection 3.6.2.4.1](#)) and evaluated for spray effects if required ([subsection 3.6.2.7](#)).

Active mechanical equipment is qualified for operability as discussed in [subsection 3.9.3](#) and [Section 3.10](#). This operability program, combined with the qualification of the electrical appurtenances (valve operators, solenoids, limit switches), demonstrates qualification under required environmental conditions. Active mechanical equipment is defined as equipment that performs a mechanical motion as part of its safety-related function.

Nonactive mechanical equipment whose only safety function is structural integrity is designed according to ASME Code guidelines. The accident and post-accident environmental effects are considered in the design of such structural components as pump casings and valve bodies.

The environmental qualification program is restricted to evaluating the design of critical nonmetallic subcomponents of active devices in a harsh environment, where failure results in loss of the active component.

In the event of potential flooding/wetting, one of the following criteria is applied for protection of equipment for service in such an environment:

- Equipment will be qualified for submergence due to flooding/wetting.
- Equipment will be protected from wetting due to spray.
- Equipment will be evaluated to show that failure of the equipment due to flooding/wetting is acceptable since its safety-related function is not required or has otherwise been accomplished.

3.11.1.3 Equipment Operability Times

For the AP1000 Class 1E electrical and active mechanical equipment, post-accident operability times are shown in [Table 3D.4-2](#) in [Appendix 3D](#).

Specific information for each device qualified as part of the IEEE 323-1974 qualification program is contained in the appropriate equipment qualification data package.

The active mechanical component is qualified for operability as discussed in [Section 3.10](#), using test, analysis, or a combination of tests and analyses. This operability program, combined with the qualification of the electrical appurtenances (for example, valve operators) discussed in the appropriate equipment qualification data packages, demonstrates qualification.

3.11.1.4 Standard Review Plan Evaluation

A discussion of the Standard Review Plan requirements in regard to environmental qualification of mechanical equipment is provided in [subsection 1.9.2](#).

3.11.2 Qualification Tests and Analysis

3.11.2.1 Environmental Qualification of Electrical Equipment

The AP1000 approach for environmental qualification of Class 1E equipment is outlined in [Appendix 3D](#). The [Appendix 3D](#) methodology is developed based on the guidelines provided in IEEE 323-1974 ([Reference 1](#)) and IEEE 344-1987 ([Reference 2](#)).

Qualification for equipment in a harsh environment is based on type testing or testing and analysis. Analysis may be used to determine significant aging mechanisms in mild environment applications. Type testing includes thermal and mechanical aging, radiation, and exposure to extremes of environmental, seismic, and vibration effects. Type testing is done with representative samples of the production line equipment according to the sequence indicated in IEEE 323-1974 to the specified service conditions, including margin. The testing takes into account normal and abnormal plant operation and design basis accident and post-design basis accident operations, as required.

When reliable data and proven analytical methods are available, environmental qualification may be based on analysis supported by partial type test data. This method includes justification of the methods, theories, and assumptions used (that is, mathematical or logical proof based on actual test data) that the equipment meets or exceeds its specified performance requirements when subjected to normal, abnormal, and design basis accident environmental conditions.

Regulatory guides providing guidance for meeting the requirements of 10CFR50, Appendix A, General Design Criteria 1, 2, 4, 23, and 50; Appendix B, Criteria III, XI, and XVII to 10CFR50 and 10CFR50.49, include Regulatory Guide 1.89, Regulatory Guide 1.30, Regulatory Guide 1.63, Regulatory Guide 1.73, Regulatory Guide 1.100, and Regulatory Guide 1.131. The maintenance surveillance program follows the guidance of Regulatory Guide 1.33.

Additional information regarding conformance with each of these regulatory guides is given in [Section 1.9](#).

3.11.2.2 Environmental Qualification of Mechanical Equipment

AP1000 mechanical components identified in [Table 3.11-1](#) are qualified by design to perform their required functions under the appropriate environmental effects of normal, abnormal, accident, and post-accident conditions as required by General Design Criterion 4 and discussed in [Appendix 3D](#). For mild environments, the area conditions do not change as a result of an accident. There are no degrading environmental effects that lead to common mode failure of equipment in mild environments. Mechanical equipment located in harsh environmental zones is designed to perform under the appropriate environmental conditions.

For mechanical equipment, there are two categories of components:

- Active equipment – equipment that performs a mechanical motion as part of its safety-related function.

The program for environmental qualification of active mechanical components is based on a combination of design, test, and analysis of critical sub-components, which is supported by maintenance and surveillance programs.

- Nonactive equipment – equipment whose only safety-related function is structural integrity. Nonactive components are designed for structural integrity according to ASME Code, Section III, as discussed in [Section 3.9](#).

3.11.3 Loss of Ventilation

The abnormal environmental conditions shown on [Tables 3D.5-3](#) and [3D.5-4](#) reflect anticipated maximum conditions based on loss of normal ventilation systems.

Normal containment heat removal is provided by the nonsafety-related containment air recirculation cooling system. If this system is out of service for an extended period of time, the passive containment cooling system may be initiated to maintain the temperature and pressure below the limits noted. Environmentally qualified equipment located in containment performs its functions under these conditions until the normal containment cooling system is restored.

Equipment areas outside containment and outside the main control room are maintained at normal environmental conditions by nonsafety-related HVAC systems. If these systems are disabled, the heat generated by this equipment is absorbed by the surrounding concrete with an ambient temperature rise that does not exceed the abnormal condition. Normal HVAC is restored within 72 hours or ventilation is provided as discussed in [Section 6.4](#).

If the normal nonsafety-related main control room HVAC is lost, the heat generated by equipment and people is absorbed by the surrounding concrete. Normal heating, ventilation, and air-conditioning is restored within 72 hours or ventilation is provided as discussed in [Section 6.4](#).

3.11.4 Estimated Radiation and Chemical Environment

The plant-specific estimates of the radiation dose incurred by equipment during normal operation is shown in [Table 3D.5-2](#) and the estimated doses following a loss-of-coolant accident are defined in [Table 3D.5-5](#).

The identified equipment is qualified to perform functions in the radiation environments present during normal and design basis accident conditions. The normal operational exposure is based upon design source terms presented in [Chapter 11](#) and [subsection 12.2.1](#). The equipment and shielding configurations are presented in [Section 12.3](#). Post-accident monitoring, reactor trip and engineered safety features system and component radiation exposures are dependent on the location of the equipment in the plant. Source terms and other accident parameters are presented in [subsection 12.2.1](#) and [Chapter 15](#).

The maximum combined integrated radiation dose inside containment is based on the effects of the normally expected radiation environment (gamma) over the equipment's installed life plus that associated with the most severe design basis event (gamma and beta) during or following which the equipment is required to remain functional.

The chemical environment following a loss of coolant accident is primarily based on the chemistry of the reactor coolant system fluid since there is no caustic containment spray. Sump pH adjustments are considered for certain qualification tests. This is discussed further in [Appendix 3D](#).

3.11.5 Combined License Information Item for Equipment Qualification File

Westinghouse Electric Company LLC will act as the agent for the COL holder during the equipment design phase, equipment selection and procurement phase, equipment qualification phase, plant construction phase, and ITAAC inspection phases.

The COL holder is responsible for the maintenance of the equipment qualification file upon receipt from the reactor vendor. The documentation necessary to support the continued qualification of the equipment installed in the plant that is within the Environmental Qualification (EQ) Program scope is available in accordance with 10 CFR Part 50 Appendix A, General Design Criterion 1.

EQ files developed by the reactor vendor are maintained as applicable for equipment and certain post-accident monitoring devices that are subject to a harsh environment. The contents of the qualification files are discussed in [Section 3D.7](#). The files are maintained for the operational life of the plant.

For equipment not located in a harsh environment, design specifications received from the reactor vendor are retained. Any plant modifications that impact the equipment use the original specifications for modification or procurement. This process is governed by applicable plant design control or configuration control procedures.

Central to the EQ Program is the EQ Master Equipment List (EQMEL). This EQMEL identifies the electrical and mechanical equipment or components that must be environmentally qualified for use in a harsh environment. The EQMEL consists of equipment that is essential to emergency reactor shutdown, containment isolation, reactor core cooling, or containment and reactor heat removal, or that is otherwise essential in preventing significant release of radioactive material to the environment. This list is developed from the equipment list provided in [Table 3.11-1](#). The EQMEL and a summary of equipment qualification results are maintained as part of the equipment qualification file for the operational life of the plant.

Administrative programs are in place to control revision to the EQ files and the EQMEL. When adding or modifying components in the EQ Program, EQ files are generated or revised to support qualification. The EQMEL is revised to reflect these new components. To delete a component from the EQ Program, a deletion justification is prepared that demonstrates why the component can be deleted. This justification consists of an analysis of the component, an associated circuit review if appropriate, and a safety evaluation. The justification is released and/or referenced on an appropriate change document. For changes to the EQMEL, supporting documentation is completed and approved prior to issuing the changes. This documentation includes safety reviews and new or revised EQ files. Plant modifications and design basis changes are subject to change process reviews, e.g. reviews in accordance with 10 CFR 50.59 or Section VIII of Appendix D to 10 CFR Part 52, in accordance with appropriate plant procedures. These reviews address EQ issues associated with the activity. Any changes to the EQMEL that are not the result of a modification or design basis change are subject to a separate review that is accomplished and documented in accordance with plant procedures.

Engineering change documents or maintenance documents generated to document work performed on an EQ component, which may not have an impact on the EQ file, are reviewed against the current revision of the EQ files for potential impact. Changes to EQ documentation may be due to, but not limited to, plant modifications, calculations, corrective maintenance, or other EQ concerns.

[Table 13.4-201](#) provides milestones for EQ implementation.

3.11.6 References

1. IEEE 323-1974, "IEEE Standard for Qualifying Class 1E Equipment for Nuclear Power Generating Stations."
2. IEEE 344-1987, "IEEE Recommended Practices for Seismic Qualification of Class 1E Equipment for Nuclear Power Generating Stations."

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 1 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
BATTERIES					
IDSA 125V 60 Cell Battery 1A	IDSA-DB-1A	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSA 125V 60 Cell Battery 1B	IDSA-DB-1B	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSB 125V 60 Cell Battery 1A	IDSB-DB-1A	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSB 125V 60 Cell Battery 1B	IDSB-DB-1B	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSB 125V 60 Cell Battery 2A	IDSB-DB-2A	2	RT ESF PAMS	5 min 24 hr 72 hr	E
IDSB 125V 60 Cell Battery 2B	IDSB-DB-2B	2	RT ESF PAMS	5 min 24 hr 72 hr	E
IDSC 125V 60 Cell Battery 1A	IDSC-DB-1A	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSC 125V 60 Cell Battery 1B	IDSC-DB-1B	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSC 125V 60 Cell Battery 2A	IDSC-DB-2A	2	RT ESF PAMS	5 min 24 hr 72 hr	E
IDSC 125V 60 Cell Battery 2B	IDSC-DB-2B	2	RT ESF PAMS	5 min 24 hr 72 hr	E
IDSD 125V 60 Cell Battery 1A	IDSD-DB-1A	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSD 125V 60 Cell Battery 1B	IDSD-DB-1B	2	RT ESF PAMS	5 min 24 hr 24 hr	E

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 2 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Spare 125V 60 Cell Battery 1A	IDSS-DB-1A	2	RT ESF PAMS	5 min 24 hr 72 hr	E
Spare 125V 60 Cell Battery 1B	IDSS-DB-1B	2	RT ESF PAMS	5 min 24 hr 72 hr	E
BATTERY CHARGERS					
IDSA Battery Charger	IDSA-DC-1	2	ISOL	24 hr	E
IDSB Battery Charger	IDSB-DC-1	2	ISOL	24 hr	E
IDSB Battery Charger 2	IDSB-DC-2	2	ISOL	72 hr	E
IDSC Battery Charger 1	IDSC-DC-1	2	ISOL	24 hr	E
IDSC Battery Charger 2	IDSC-DC-2	2	ISOL	72 hr	E
IDSD Battery Charger	IDSD-DC-1	2	ISOL	24 hr	E
Spare Battery Charger	IDSS-DC-1	2	ISOL	72 hr	E
DISTRIBUTION PANELS					
IDSA 250 Vdc Dist Panel	IDSA-DD-1	2	ESF	24 hr	E
IDSB 250 Vdc Dist Panel	IDSB-DD-1	2	ESF	24 hr	E
IDSC 250 Vdc Dist Panel	IDSC-DD-1	2	ESF	24 hr	E
IDSD 250 Vdc Dist Panel	IDSD-DD-1	2	ESF	24 hr	E
IDSA 120 Vac Dist Panel 1	IDSA-EA-1	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSA 120 Vac Dist Panel 2	IDSA-EA-2	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSB 120 Vac Dist Panel 1	IDSB-EA-1	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSB 120 Vac Dist Panel 2	IDSB-EA-2	2	RT ESF PAMS	5 min 24 hr 2 wks	E
IDSB 120 Vac Dist Panel 3	IDSB-EA-3	2	PAMS	2 wks	E
IDSC 120 Vac Dist Panel 1	IDSC-EA-1	2	RT ESF PAMS	5 min 24 hr 24 hr	E

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 3 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
IDSC 120 Vac Dist Panel 2	IDSC-EA-2	2	RT ESF PAMS	5 min 24 hr 2 wks	E
IDSC 120 Vac Dist Panel 3	IDSC-EA-3	2	PAMS	2 wks	E
IDSD 120 Vac Dist Panel 1	IDSD-EA-1	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSD 120 Vac Dist Panel 2	IDSD-EA-2	2	RT ESF PAMS	5 min 24 hr 24 hr	E
FUSE PANELS					
IDSA Fuse Panel	IDSA-EA-4	2	ISOL	24 hr	E
IDSB Fuse Panel	IDSB-EA-4	2	ISOL	24 hr	E
IDSB Fuse Panel	IDSB-EA-5	2	ISOL	2 wks	E
IDSB Fuse Panel	IDSB-EA-6	2	ISOL	2 wks	E
IDSC Fuse Panel	IDSC-EA-4	2	ISOL	24 hr	E
IDSC Fuse Panel	IDSC-EA-5	2	ISOL	2 wks	E
IDSC Fuse Panel	IDSC-EA-6	2	ISOL	2 wks	E
IDSD Fuse Panel	IDSD-EA-4	2	ISOL	24 hr	E
TRANSFER SWITCHES					
IDSA Fused Transfer Switch Box 1	IDSA-DF-1	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSB Fused Transfer Switch Box 1	IDSB-DF-1	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSB Fused Transfer Switch Box 2	IDSB-DF-2	2	RT ESF PAMS	5 min 24 hr 72 hr	E

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 4 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
IDSC Fused Transfer Switch Box 1	IDSC-DF-1	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSC Fused Transfer Switch Box 2	IDSC-DF-2	2	RT ESF PAMS	5 min 24 hr 72 hr	E
IDSD Fused Transfer Switch Box 1	IDSD-DF-1	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSS Fused Transfer Switch Box 1 (Spare)	IDSS-DF-1	2	RT ESF PAMS	5 min 24 hr 72 hr	E
IDSS Spare Battery Termination Box	IDSS-DF-3	2	RT ESF PAMS	5 min 24 hr 72 hr	E
MOTOR CONTROL CENTERS					
IDSA 250 Vdc MCC	IDSA-DK-1	2	ESF	24 hr	E
IDSB 250 Vdc MCC	IDSB-DK-1	2	ESF	24 hr	E
IDSC 250 Vdc MCC	IDSC-DK-1	2	ESF	24 hr	E
IDSD 250 Vdc MCC	IDSD-DK-1	2	ESF	24 hr	E
SWITCHBOARDS					
IDSA 250 Vdc Switchboard 1	IDSA-DS-1	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSB 250 Vdc Switchboard 1	IDSB-DS-1	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSB 250 Vdc Switchboard 2	IDSB-DS-2	2	RT ESF PAMS	5 min 24 hr 72 hr	E

RN-14-141

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 5 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
IDSC 250 Vdc Switchboard 1	IDSC-DS-1	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSC 250 Vdc Switchboard 2	IDSC-DS-2	2	RT ESF PAMS	5 min 24 hr 72 hr	E
IDSD 250 Vdc Switchboard 1	IDSD-DS-1	2	RT ESF PAMS	5 min 24 hr 24 hr	E
TRANSFORMERS					
IDSA Regulating Transformer 1	IDSA-DT-1	2	ISOL	24 hr	E
IDSB Regulating Transformer 1	IDSB-DT-1	2	ISOL PAMS	72 hr 2 wks	E
IDSC Regulating Transformer 1	IDSC-DT-1	2	ISOL PAMS	72 hr 2 wks	E
IDSD Regulating Transformer 1	IDSD-DT-1	2	ISOL	24 hr	E
INVERTERS					
IDSA Inverter	IDSA-DU-1	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSB Inverter 1	IDSB-DU-1	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSB Inverter 2	IDSB-DU-2	2	RT ESF PAMS	5 min 24 hr 2 wks	E
IDSC Inverter 1	IDSC-DU-1	2	RT ESF PAMS	5 min 24 hr 24 hr	E
IDSC Inverter 2	IDSC-DU-2	2	RT ESF PAMS	5 min 24 hr 2 wks	E
IDSD Inverter	IDSD-DU-1	2	RT ESF PAMS	5 min 24 hr 24 hr	E

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 6 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
SWITCHGEAR					
RCP 1A 6900V Switchgear 31	ECS-ES-31	2	ESF PAMS	5 min 2 wks	E
RCP 1A 6900V Switchgear 32	ECS-ES-32	2	ESF PAMS	5 min 2 wks	E
RCP 2A 6900V Switchgear 51	ECS-ES-51	2	ESF PAMS	5 min 2 wks	E
RCP 2A 6900V Switchgear 52	ECS-ES-52	2	ESF PAMS	5 min 2 wks	E
RCP 1B 6900V Switchgear 41	ECS-ES-41	2	ESF PAMS	5 min 2 wks	E
RCP 1B 6900V Switchgear 42	ECS-ES-42	2	ESF PAMS	5 min 2 wks	E
RCP 2B 6900V Switchgear 61	ECS-ES-61	2	ESF PAMS	5 min 2 wks	E
RCP 2B 6900V Switchgear 62	ECS-ES-62	2	ESF PAMS	5 min 2 wks	E
Reactor Trip Switchgear	PMS-JD-RTSA01	4	RT PAMS	5 min 2 wks	E
Reactor Trip Switchgear	PMS-JD-RTSA02	4	RT PAMS	5 min 2 wks	E
Reactor Trip Switchgear	PMS-JD-RTSB01	4	RT PAMS	5 min 2 wks	E
Reactor Trip Switchgear	PMS-JD-RTSB02	4	RT PAMS	5 min 2 wks	E
Reactor Trip Switchgear	PMS-JD-RTSC01	4	RT PAMS	5 min 2 wks	E
Reactor Trip Switchgear	PMS-JD-RTSC02	4	RT PAMS	5 min 2 wks	E
Reactor Trip Switchgear	PMS-JD-RTSD01	4	RT PAMS	5 min 2 wks	E
Reactor Trip Switchgear	PMS-JD-RTSD02	4	RT PAMS	5 min 2 wks	E

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 7 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
LEVEL TRANSMITTERS					
Core Makeup Tank A Narrow Range Upper Level	PXS-JE-LE011A PXS-JE-LT011A	1 2	ESF PAMS	24 hr 4 mos	E *
Core Makeup Tank A Narrow Range Upper Level	PXS-JE-LE011B PXS-JE-LT011B	1 2	ESF PAMS	24 hr 4 mos	E *
Core Makeup Tank A Narrow Range Upper Level	PXS-JE-LE011C PXS-JE-LT011C	1 2	ESF PAMS	24 hr 4 mos	E *
Core Makeup Tank A Narrow Range Upper Level	PXS-JE-LE011D PXS-JE-LT011D	1 2	ESF PAMS	24 hr 4 mos	E *
Core Makeup Tank B Narrow Range Upper Level	PXS-JE-LE012A PXS-JE-LT012A	1 2	ESF PAMS	24 hr 4 mos	E *
Core Makeup Tank B Narrow Range Upper Level	PXS-JE-LE012B PXS-JE-LT012B	1 2	ESF PAMS	24 hr 4 mos	E *
Core Makeup Tank B Narrow Range Upper Level	PXS-JE-LE012C PXS-JE-LT012C	1 2	ESF PAMS	24 hr 4 mos	E *
Core Makeup Tank B Narrow Range Upper Level	PXS-JE-LE012D PXS-JE-LT012D	1 2	ESF PAMS	24 hr 4 mos	E *
Core Makeup Tank A Narrow Range Lower Level	PXS-JE-LE013A PXS-JE-LT013A	1 2	ESF PAMS	24 hr 4 mos	E *
Core Makeup Tank A Narrow Range Lower Level	PXS-JE-LE013B PXS-JE-LT013B	1 2	ESF PAMS	24 hr 4 mos	E *
Core Makeup Tank A Narrow Range Lower Level	PXS-JE-LE013C PXS-JE-LT013C	1 2	ESF PAMS	24 hr 4 mos	E *
Core Makeup Tank A Narrow Range Lower Level	PXS-JE-LE013D PXS-JE-LT013D	1 2	ESF PAMS	24 hr 4 mos	E *
Core Makeup Tank B Narrow Range Lower Level	PXS-JE-LE014A PXS-JE-LT014A	1 2	ESF PAMS	24 hr 4 mos	E *
Core Makeup Tank B Narrow Range Lower Level	PXS-JE-LE014B PXS-JE-LT014B	1 2	ESF PAMS	24 hr 4 mos	E *
Core Makeup Tank B Narrow Range Lower Level	PXS-JE-LE014C PXS-JE-LT014C	1 2	ESF PAMS	24 hr 4 mos	E *
Core Makeup Tank B Narrow Range Lower Level	PXS-JE-LE014D PXS-JE-LT014D	1 2	ESF PAMS	24 hr 4 mos	E *
Containment Floodup Level	PXS-JE-LE050 PXS-JE-LT050	1 2	PAMS	4 mos	E *
Containment Floodup Level	PXS-JE-LE051 PXS-JE-LT051	1 2	PAMS	4 mos	E *
Containment Floodup Level	PXS-JE-LE052 PXS-JE-LT052	1 2	PAMS	4 mos	E *

RN-13-007

RN-13-007

RN-13-007

RN-13-007

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 8 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
NEUTRON DETECTORS					
Source Range Neutron Detector	RXS-JE-NE001A	1	RT ESF	Note 3 Note 3	E *
Source Range Neutron Detector	RXS-JE-NE001B	1	RT ESF	Note 3 Note 3	E *
Source Range Neutron Detector	RXS-JE-NE001C	1	RT ESF	Note 3 Note 3	E *
Source Range Neutron Detector	RXS-JE-NE001D	1	RT ESF	Note 3 Note 3	E *
Intermediate Range Neutron Detector	RXS-JE-NE002A	1	RT PAMS	Note 3 4 mos	E *
Intermediate Range Neutron Detector	RXS-JE-NE002B	1	RT PAMS	Note 3 4 mos	E *
Intermediate Range Neutron Detector	RXS-JE-NE002C	1	RT PAMS	Note 3 4 mos	E *
Intermediate Range Neutron Detector	RXS-JE-NE002D	1	RT PAMS	Note 3 4 mos	E *
Power Range Neutron Detector (Lower)	RXS-JE-NE003A	1	RT	5 min	E *
Power Range Neutron Detector (Lower)	RXS-JE-NE003B	1	RT	5 min	E *
Power Range Neutron Detector (Lower)	RXS-JE-NE003C	1	RT	5 min	E *
Power Range Neutron Detector (Lower)	RXS-JE-NE003D	1	RT	5 min	E *
Power Range Neutron Detector (Upper)	RXS-JE-NE004A	1	RT	5 min	E *
Power Range Neutron Detector (Upper)	RXS-JE-NE004B	1	RT	5 min	E *
Power Range Neutron Detector (Upper)	RXS-JE-NE004C	1	RT	5 min	E *
Power Range Neutron Detector (Upper)	RXS-JE-NE004D	1	RT	5 min	E *

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 9 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
RADIATION MONITORS					
Containment High Range Area Monitor	PXS-JE-RE160	1	ESF PAMS	24 hr 4 mos	E *
Containment High Range Area Monitor	PXS-JE-RE161	1	ESF PAMS	24 hr 4 mos	E *
Containment High Range Area Monitor	PXS-JE-RE162	1	ESF PAMS	24 hr 4 mos	E *
Containment High Range Area Monitor	PXS-JE-RE163	1	ESF PAMS	24 hr 4 mos	E *
Control Room Supply Air Radiation Monitor	VBS-JE-RE001A	3	ESF PAMS	24 hr 2 wks	E
Control Room Supply Air Radiation Monitor	VBS-JE-RE001B	3	ESF PAMS	24 hr 2 wks	E
RESISTANCE TEMPERATURE DETECTORS					
PRHR HX Outlet Temperature	RCS-JE-TE161	1	PAMS	4 mos	E *
RCS Cold Leg 1A Narrow Range Temperature	RCS-JE-TE121A	1	RT ESF	5 min 5 min	E *
RCS Cold Leg 1A Narrow Range Temperature	RCS-JE-TE121D	1	RT ESF	5 min 5 min	E *
RCS Cold Leg 1B Narrow Range Temperature	RCS-JE-TE121B	1	RT ESF	5 min 5 min	E *
RCS Cold Leg 1B Narrow Range Temperature	RCS-JE-TE121C	1	RT ESF	5 min 5 min	E *
RCS Cold Leg 2A Narrow Range Temperature	RCS-JE-TE122B	1	RT ESF	5 min 5 min	E *
RCS Cold Leg 2A Narrow Range Temperature	RCS-JE-TE122C	1	RT ESF	5 min 5 min	E *
RCS Cold Leg 2B Narrow Range Temperature	RCS-JE-TE122A	1	RT ESF	5 min 5 min	E *
RCS Cold Leg 2B Narrow Range Temperature	RCS-JE-TE122D	1	RT ESF	5 min 5 min	E *
RCS Hot Leg 1 Narrow Range Temperature	RCS-JE-TE131A	1	RT ESF	5 min 5 min	E *
RCS Hot Leg 1 Narrow Range Temperature	RCS-JE-TE131C	1	RT ESF	5 min 5 min	E *

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 10 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
RCS Hot Leg 1 Narrow Range Temperature	RCS-JE-TE132A	1	RT ESF	5 min 5 min	E *
RCS Hot Leg 1 Narrow Range Temperature	RCS-JE-TE132C	1	RT ESF	5 min 5 min	E *
RCS Hot Leg 1 Narrow Range Temperature	RCS-JE-TE133C	1	RT ESF	5 min 5 min	E *
RCS Hot Leg 1 Narrow Range Temperature	RCS-JE-TE133A	1	RT ESF	5 min 5 min	E *
RCS Hot Leg 2 Narrow Range Temperature	RCS-JE-TE131B	1	RT ESF	5 min 5 min	E *
RCS Hot Leg 2 Narrow Range Temperature	RCS-JE-TE131D	1	RT ESF	5 min 5 min	E *
RCS Hot Leg 2 Narrow Range Temperature	RCS-JE-TE132B	1	RT ESF	5 min 5 min	E *
RCS Hot Leg 2 Narrow Range Temperature	RCS-JE-TE132D	1	RT ESF	5 min 5 min	E *
RCS Hot Leg 2 Narrow Range Temperature	RCS-JE-TE133B	1	RT ESF	5 min 5 min	E *
RCS Hot Leg 2 Narrow Range Temperature	RCS-JE-TE133D	1	RT ESF	5 min 5 min	E *
RCS Cold Leg 1A Dual Range Temperature	RCS-JE-TE125A	1	PAMS	4 mos	E *
RCS Cold Leg 1B Dual Range Temperature	RCS-JE-TE125C	1	PAMS	4 mos	E *
RCS Cold Leg 2A Dual Range Temperature	RCS-JE-TE125B	1	PAMS	4 mos	E *
RCS Cold Leg 2B Dual Range Temperature	RCS-JE-TE125D	1	PAMS	4 mos	E *
RCS Hot Leg 1 Wide Range Temperature	RCS-JE-TE135A	1	PAMS	4 mos	E *
RCS Hot Leg 2 Wide Range Temperature	RCS-JE-TE135B	1	PAMS	4 mos	E *
PZR Reference Leg Level Temperature	RCS-JE-TE193A	1	RT ESF PAMS	5 min 5 min 4 mos	E *

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 11 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
PZR Reference Leg Level Temperature	RCS-JE-TE193B	1	RT ESF PAMS	5 min 5 min 4 mos	E *
PZR Reference Leg Level Temperature	RCS-JE-TE193C	1	RT ESF PAMS	5 min 5 min 4 mos	E *
PZR Reference Leg Level Temperature	RCS-JE-TE193D	1	RT ESF PAMS	5 min 5 min 4 mos	E *
SPEED SENSORS					
RCP 1A Pump Speed	RCS-JE-ST281	1	RT	Note 3	E *
RCP 1B Pump Speed	RCS-JE-ST282	1	RT	Note 3	E *
RCP 2A Pump Speed	RCS-JE-ST283	1	RT	Note 3	E *
RCP 2B Pump Speed	RCS-JE-ST284	1	RT	Note 3	E *
THERMOCOUPLES					
Incore Thermocouples	IIS-JE-TE001 through IIS-JE-TE042	1	PAMS	1 yr	E *
RCP 1A Bearing Water Temperature	RCS-JE-TE211A	1	RT	Note 3	E *
RCP 1A Bearing Water Temperature	RCS-JE-TE211B	1	RT	Note 3	E *
RCP 1A Bearing Water Temperature	RCS-JE-TE211C	1	RT	Note 3	E *
RCP 1A Bearing Water Temperature	RCS-JE-TE211D	1	RT	Note 3	E *
RCP 1B Bearing Water Temperature	RCS-JE-TE212A	1	RT	Note 3	E *
RCP 1B Bearing Water Temperature	RCS-JE-TE212B	1	RT	Note 3	E *
RCP 1B Bearing Water Temperature	RCS-JE-TE212C	1	RT	Note 3	E *
RCP 1B Bearing Water Temperature	RCS-JE-TE212D	1	RT	Note 3	E *
RCP 2A Bearing Water Temperature	RCS-JE-TE213A	1	RT	Note 3	E *
RCP 2A Bearing Water Temperature	RCS-JE-TE213B	1	RT	Note 3	E *
RCP 2A Bearing Water Temperature	RCS-JE-TE213C	1	RT	Note 3	E *
RCP 2A Bearing Water Temperature	RCS-JE-TE213D	1	RT	Note 3	E *
RCP 2B Bearing Water Temperature	RCS-JE-TE214A	1	RT	Note 3	E *
RCP 2B Bearing Water Temperature	RCS-JE-TE214B	1	RT	Note 3	E *
RCP 2B Bearing Water Temperature	RCS-JE-TE214C	1	RT	Note 3	E *
RCP 2B Bearing Water Temperature	RCS-JE-TE214D	1	RT	Note 3	E *

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 12 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
TRANSMITTERS					
PCS Water Delivery Flow	PCS-JE-FT001	9	PAMS	2 wks	E
PCS Water Delivery Flow	PCS-JE-FT002	9	PAMS	2 wks	E
PCS Water Delivery Flow	PCS-JE-FT003	9	PAMS	2 wks	E
PCS Water Delivery Flow	PCS-JE-FT004	9	PAMS	2 wks	E
PCS Storage Tank Water Level	PCS-JE-LT010	9	PAMS	2 wks	E
PCS Storage Tank Water Level	PCS-JE-LT011	9	PAMS	2 wks	E
PRHR HX Flow	PXS-JE-FT049A	1	PAMS	4 mos	E *
PRHR HX Flow	PXS-JE-FT049B	1	PAMS	4 mos	E *
RCS Hot Leg 1 Flow	RCS-JE-FT101A	1	RT	Note 3	E *
RCS Hot Leg 1 Flow	RCS-JE-FT101B	1	RT	Note 3	E *
RCS Hot Leg 1 Flow	RCS-JE-FT101C	1	RT	Note 3	E *
RCS Hot Leg 1 Flow	RCS-JE-FT101D	1	RT	Note 3	E *
RCS Hot Leg 2 Flow	RCS-JE-FT102A	1	RT	Note 3	E *
RCS Hot Leg 2 Flow	RCS-JE-FT102B	1	RT	Note 3	E *
RCS Hot Leg 2 Flow	RCS-JE-FT102C	1	RT	Note 3	E *
RCS Hot Leg 2 Flow	RCS-JE-FT102D	1	RT	Note 3	E *
SG1 Startup Feedwater Flow	SGS-JE-FT055A	2	ESF PAMS	5 min 2 wks	E
SG1 Startup Feedwater Flow	SGS-JE-FT055B	2	ESF PAMS	5 min 2 wks	E
SG2 Startup Feedwater Flow	SGS-JE-FT056A	2	ESF PAMS	5 min 2 wks	E
SG2 Startup Feedwater Flow	SGS-JE-FT056B	2	ESF PAMS	5 min 2 wks	E
MCR Air Delivery Line Flowrate – A	VES-JE-FT003A	3	PAMS	72 hrs	E
MCR Air Delivery Line Flowrate – B	VES-JE-FT003B	3	PAMS	72 hrs	E
Plant Vent Flow	VFS-JE-FT101	7	PAMS	2 wks	E +
IRWST Level	PXS-JE-LT045	1	PAMS ESF	4 mos 24 hr	E *
IRWST Level	PXS-JE-LT046	1	PAMS ESF	4 mos 24 hr	E *
IRWST Level	PXS-JE-LT047	1	PAMS ESF	4 mos 24 hr	E *
IRWST Level	PXS-JE-LT048	1	PAMS ESF	4 mos 24 hr	E *

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 13 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
RCS Hot Leg Water Level	RCS-JE-LT160A	1	PAMS	2 wks	E *
RCS Hot Leg Water Level	RCS-JE-LT160B	1	PAMS	2 wks	E *
PZR Level	RCS-JE-LT195A	1	RT ESF PAMS	5 min 5 min 4 mos	E *
PZR Level	RCS-JE-LT195B	1	RT ESF PAMS	5 min 5 min 4 mos	E *
PZR Level	RCS-JE-LT195C	1	RT ESF PAMS	5 min 5 min 4 mos	E *
PZR Level	RCS-JE-LT195D	1	RT ESF PAMS	5 min 5 min 4 mos	E *
SG1 Narrow Range Level	SGS-JE-LT001	1	RT ESF PAMS	5 min 5 min 2 wks	E *
SG1 Narrow Range Level	SGS-JE-LT002	1	RT ESF PAMS	5 min 5 min 2 wks	E *
SG1 Narrow Range Level	SGS-JE-LT003	1	RT ESF PAMS	5 min 5 min 2 wks	E *
SG1 Narrow Range Level	SGS-JE-LT004	1	RT ESF PAMS	5 min 5 min 2 wks	E *
SG2 Narrow Range Level	SGS-JE-LT005	1	RT ESF PAMS	5 min 5 min 2 wks	E *
SG2 Narrow Range Level	SGS-JE-LT006	1	RT ESF PAMS	5 min 5 min 2 wks	E *
SG2 Narrow Range Level	SGS-JE-LT007	1	RT ESF PAMS	5 min 5 min 2 wks	E *
SG2 Narrow Range Level	SGS-JE-LT008	1	RT ESF PAMS	5 min 5 min 2 wks	E *

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 14 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
SG1 Wide Range Level	SGS-JE-LT011	1	ESF PAMS	5 min 2 wks	E *
SG1 Wide Range Level	SGS-JE-LT012	1	ESF PAMS	5 min 2 wks	E *
SG1 Wide Range Level	SGS-JE-LT015	1	ESF PAMS	5 min 2 wks	E * E *
SG1 Wide Range Level	SGS-JE-LT016	1	ESF PAMS	5 min 2 wks	E * E *
SG2 Wide Range Level	SGS-JE-LT013	1	ESF PAMS	5 min 2 wks	E *
SG2 Wide Range Level	SGS-JE-LT014	1	ESF PAMS	5 min 2 wks	E *
SG2 Wide Range Level	SGS-JE-LT017	1	ESF PAMS	5 min 2 wks	E *
SG2 Wide Range Level	SGS-JE-LT018	1	ESF PAMS	5 min 2 wks	E *
Spent Fuel Pool Level	SFS-JE-LT019A	11	PAMS	2 wks	E **
Spent Fuel Pool Level	SFS-JE-LT019B	11	PAMS	2 wks	E **
Spent Fuel Pool Level	SFS-JE-LT019C	11	PAMS	2 wks	E **
Air Storage Tank Pressure – A	VES-JE-PT001A	7	PAMS	2 wks	E+
Air Storage Tank Pressure – B	VES-JE-PT001B	7	PAMS	2 wks	E+
Containment Pressure Normal Range	PCS-JE-PT005	7	ESF PAMS	5 min 4 mos	E *
Containment Pressure Normal Range	PCS-JE-PT006	7	ESF PAMS	5 min 4 mos	E *
Containment Pressure Normal Range	PCS-JE-PT007	7	ESF PAMS	5 min 4 mos	E *
Containment Pressure Normal Range	PCS-JE-PT008	7	ESF PAMS	5 min 4 mos	E *
Containment Pressure Extended Range	PCS-JE-PT012	7	PAMS	4 mos	E *
Containment Pressure Extended Range	PCS-JE-PT013	7	PAMS	4 mos	E *
Containment Pressure Extended Range	PCS-JE-PT014	7	PAMS	4 mos	E *

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 15 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
RCS Wide Range Pressure	RCS-JE-PT140A	1	PAMS ESF	4 mos 5 min	E *
RCS Wide Range Pressure	RCS-JE-PT140B	1	PAMS ESF	4 mos 5 min	E *
RCS Wide Range Pressure	RCS-JE-PT140C	1	PAMS ESF	4 mos 5 min	E *
RCS Wide Range Pressure	RCS-JE-PT140D	1	PAMS ESF	4 mos 5 min	E *
PZR Pressure	RCS-JE-PT191A	1	RT ESF PAMS	5 min 5 min 4 mos	E *
PZR Pressure	RCS-JE-PT191B	1	RT ESF PAMS	5 min 5 min 4 mos	E *
PZR Pressure	RCS-JE-PT191C	1	RT ESF PAMS	5 min 5 min 4 mos	E *
PZR Pressure	RCS-JE-PT191D	1	RT ESF PAMS	5 min 5 min 4 mos	E *
Main Steam Line SG1 Pressure	SGS-JE-PT030	1	ESF PAMS	5 min 2 wks	E *
Main Steam Line SG1 Pressure	SGS-JE-PT031	2	ESF PAMS	5 min 2 wks	E
Main Steam Line SG1 Pressure	SGS-JE-PT032	1	ESF PAMS	5 min 2 wks	E *
Main Steam Line SG1 Pressure	SGS-JE-PT033	2	ESF PAMS	5 min 2 wks	E
Main Steam Line SG2 Pressure	SGS-JE-PT034	1	ESF PAMS	5 min 2 wks	E *
Main Steam Line SG2 Pressure	SGS-JE-PT035	2	ESF PAMS	5 min 2 wks	E
Main Steam Line SG2 Pressure	SGS-JE-PT036	1	ESF PAMS	5 min 2 wks	E *
Main Steam Line SG2 Pressure	SGS-JE-PT037	2	ESF PAMS	5 min 2 wks	E

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 16 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Main Control Room Differential Pressure	VES-JE-PDT004A	3	ESF PAMS	2 wks 2 wks	E
Main Control Room Differential Pressure	VES-JE-PDT004B	3	ESF PAMS	2 wks 2 wks	E
PROTECTION AND SAFETY MONITORING SYSTEMS					
Protection and Safety Monitoring System Cabinets	Multiple (Note 7)	2	RT ESF PAMS	5 min 24 hr 2 wks	E
MCR/RSW Transfer Switch Panel A	PMS-JW-004A	2	RT ESF	5 min 24 hr	E
MCR/RSW Transfer Switch Panel B	PMS-JW-004B	2	RT ESF	5 min 24 hr	E
MCR/RSW Transfer Switch Panel C	PMS-JW-004C	2	RT ESF	5 min 24 hr	E
MCR/RSW Transfer Switch Panel D	PMS-JW-004D	2	RT ESF	5 min 24 hr	E
Source Range Neutron Flux Preamplifier Panel A	PMS-JW-005A	2	RT, ESF	Note 3	E
Source Range Neutron Flux Preamplifier Panel B	PMS-JW-005B	2	RT, ESF	Note 3	E
Source Range Neutron Flux Preamplifier Panel C	PMS-JW-005C	2	RT, ESF	Note 3	E
Source Range Neutron Flux Preamplifier Panel D	PMS-JW-005D	2	RT, ESF	Note 3	E
Intermediate Range Neutron Flux Preamplifier Panel A	PMS-JW-006A	2	RT PAMS	Note 3 4 mos	E
Intermediate Range Neutron Flux Preamplifier Panel B	PMS-JW-006B	2	RT PAMS	Note 3 4 mos	E
Intermediate Range Neutron Flux Preamplifier Panel C	PMS-JW-006C	2	RT PAMS	Note 3 4 mos	E
Intermediate Range Neutron Flux Preamplifier Panel D	PMS-JW-006D	2	RT PAMS	Note 3 4 mos	E
Power Range Neutron Flux High Voltage Distribution Box A	PMS-JW-007A	2	RT	5 min	E
Power Range Neutron Flux High Voltage Distribution Box B	PMS-JW-007B	2	RT	5 min	E

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 17 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Power Range Neutron Flux High Voltage Distribution Box C	PMS-JW-007C	2	RT	5 min	E
Power Range Neutron Flux High Voltage Distribution Box D	PMS-JW-007D	2	RT	5 min	E
MAIN CONTROL ROOM					
Operator Workstation A	N/A	3	RT ESF PAMS	5 min 24 hr 2 wks	E
Operator Workstation B	N/A	3	RT ESF PAMS	5 min 24 hr 2 wks	E
Supervisor Workstation	N/A	3	RT ESF PAMS	5 min 24 hr 2 wks	E
Switch Station (Including Switches)	N/A	3	RT ESF	5 min 24 hr	E
QDPS MCR Display Unit	PMS-JY-001B	3	PAMS	2 wks	E
QDPS MCR Display Unit	PMS-JY-001C	3	PAMS	2 wks	E
PENETRATIONS					
Penetrations (Mechanical)	See Table 6.2.3-1				M *
Penetrations (Electrical)	See Figure 3.8.2-4				E *
ACTIVE VALVES					
Containment Isolation – Air Out	CAS-PL-V014	2	ESF	5 min	M S
Solenoid Valve	CAS-PL-V014-S	2	ESF	5 min	E
Limit Switch	CAS-PL-V014-L	2	PAMS	2 wks	E
Containment Isolation – Air In	CAS-PL-V015	1	ESF	5 min	M *
Containment Isolation – Inlet	CCS-PL-V200	2	ESF	5 min	M S
Limit Switch	CCS-PL-V200-L	2	PAMS	2 wks	E
Motor Operator	CCS-PL-V200-M	2	ESF	5 min	E
Service Air Supply Inside Containment Isolation	CAS-PL-V205	1	ESF	5 min	M *
Containment Isolation – Inlet	CCS-PL-V201	1	ESF	5 min	M *
Containment Isolation – Outlet	CCS-PL-V207	1	ESF	5 min	M *
Limit Switch	CCS-PL-V207-L	1	PAMS	1 yr	E *
Motor Operator	CCS-PL-V207-M	1	ESF	5 min	E *

RN-16-015

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 18 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Containment Isolation – Outlet	CCS-PL-V208	2	ESF	5 min	M S
Limit Switch	CCS-PL-V208-L	2	PAMS	2 wks	E
Motor Operator	CCS-PL-V208-M	2	ESF	5 min	E
CCS Containment Isolation Relief	CCS-PL-V220	1	ESF	24 hr	M *
CCS IRC Relief Valve	CCS-PL-V270	1	ESF	24 hr	M*
CCS IRC Relief Valve	CCS-PL-V271	1	ESF	24 hr	M*
RCS Purification Stop Valve	CVS-PL-V001	1	ESF	5 min	M *
Limit Switch	CVS-PL-V001-L	1	PAMS	1 yr	E *
Motor Operator	CVS-PL-V001-M	1	ESF	5 min	E *
RCS Purification Stop Valve	CVS-PL-V002	1	ESF	5 min	M *
Limit Switch	CVS-PL-V002-L	1	PAMS	1 yr	E *
Motor Operator	CVS-PL-V002-M	1	ESF	5 min	E *
RCS Letdown Stop Valve	CVS-PL-V003	1	ESF	5 min	M *
Limit Switch	CVS-PL-V003-L	1	PAMS	1 yr	E *
Motor Operator	CVS-PL-V003-M	1	ESF	5 min	E *
Demineralizer Flush Line Relief Valve	CVS-PL-V042	1	ESF	24 hr	M *
WLS Letdown IRC Isolation	CVS-PL-V045	1	ESF	5 min	M *
Limit Switch	CVS-PL-V045-L	1	PAMS	1 yr	E *
Solenoid Valve	CVS-PL-V045-S1	1	ESF	5 min	E *
Letdown Flow ORC Isolation	CVS-PL-V047	7	ESF	5 min	M S **
Limit Switch	CVS-PL-V047-L	7	PAMS	2 wks	E **
Solenoid Valve	CVS-PL-V047-S1	7	ESF	5 min	E **
Letdown Line Containment Isolation Thermal Relief	CVS-PL-V058	1	ESF	24 hr	M *
CVS Makeup Line Bypass Check Valve	CVS-PL-V067	1	ESF	5 min	M*
RCS Purification Check Valve	CVS-PL-V080	1	ESF	5 min	M *
RCS Purification Stop Valve	CVS-PL-V081	1	ESF	5 min	M *
RCS Purification Check Valve	CVS-PL-V082	1	ESF	5 min	M *
Auxiliary PZR Spray Isolation	CVS-PL-V084	1	ESF	5 min	M *
Limit Switch	CVS-PL-V084-L	1	PAMS	1 yr	E *
Solenoid Valve	CVS-PL-V084-S	1	ESF	5 min	E *
Auxiliary PZR Spray Isolation	CVS-PL-V085	1	ESF	5 min	M *
Makeup Line Containment Isolation	CVS-PL-V090	7	ESF	5 min	M S **
Limit Switch	CVS-PL-V090-L	7	PAMS	2 wks	E **
Motor Operator	CVS-PL-V090-M	7	ESF	5 min	E **
Makeup Line Containment Isolation	CVS-PL-V091	1	ESF	5 min	M *
Limit Switch	CVS-PL-V091-L	1	PAMS	1 yr	E *
Motor Operator	CVS-PL-V091-M	1	ESF	5 min	E *

RN-16-015

RN-12-004

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 19 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Zinc Injection Containment Isolation	CVS-PL-V092	10	ESF	5 min	M *
Limit Switch	CVS-PL-V092-L	10	PAMS	2 wks	E *
Solenoid Valve	CVS-PL-V092-S	10	ESF	5 min	E *
Zinc Injection Containment Isolation IRC	CVS-PL-V094	1	ESF	5 min	M *
Limit Switch	CVS-PL-V094-L	1	PAMS	1 yr	E *
Solenoid Valve	CVS-PL-V094-S	1	ESF	5 mins	E *
Zinc Injection Containment Isolation Thermal Overpressurization Relief Valve	CVS-PL-V098	1	ESF	24 hrs	M *
Makeup Containment Isolation	CVS-PL-V100	1	ESF	24 hrs	M *
Demineralizer Water System Isolation	CVS-PL-V136A	7	ESF	5 min	M **
Limit Switch	CVS-PL-V136A-L	7	PAMS	2 wks	E **
Solenoid Valve	CVS-PL-V136A-S	7	ESF	5 min	E **
Demineralized Water System Isolation	CVS-PL-V136B	7	ESF	5 min	M **
Limit Switch	CVS-PL-V136B-L	7	PAMS	2 wks	E **
Solenoid Valve	CVS-PL-V136B-S	7	ESF	5 min	E **
Hydrogen Injection Containment Isolation Check IRC	CVS-PL-V217	1	PB	1 yr	M *
Hydrogen Injection Containment Isolation	CVS-PL-V219	10	ESF	5 min	M *
Limit Switch	CVS-PL-V219-L	10	PAMS	2 wks	E *
Solenoid Valve	CVS-PL-V219-S	10	EST	5 min	E *
DWS Containment Penetration Thermal Relief Valve	DWS-PL-V241	1	ESF	24 hrs	M *
Demin Water Supply Containment Isolation – Inside	DWS-PL-V245	1	ESF	5 min	M *
Fuel Transfer Tube Gate Valve	FHS-PL-V001	11	ESF	2 wks	M **
Fire Water Containment Supply Isolation – Inside	FPS-PL-V052	1	ESF	5 min	M *
FPS Containment Penetration Thermal Relief Valve	FPS-PL-V702	1	ESF	24 hrs	M *
PCCWST Isolation Valve	PCS-PL-V001A	9	ESF	5 min	M S
Limit Switch	PCS-PL-V001A-L	9	PAMS	2 wks	E
Solenoid Valve	PCS-PL-V001A-S1	9	ESF	5 min	E
PCCWST Isolation Valve	PCS-PL-V001B	9	ESF	5 min	M S
Limit Switch	PCS-PL-V001B-L	9	PAMS	2 wks	E
Solenoid Valve	PCS-PL-V001B-S1	9	ESF	5 min	E
PCCWST Isolation Valve	PCS-PL-V001C	9	ESF	5 min	M S
Limit Switch	PCS-PL-V001C-L	9	PAMS	2 wks	E
Motor Operator	PCS-PL-V001C-M	9	ESF	5 min	E

RN-12-004

RN-12-004

RN-14-103

RN-16-015

RN-16-015

RN-14-103

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 20 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
PCCWST Isolation Valve	PCS-PL-V002A	9	ESF	5 min	M S
Limit Switch	PCS-PL-V002A-L	9	PAMS	2 wks	E
Motor Operator	PCS-PL-V002A-M	9	ESF	5 min	E
PCCWST Isolation Valve	PCS-PL-V002B	9	ESF	5 min	M S
Limit Switch	PCS-PL-V002B-L	9	PAMS	2 wks	E
Motor Operator	PCS-PL-V002B-M	9	ESF	5 min	E
PCCWST Isolation Valve	PCS-PL-V002C	9	ESF	5 min	M S
Limit Switch	PCS-PL-V002C-L	9	PAMS	2 wks	E
Motor Operator	PCS-PL-V002C-M	9	ESF	5 min	E
PCCWST Fire Protection Isolation	PCS-PL-V005	10	ESF	72 hrs	M *
PCCWST Emergency Spent Fuel Pool Makeup Isolation	PCS-PL-V009	9	ESF	2 wks	M *
Water Bucket Makeup Line Drain Valve	PCS-PL-V015	10	ESF	2 wks	M *
Water Bucket Makeup Line Isolation Valve	PCS-PL-V020	10	ESF	2 wks	M *
PCS Recirculation Isolation	PCS-PL-V023	10	ESF	72 hrs	M *
PCCWST Long-Term Makeup Check Valve	PCS-PL-V039	10	ESF	2 wks	M *
PCCWST Long Term Makeup Isolation Drain Valve	PCS-PL-V042	10	ESF	2 wks	M *
PCCWST Long Term Makeup Isolation Valve	PCS-PL-V044	10	ESF	2 wks	M *
Emergency Makeup to the Spent Fuel Pool Isolation Valve	PCS-PL-V045	7	ESF	2 wks	M *
PCCWST Recirculation Return Isolation Valve	PCS-PL-V046	10	ESF	2 wks	M *
Emergency Makeup to the Spent Fuel Pool Drain Isolation Valve	PCS-PL-V049	7	ESF	2 wks	M *
Spent Fuel Pool Long Term Makeup Isolation Valve	PCS-PL-V050	10	ESF	2 wks	M *
Spent Fuel Pool Emergency Makeup Lower Isolation Valve	PCS-PL-V051	7	ESF	2 wks	M *
Containment Isolation – Air Sample Line	PSS-PL-V008	1	ESF	4 mos	M *
Limit Switch	PSS-PL-V008-L	1	PAMS	1 yr	E *
Solenoid Operator	PSS-PL-V008-S	1	ESF	5 min	E *
Containment Isolation – Liquid Sample Line	PSS-PL-V010A	1	ESF	4 mos	M *
Limit Switch	PSS-PL-V010A-L	1	PAMS	1 yr	E *
Solenoid Operator	PSS-PL-V010A-S	1	ESF	5 min	E *
Containment Isolation – Liquid Sample Line	PSS-PL-V010B	1	ESF	4 mos	M *
Limit Switch	PSS-PL-V010B-L	1	PAMS	1 yr	E *
Solenoid Operator	PSS-PL-V010B-S	1	ESF	5 min	E *

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 21 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Containment Isolation – Liquid Sample Line	PSS-PL-V011A	6	ESF	2 wks	M S **
Limit Switch	PSS-PL-V011A-L	6	PAMS	2 wks	E **
Solenoid Valve	PSS-PL-V011A-S	6	ESF	5 min	E **
Containment Isolation – Liquid Sample Line	PSS-PL-V011B	6	ESF	2 wks	M S **
Limit Switch	PSS-PL-V011B-L	6	PAMS	2 wks	E **
Solenoid Valve	PSS-PL-V011B-S	6	ESF	5 min	E **
Containment Isolation - Sample Return Line	PSS-PL-V023	6	ESF	2 wks	M S **
Limit Switch	PSS-PL-V023-L	6	PAMS	2 wks	E **
Solenoid Valve	PSS-PL-V023-S	6	ESF	5 min	E **
Containment Isolation - Sample Return Line	PSS-PL-V024	1	ESF	4 mos	M *
Limit Switch	PSS-PL-V024-L	1	PAMS	1 yr	E *
Solenoid Operator	PSS-PL-V024-S	1	ESF	5 min	E *
Containment Isolation - Air Sample Line	PSS-PL-V046	6	ESF	2 wks	M S **
Limit Switch	PSS-PL-V046-L	6	PAMS	2 wks	E **
Solenoid Valve	PSS-PL-V046-S	6	ESF	2 wks	E **
PWS MCR Isolation Valve	PWS-PL-V418	3	ESF	5 min	M
PWS MCR Isolation Valve	PWS-PL-V420	3	ESF	5 min	M
PWS MCR Vacuum Relief	PWS-PL-V498	3	ESF	5 min	M
Core Makeup Tank A Discharge Isolation	PXS-PL-V014A	1	ESF	5 min	M *
Limit Switch	PXS-PL-V014A-L	1	PAMS	1 yr	E *
Solenoid Valve	PXS-PL-V014A-S1	1	ESF	5 min	E *
Core Makeup Tank B Discharge Isolation	PXS-PL-V014B	1	ESF	5 min	M *
Limit Switch	PXS-PL-V014B-L	1	PAMS	1 yr	E *
Solenoid Valve	PXS-PL-V014B-S1	1	ESF	5 min	E *
Core Makeup Tank A Discharge Isolation	PXS-PL-V015A	1	ESF	5 min	M *
Limit Switch	PXS-PL-V015A-L	1	PAMS	1 yr	E *
Solenoid Valve	PXS-PL-V015A-S1	1	ESF	5 min	E *
Core Makeup Tank B Discharge Isolation	PXS-PL-V015B	1	ESF	5 min	M *
Limit Switch	PXS-PL-V015B-L	1	PAMS	1 yr	E *
Solenoid Valve	PXS-PL-V015B-S1	1	ESF	5 min	E *
Core Makeup Tank A Discharge	PXS-PL-V016A	1	ESF	5 min	M *
Core Makeup Tank B Discharge	PXS-PL-V016B	1	ESF	5 min	M *

RN-12-033

RN-12-033

RN-16-015

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 22 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Core Makeup Tank A Discharge	PXS-PL-V017A	1	ESF	5 min	M *
Core Makeup Tank B Discharge	PXS-PL-V017B	1	ESF	5 min	M *
Accumulator A Pressure Relief	PXS-PL-V022A	1	ESF	5 min	M *
Accumulator B Pressure Relief	PXS-PL-V022B	1	ESF	5 min	M *
Accumulator A Discharge	PXS-PL-V028A	1	ESF	5 min	M *
Accumulator B Discharge	PXS-PL-V028B	1	ESF	5 min	M *
Accumulator A Discharge	PXS-PL-V029A	1	ESF	5 min	M *
Accumulator B Discharge	PXS-PL-V029B	1	ESF	5 min	M *
Nitrogen Supply Outside Containment Isolation	PXS-PL-V042	2	ESF	5 min	M S
Limit Switch	PXS-PL-V042-L	2	PAMS	2 wks	E
Solenoid Valve	PXS-PL-V042-S	2	ESF	5 min	E
Nitrogen Supply Containment Isolation IRC Check Valve	PXS-PL-V043	1	ESF	5 min	M *
PRHR HX Discharge Isolation	PXS-PL-V108A	1	ESF	5 min	M *
Limit Switch	PXS-PL-V108A-L	1	PAMS	1 yr	E *
Solenoid Valve	PXS-PL-V108A-S1	1	ESF	5 min	E *
PRHR HX Discharge Isolation	PXS-PL-V108B	1	ESF	5 min	M *
Limit Switch	PXS-PL-V108B-L	1	PAMS	1 yr	E *
Solenoid Valve	PXS-PL-V108B-S1	1	ESF	5 min	E *
Recirc Sump A Isolation	PXS-PL-V118A	1	ESF	72 hr	M *
Limit Switch	PXS-PL-V118A-L	1	PAMS	1 yr	E *
Squib Operator	PXS-PL-V118A-T	1	ESF	72 hr	E *
Recirc Sump B Isolation	PXS-PL-V118B	1	ESF	72 hr	M *
Limit Switch	PXS-PL-V118B-L	1	PAMS	1 yr	E *
Squib Operator	PXS-PL-V118B-T	1	ESF	72 hr	E *
Recirc Sump A	PXS-PL-V119A	1	ESF	1 yr	M *
Recirc Sump B	PXS-PL-V119B	1	ESF	1 yr	M *
Recirc Sump A	PXS-PL-V120A	1	ESF	72 hr	M *
Limit Switch	PXS-PL-V120A-L	1	PAMS	1 yr	E *
Squib Operator	PXS-PL-V120A-T	1	ESF	72 hr	E *
Recirc Sump B	PXS- PL-V120B	1	ESF	72 hr	M *
Limit Switch	PXS-PL-V120B-L	1	PAMS	1 yr	E *
Squib Operator	PXS-PL-V120B-T	1	ESF	72 hr	E *
IRWST Injection A	PXS-PL-V122A	1	ESF	1 yr	M *
IRWST Injection B	PXS-PL-V122B	1	ESF	1 yr	M *
IRWST Injection A	PXS-PL-V123A	1	ESF	72 hr	M *
Limit Switch	PXS-PL-V123A-L	1	PAMS	1 yr	E *
Squib Operator	PXS-PL-V123A-T	1	ESF	72 hr	E *

RN-16-015

RN-15-024

RN-15-024

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 23 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
IRWST Injection B	PXS-PL-V123B	1	ESF	72 hr	M *
Limit Switch	PXS-PL-V123B-L	1	PAMS	1 yr	E *
Squib Operator	PXS-PL-V123B-T	1	ESF	72 hr	E *
IRWST Injection A	PXS-PL-V124A	1	ESF	1 yr	M *
IRWST Injection B	PXS-PL-V124B	1	ESF	1 yr	M *
IRWST Injection A	PXS-PL-V125A	1	ESF	72 hr	M *
Limit Switch	PXS-PL-V125A-L	1	PAMS	1 yr	E *
Squib Operator	PXS-PL-V125A-T	1	ESF	72 hr	E *
IRWST Injection B	PXS-PL-V125B	1	ESF	72 hr	M *
Limit Switch	PXS-PL-V125B-L	1	PAMS	1 yr	E *
Squib Operator	PXS-PL-V125B-T	1	ESF	72 hr	E *
IRWST Gutter Drain Isolation A	PXS-PL-V130A	1	ESF	5 min	M *
Limit Switch	PXS-PL-V130A-L	1	PAMS	1 yr	E *
Solenoid Valve	PXS-PL-V130A-S1	1	ESF	5 min	E *
IRWST Gutter Drain Isolation B	PXS-PL-V130B	1	ESF	5 min	M *
Limit Switch	PXS-PL-V130B-L	1	PAMS	1 yr	E *
Solenoid Valve	PXS-PL-V130B-S1	1	ESF	5 min	E *
First Stage ADS	RCS-PL-V001A	1	ESF	24 hr	M *
Limit Switch	RCS-PL-V001A-L	1	PAMS	1 yr	E *
Motor Operator	RCS-PL-V001A-M	1	ESF	24 hr	E *
First Stage ADS	RCS-PL-V001B	1	ESF	24 hr	M *
Limit Switch	RCS-PL-V001B-L	1	PAMS	1 yr	E *
Motor Operator	RCS-PL-V001B-M	1	ESF	24 hr	E *
Second Stage ADS	RCS-PL-V002A	1	ESF	24 hr	M *
Limit Switch	RCS-PL-V002A-L	1	PAMS	1 yr	E *
Motor Operator	RCS-PL-V002A-M	1	ESF	24 hr	E *
Second Stage ADS	RCS-PL-V002B	1	ESF	24 hr	M *
Limit Switch	RCS-PL-V002B-L	1	PAMS	1 yr	E *
Motor Operator	RCS-PL-V002B-M	1	ESF	24 hr	E *
Third Stage ADS	RCS-PL-V003A	1	ESF	24 hr	M *
Limit Switch	RCS-PL-V003A-L	1	PAMS	1 yr	E *
Motor Operator	RCS-PL-V003A-M	1	ESF	24 hr	E *
Third Stage ADS	RCS-PL-V003B	1	ESF	24 hr	M *
Limit Switch	RCS-PL-V003B-L	1	PAMS	1 yr	E *
Motor Operator	RCS-PL-V003B-M	1	ESF	24 hr	E *
Fourth Stage ADS	RCS-PL-V004A	1	ESF	72 hr	M *
Limit Switch	RCS-PL-V004A-L	1	PAMS	1 yr	E *
Squib Operator	RCS-PL-V004A-T	1	ESF	72 hr	E *

RN-15-024

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 24 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Fourth Stage ADS	RCS-PL-V004B	1	ESF	72 hr	M *
Limit Switch	RCS-PL-V004B-L	1	PAMS	1 yr	E *
Squib Operator	RCS-PL-V004B-T	1	ESF	72 hr	E *
Fourth Stage ADS	RCS-PL-V004C	1	ESF	72 hr	M *
Limit Switch	RCS-PL-V004C-L	1	PAMS	1 yr	E *
Squib Operator	RCS-PL-V004C-T	1	ESF	72 hr	E *
Fourth Stage ADS	RCS-PL-V004D	1	ESF	72 hr	M *
Limit Switch	RCS-PL-V004D-L	1	PAMS	1 yr	E *
Squib Operator	RCS-PL-V004D-T	1	ESF	72 hr	E *
PZR Safety Valve	RCS-PL-V005A	1	ESF	5 min	M *
PZR Safety Valve	RCS-PL-V005B	1	ESF	5 min	M *
ADS Discharge Header A Relief	RCS-PL-V010A	1	ESF	24 hr	M *
ADS Discharge Header B Relief	RCS-PL-V010B	1	ESF	24 hr	M *
First Stage ADS Isolation	RCS-PL-V011A	1	ESF	24 hr	M *
Limit Switch	RCS-PL-V011A-L	1	PAMS	1 yr	E *
Motor Operator	RCS-PL-V011A-M	1	ESF	24 hr	E *
First Stage ADS Isolation	RCS-PL-V011B	1	ESF	24 hr	M *
Limit Switch	RCS-PL-V011B-L	1	PAMS	1 yr	E *
Motor Operator	RCS-PL-V011B-M	1	ESF	24 hr	E *
Second Stage ADS Isolation	RCS-PL-V012A	1	ESF	24 hr	M *
Limit Switch	RCS-PL-V012A-L	1	PAMS	1 yr	E *
Motor Operator	RCS-PL-V012A-M	1	ESF	24 hr	E *
Second Stage ADS Isolation	RCS-PL-V012B	1	ESF	24 hr	M *
Limit Switch	RCS-PL-V012B-L	1	PAMS	1 yr	E *
Motor Operator	RCS-PL-V012B-M	1	ESF	24 hr	E *
Third Stage ADS Isolation	RCS-PL-V013A	1	ESF	24 hr	M *
Limit Switch	RCS-PL-V013A-L	1	PAMS	1 yr	E *
Motor Operator	RCS-PL-V013A-M	1	ESF	24 hr	E *
Third Stage ADS Isolation	RCS-PL-V013B	1	ESF	24 hr	M *
Limit Switch	RCS-PL-V013B-L	1	PAMS	1 yr	E *
Motor Operator	RCS-PL-V013B-M	1	ESF	24 hr	E *
Reactor Vessel Head Vent	RCS-PL-V150A	1	ESF	5 min	M *
Limit Switch	RCS-PL-V150A-L	1	PAMS	1 yr	E *
Solenoid Operator	RCS-PV-V150A-S	1	ESF	5 min	E *
Reactor Vessel Head Vent	RCS-PL-V150B	1	ESF	5 min	M *
Limit Switch	RCS-PL-V150B-L	1	PAMS	1 yr	E *
Solenoid Operator	RCS-PL-V150B-S	1	ESF	5 min	E *

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 25 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Reactor Vessel Head Vent	RCS-PL-V150C	1	ESF	5 min	M *
Limit Switch	RCS-PL-V150C-L	1	PAMS	1 yr	E *
Solenoid Operator	RCS-PL-V150C-S	1	ESF	5 min	E *
Reactor Vessel Head Vent	RCS-PL-V150D	1	ESF	5 min	M *
Limit Switch	RCS-PL-V150D-L	1	PAMS	1 yr	E *
Solenoid Operator	RCS-PL-V150D-S	1	ESF	5 min	E *
RCS Inner Suction Isolation	RNS-PL-V001A	1	ESF	5 min	M *
Limit Switch	RNS-PL-V001A-L	1	PAMS	1 yr	E *
Motor Operator	RNS-PL-V001A-M	1	ESF	5 min	E *
RCS Inner Suction Isolation	RNS-PL-V001B	1	ESF	5 min	M *
Limit Switch	RNS-PL-V001B-L	1	PAMS	1 yr	E *
Motor Operator	RNS-PL-V001B-M	1	ESF	5 min	E *
RCS Outer Suction Isolation	RNS-PL-V002A	1	ESF	5 min	M *
Limit Switch	RNS-PL-V002A-L	1	PAMS	1 yr	E *
Motor Operator	RNS-PL-V002A-M	1	ESF	5 min	E *
RCS Outer Suction Isolation	RNS-PL-V002B	1	ESF	5 min	M *
Limit Switch	RNS-PL-V002B-L	1	PAMS	1 yr	E *
Motor Operator	RNS-PL-V002B-M	1	ESF	5 min	E *
RCS Thermal Relief	RNS-PL-V003A	1	ESF	24 hr	M *
RCS Thermal Relief	RNS-PL-V003B	1	ESF	24 hr	M *
RHR Control/Isolation Valve	RNS-PL-V011	6	ESF	5 min	M S **
Limit Switch	RNS-PL-V011-L	6	PAMS	2 wks	E **
Motor Operator	RNS-PL-V011-M	6	ESF	5 min	E **
RNS Discharge Containment Isolation Valve Test Connection	RNS-PL-V012	6	ESF	1 yr	M **
RNS Discharge Containment Isolation	RNS-PL-V013	1	ESF	5 min	M *
RNS Discharge RCS Pressure Boundary	RNS-PL-V015A	1	ESF	5 min	M *
RNS Discharge RCS Pressure Boundary	RNS-PL-V015B	1	ESF	5 min	M *
RNS Discharge RCS Pressure Boundary	RNS-PL-V017A	1	ESF	5 min	M *
RNS Discharge RCS Pressure Boundary	RNS-PL-V017B	1	ESF	5 min	M *
RNS Hot Leg Suction Relief	RNS-PL-V021	1	ESF	24 hr	M *
RNS Suction Header Containment Isolation	RNS-PL-V022	6	ESF	5 min	M S **
Limit Switch	RNS-PL-V022-L	6	PAMS	2 wks	E **
Motor Operator	RNS-PL-V022-M	6	ESF	5 min	E **
IRWST Suction Line Isolation	RNS-PL-V023	1	ESF	5 min	M *
Limit Switch	RNS-PL-V023-L	1	PAMS	1 yr	E *
Motor Operator	RNS-PL-V023-M	1	ESF	5 min	E *

RN-16-015

RN-16-015

RN-15-002

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 26 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
RNS Suction from IRWST - Bonnet Relief Isolation	RNS-PL-V025	1	PB	1 yr	M*
RNS Suction from IRWST - Containment Isolation Test	RNS-PL-V026	1	PB	1 yr	M*
RNS – CVS Containment Isolation	RNS-PL-V061	1	ESF	5 min	M *
Limit Switch	RNS-PL-V061-L	1	PAMS	1 yr	E *
Air Operator	RNS-PL-V061-S	1	ESF	5 min	E *
SDS MCR Vent Isolation Valve	SDS-PL-V001	3	ESF	24 hr	M
Limit Switch	SDS-PL-V001-L	3	PAMS	2 wks	E
Motor Operator	SDS-PL-V001-M	3	ESF	5 min	E
SDS MCR Vent Isolation Valve	SDS-PL-V002	3	ESF	24 hr	M
Limit Switch	SDS-PL-V002-L	3	PAMS	2 wks	E
Motor Operator	SDS-PL-V002-M	3	ESF	5 min	E
SFS Suction Line Containment Isolation	SFS-PL-V034	1	ESF	5 min	M *
Limit Switch	SFS-PL-V034-L	1	PAMS	1 yr	E *
Motor Operator	SFS-PL-V034-M	1	ESF	5 min	E *
SFS Suction Line Containment Isolation	SFS-PL-V035	6	ESF	5 min	M S **
Limit Switch	SFS-PL-V035-L	6	PAMS	2 wks	E **
Motor Operator	SFS- PL-V035-M	6	ESF	5 min	E **
SFS Discharge Containment Isolation	SFS-PL-V037	1	ESF	5 min	M *
SFS Discharge Line Containment Isolation	SFS-PL-V038	6	ESF	5 min	M S **
Limit Switch	SFS-PL-V038-L	6	PAMS	2 wks	E **
Motor Operator	SFS-PL-V038-M	6	ESF	5 min	E **
SFS Cask Loading Pit to SFS Pump	SFS-PL-V042	6	ESF	2 wks	M **
SFS Pump to Cask Loading Pit	SFS-PL-V045	6	ESF	2 wks	M **
Cask Loading Pit to WLS	SFS-PL-V049	6	ESF	2 wks	M **
Spent Fuel Pool to Cask Washdown Pit Isolation	SFS-PL-V066	6	ESF	2 wks	M **
SFS Containment Isolation Relief	SFS-PL-V067	1	ESF	24 hr	M **
Cask Washdown Pit Drain Isolation	SFS-PL-V068	6	ESF	2 wks	M **
Refueling Cavity to SG Compartment	SFS-PL-V071	1	ESF	2 wks	M *
Refueling Cavity to SG Compartment	SFS-PL-V072	1	ESF	2 wks	M *
PORV Block Valve	SGS-PL-V027A	5	ESF	5 min	M *
Limit Switch	SGS-PL-V027A-L	5	PAMS	2 wks	E *
Motor Operator	SGS-PL-V027A-M	5	ESF	5 min	E *
PORV Block Valve	SGS-PL-V027B	5	ESF	5 min	M *
Limit Switch	SGS-PL-V027B-L	5	PAMS	2 wks	E *
Motor Operator	SGS-PL-V027B-M	5	ESF	5 min	E *

RN-15-016

RN-16-015

RN-16-015

RN-16-015

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 27 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Steam Safety Valve SG01	SGS-PL-V030A	5	ESF	5 min	M *
Steam Safety Valve SG02	SGS-PL-V030B	5	ESF	5 min	M *
Steam Safety Valve SG01	SGS-PL-V031A	5	ESF	5 min	M *
Steam Safety Valve SG02	SGS-PL-V031B	5	ESF	5 min	M *
Steam Safety Valve SG01	SGS-PL-V032A	5	ESF	5 min	M *
Steam Safety Valve SG02	SGS-PL-V032B	5	ESF	5 min	M *
Steam Safety Valve SG01	SGS-PL-V033A	5	ESF	5 min	M *
Steam Safety Valve SG02	SGS-PL-V033B	5	ESF	5 min	M *
Steam Safety Valve SG01	SGS-PL-V034A	5	ESF	5 min	M *
Steam Safety Valve SG02	SGS-PL-V034B	5	ESF	5 min	M *
Steam Safety Valve SG01	SGS-PL-V035A	5	ESF	5 min	M *
Steam Safety Valve SG02	SGS-PL-V035B	5	ESF	5 min	M *
Steam Line Condensate Drain Isolation	SGS-PL-V036A	5	ESF	5 min	M *
Limit Switch	SGS-PL-V036A-L	5	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V036A-S	5	ESF	5 min	E *
Steam Line Condensate Isolation	SGS-PL-V036B	5	ESF	5 min	M *
Limit Switch	SGS-PL-V036B-L	5	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V036B-S	5	ESF	5 min	E *
Main Steam Line Isolation	SGS-PL-V040A	5	ESF	5 min	M *
Limit Switch	SGS-PL-V040A-L	5	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V040A-S1	5	ESF	5 min	E *
Solenoid Valve	SGS-PL-V040A-S2	5	ESF	5 min	E *
Solenoid Valve	SGS-PL-V040A-S3	5	ESF	5 min	E *
Solenoid Valve	SGS-PL-V040A-S4	5	ESF	5 min	E *
Main Steam Line Isolation	SGS-PL-V040B	5	ESF	5 min	M *
Limit Switch	SGS-PL-V040B-L	5	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V040B-S1	5	ESF	5 min	E *
Solenoid Valve	SGS-PL-V040B-S2	5	ESF	5 min	E *
Solenoid Valve	SGS-PL-V040B-S3	5	ESF	5 min	E *
Solenoid Valve	SGS-PL-V040B-S4	5	ESF	5 min	E *
Main Feedwater Isolation	SGS-PL-V057A	5	ESF	5 min	M *
Limit Switch	SGS-PL-V057A-L	5	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V057A-S1	5	ESF	5 min	E *
Solenoid Valve	SGS-PL-V057A-S2	5	ESF	5 min	E *
Solenoid Valve	SGS-PL-V057A-S3	5	ESF	5 min	E *
Solenoid Valve	SGS-PL-V057A-S4	5	ESF	5 min	E *

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 28 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Main Feedwater Isolation	SGS-PL-V057B	5	ESF	5 min	M *
Limit Switch	SGS-PL-V057B-L	5	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V057B-S1	5	ESF	5 min	E *
Solenoid Valve	SGS-PL-V057B-S2	5	ESF	5 min	E *
Solenoid Valve	SGS-PL-V057B-S3	5	ESF	5 min	E *
Solenoid Valve	SGS-PL-V057B-S4	5	ESF	5 min	E *
Startup Feedwater Isolation	SGS-PL-V067A	5	ESF	5 min	M *
Limit Switch	SGS-PL-V067A-L	5	PAMS	2 wks	E *
Motor Operator	SGS-PL-V067A-M	5	ESF	5 min	E *
Startup Feedwater Isolation	SGS-PL-V067B	5	ESF	5 min	M *
Limit Switch	SGS-PL-V067B-L	5	PAMS	2 wks	E *
Motor Operator	SGS-PL-V067B-M	5	ESF	5 min	E *
SG Blowdown Isolation	SGS-PL-V074A	10	ESF	5 min	M *
Limit Switch	SGS-PL-V074A-L	10	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V074A-S	10	ESF	5 min	E *
SG Blowdown Isolation	SGS-PL-V074B	10	ESF	5 min	M *
Limit Switch	SGS-PL-V074B-L	10	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V074B-S	10	ESF	5 min	E *
SG Series Blowdown Isolation	SGS-PL-V075A	10	ESF	5 min	M *
Limit Switch	SGS-PL-V075A-L	10	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V075A-S	10	ESF	5 min	E *
SG Series Blowdown Isolation	SGS-PL-V075B	10	ESF	5 min	M *
Limit Switch	SGS-PL-V075B-L	10	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V075B-S	10	ESF	5 min	E *
Steam Line Condensate Drain	SGS-PL-V086A	5	ESF	5 min	M *
Isolation Solenoid Valve	SGS-PL-V086A-S	5	ESF	5 min	E *
Steam Line Condensate Drain	SGS-PL-V086B	5	ESF	5 min	M *
Isolation Solenoid Valve	SGS-PL-V086B-S	5	ESF	5 min	E *
Power Operated Relief Valve	SGS-PL-V233A	5	ESF	5 min	M *
Limit Switch	SGS-PL-V233A-L	5	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V233A-S	5	ESF	5 min	E *
Power Operated Relief Valve	SGS-PL-V233B	5	ESF	5 min	M *
Limit Switch	SGS-PL-V233B-L	5	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V233B-S	5	ESF	5 min	E *

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 29 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
MSIV Bypass Isolation Valve	SGS-PL-V240A	5	ESF	5 min	M *
Limit Switch	SGS- PL-V240A-L	5	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V240A-S1	5	ESF	5 min	E *
Solenoid Valve	SGS-PL-V240A-S2	5	ESF	5	E *
MSIV Bypass Isolation Valve	SGSPLV240B	5	ESF	5 min	M *
Limit Switch	SGS-PL-V240B-L	5	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V240B-S1	5	ESF	5 min	E *
Solenoid Valve	SGS-PL-V240B-S2	5	ESF	5 min	E *
Main Feedwater Control Valve	SGS-PL-V250A	5	ESF	5 min	M *
Limit Switch	SGS-PL-V250A-L	5	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V250A-S	5	ESF	5 min	E *
Main Feedwater Control Valve	SGS-PL-V250B	5	ESF	5 min	M *
Limit Switch	SGS-PL-V250B-L	5	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V250B-S	5	ESF	5 min	E *
Startup Feedwater Control Valve	SGS-PL-V255A	5	ESF	5 min	M *
Limit Switch	SGS-PL-V255A-L	5	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V255A-S	5	ESF	5 min	E *
Startup Feedwater Control Valve	SGS-PL-V255B	5	ESF	5 min	M *
Limit Switch	SGS-PL-V255B-L	5	PAMS	2 wks	E *
Solenoid Valve	SGS-PL-V255B-S	5	ESF	5 min	E *
MCR Isolation Valve	VBS-PL-V186	3	ESF	24 hr	M
Limit Switch	VBS-PL-V186-L	3	PAMS	2 wks	E
Motor Operator	VBS-PL-V186-M	3	ESF	24 hr	E
MCR Isolation Valve	VBS-PL-V187	3	ESF	24 hr	M
Limit Switch	VBS-PL-V187-L	3	PAMS	2 wks	E
Motor Operator	VBS-PL-V187-M	3	ESF	24 hr	E
MCR Isolation Valve	VBS-PL-V188	3	ESF	24 hr	M
Limit Switch	VBS-PL-V188-L	3	PAMS	2 wks	E
Motor Operator	VBS-PL-V188-M	3	ESF	24 hr	E
MCR Isolation Valve	VBS-PL-V189	3	ESF	24 hr	M
Limit Switch	VBS-PL-V189-L	3	PAMS	2 wks	E
Motor Operator	VBS-PL-V189-M	3	ESF	24 hr	E
MCR Isolation Valve	VBS-PL-V190	3	ESF	24 hr	M
Limit Switch	VBS-PL-V190-L	3	PAMS	2 wks	E
Motor Operator	VBS-PL-V190-M	3	ESF	24 hr	E

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 30 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
MCR Isolation Valve	VBS-PL-V191	3	ESF	24 hr	M
Limit Switch	VBS-PL-V191-L	3	PAMS	2 wks	E
Motor Operator	VBS-PL-V191-M	3	ESF	24 hr	E
Air Delivery Isolation Valve	VES-PL-V001	3	ESF	2 wks	M
Pressure Regulator Valve A	VES-PL-V002A	7	ESF	2 wks	M
Pressure Regulator Valve B	VES-PL-V002B	7	ESF	2 wks	M
Air Delivery Isolation Valve A	VES-PL-V005A	3	ESF	2 wks	M
Limit Switch	VES-PL-V005A-L	3	PAMS	2 wks	E
Solenoid Operator	VES-PL-V005A-S	3	ESF	2 wks	E
Air Delivery Isolation Valve B	VES-PL-V005B	3	ESF	2 wks	M
Limit Switch	VES-PL-V005B-L	3	PAMS	2 wks	E
Solenoid Operator	VES-PL-V005B-S	3	ESF	2 wks	E
Relief Isolation Valve A	VES-PL-V022A	3	ESF	2 wks	M
Limit Switch	VES-PL-V022A-L	3	PAMS	2 wks	E
Solenoid Valve	VES-PL-V022A-S	3	ESF	2 wks	E
Relief Isolation Valve B	VES-PL-V022B	3	ESF	2 wks	M
Limit Switch	VES-PL-V022B-L	3	PAMS	2 wks	E
Solenoid Valve	VES-PL-V022B-S	3	ESF	2 wks	E
Air Tank Safety Relief Valve A	VES-PL-V040A	7	ESF	2 wks	M
Air Tank Safety Relief Valve B	VES-PL-V040B	7	ESF	2 wks	M
Air Tank Safety Relief Valve C	VES-PL-V040C	7	ESF	2 wks	M
Air Tank Safety Relief Valve D	VES-PL-V040D	7	ESF	2 wks	M
Main Air Flow Path Isolation Valve	VES-PL-V044	3	ESF	2 wks	M
Eductor Flow Path Isolation Valve	VES-PL-V045	3	ESF	2 wks	M
Eductor Bypass Isolation Valve	VES-PL-V046	3	ESF	2 wks	M
Containment Purge Inlet Isolation	VFS-PL-V003	7	ESF	5 min	M S
Limit Switch	VFS-PL-V003-L	7	PAMS	2 wks	E
Solenoid Valve	VFS-PL-V003-S1	7	ESF	5 min	E
Containment Purge Inlet Isolation	VFS-PL-V004	1	ESF	5 min	M *
Limit Switch	VFS-PL-V004-L	1	PAMS	1 yr	E *
Solenoid Valve	VFS-PL-V004-S1	1	ESF	5 min	E *
Containment Purge Discharge Isolation	VFS-PL-V009	1	ESF	5 min	M *
Limit Switch	VFS-PL-V009-L	1	PAMS	1 yr	E *
Solenoid Valve	VFS-PL-V009-S1	1	ESF	5 min	E *
Containment Purge Discharge Isolation	VFS-PL-V010	6	ESF	5 min	M S **
Limit Switch	VFS-PL-V010-L	6	PAMS	2 wks	E **
Solenoid Valve	VFS-PL-V010-S1	6	ESF	5 min	E **

RN-16-015

RN-15-002

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 31 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Vacuum Relief Containment Isolation Valve A - ORC	VFS-PL-V800A	7	ESF	24 hr	M
Limit Switch	VFS-PL-V800A-L	7	PAMS	1 yr	E
Motor Operator	VFS-PL-V800A-M	7	ESF	24 hr	E
Vacuum Relief Containment Isolation Valve B - ORC	VFS-PL-V800B	7	ESF	24 hr	M
Limit Switch	VFS-PL-V800B-L	7	PAMS	1 yr	E
Motor Operator	VFS-PL-V800B-M	7	ESF	24 hr	E
Vacuum Relief Containment Isolation Check Valve A - IRC	VFS-PL-V803A	1	ESF	5 min	M*
Vacuum Relief Containment Isolation Check Valve B - IRC	VFS-PL-V803B	1	ESF	5 min	M*
VWS Containment Penetration Thermal Relief Valve	VWS-PL-V053	1	ESF	24 hrs	M*
VWS Containment Penetration Thermal Relief Valve	VWS-PL-V057	1	ESF	24 hrs	M*
Fan Cooler Supply Isolation	VWS-PL-V058	2	ESF	5 min	M S
Limit Switch	VWS-PL-V058-L	2	PAMS	2 wks	E
Solenoid Valve	VWS-PL-V058-S	2	ESF	5 min	E
Fan Coolers Supply Containment Isolation Check Valve	VWS-PL-V062	1	ESF	5 min	M *
VWS Containment Isolation Relief	VWS-PL-V080	1	ESF	24 hr	M **
Fan Cooler Return Isolation	VWS-PL-V082	1	ESF	5 min	M *
Limit Switch	VWS-PL-V082-L	1	PAMS	1 yr	E *
Solenoid Valve	VWS-PL-V082-S	1	ESF	5 min	E *
Fan Cooler Return Isolation	VWS-PL-V086	2	ESF	5 min	M S
Limit Switch	VWS-PL-V086-L	2	PAMS	2 wks	E
Solenoid Valve	VWS-PL-V086-S	2	ESF	5 min	E
Sump Containment Isolation IRC	WLS-PL-V055	1	ESF	5 min	M *
Limit Switch	WLS-PL-V055-L	1	PAMS	1 yr	E *
Solenoid Valve	WLS-PL-V055-S1	1	ESF	5 min	E *
Sump Containment Isolation ORC	WLS-PL-V057	7	ESF	5 min	M S **
Limit Switch	WLS-PL-V057-L	7	PAMS	2 wks	E **
Solenoid Valve	WLS-PL-V057-S1	7	ESF	5 min	E **
WLS Containment Isolation Relief	WLS-PL-V058	1	ESF	24 hr	M **
RCDT Gas Containment Isolation	WLS-PL-V067	1	ESF	5 min	M *
Limit Switch	WLS-PL-V067-L	1	PAMS	1 yr	E *
Solenoid Valve	WLS-PL-V067-S	1	ESF	5 min	E *
RCDT Gas Containment Isolation	WLS-PL-V068	7	ESF	5 min	M S **
Limit Switch	WLS-PL-V068-L	7	PAMS	2 wks	E **
Solenoid Valve	WLS-PL-V068-S	7	ESF	5 min	E **
CVS To Sump	WLS-PL-V071 A	1	ESF	2 wks	M *
PXS A To Sump	WLS-PL-V071 B	1	ESF	2 wks	M *

RN-14-103

RN-16-015

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 32 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
PXS B To Sump	WLS-PL-V071 C	1	ESF	2 wks	M *
CVS To Sump	WLS-PL-V072 A	1	ESF	2 wks	M *
PXS A To Sump	WLS-PL-V072 B	1	ESF	2 wks	M *
PXS B To Sump	WLS-PL-V072 C	1	ESF	2 wks	M *
MISCELLANEOUS					
Non-Active Valves					
Containment Penetration Test Connection Isolation	CAS-PL-V027	1	PB	1 yr	M*
Service Air Supply Outside Containment Isolation	CAS-PL-V204	2	PB	1 yr	M
Containment Penetration Test Connection Isolation	CAS-PL-V219	1	PB	1 yr	M *
Containment Isolation Valve Test Connection – Outlet Line	CCS-PL-V209	1	PB	1 yr	M *
CCS Supply Containment Isolation – IRC	CCS-PL-V214	1	PB	1 yr	M*
CCS Supply Containment Isolation Valve Test Connection – IRC	CCS-PL-V215	1	PB	1 yr	M*
Containment Leak Test Outlet Line – IRC	CCS-PL-V216	1	PB	1 yr	M*
Containment Isolation Valve V207 Body Test Connection Valve	CCS-PL-V217	1	PB	1 yr	M*
Containment Isolation Valve Test Connection – Inlet Line	CCS-PL-V257	2	PB	1 yr	M
Resin Flush IRC Isolation	CVS-PL-V040	1	PB	1 yr	M *
Resin Flush ORC Isolation	CVS-PL-V041	7	PB	1 yr	M **
Letdown PZR Instrument Root	CVS-PL-V046	7	PB	1 yr	M **
Zinc Addition - IRC Shutoff	CVS-PL-V065	1	PB	1 yr	M *
Zinc Add Cont Isolation Test Connection	CVS-PL-V095	1	PB	1 yr	M *
Zinc Addition Containment Isolation Test Connection	CVS-PL-V096	1	PB	1 yr	M *
Hydrogen Injection - IRC Shutoff	CVS-PL-V0215	1	PB	1 yr	M*
Hydrogen Add Cont Isolation Test Connection	CVS-PL-V0216	1	PB	1 yr	M*
Hydrogen Add Cont Isolation Test Connection	CVS-PL-V0218	1	PB	1 yr	M*
Demin Water Supply Containment Isolation – Outside	DWS-PL-V244	10	PB	1 yr	M *

RN-12-004

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 33 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)	
Containment Penetration Test Connection Isolation	DWS-PL-V248	10	PB	1 yr	M *	
Fire Water Containment Supply Isolation	FPS-PL-V050	10	PB	1 yr	M *	RN-16-015
Fire Water Containment Test Connection Isolation	FPS-PL-V051	10	PB	1 yr	M *	
Flow Transmitter FT001 Root Valve	PCS-PL-V010A	9	PB	1 yr	M	
Flow Transmitter FT001 Root Valve	PCS-PL-V010B	9	PB	1 yr	M	
Flow Transmitter FT002 Root Valve	PCS-PL-V011A	9	PB	1 yr	M	
Flow Transmitter FT002 Root Valve	PCS-PL-V011B	9	PB	1 yr	M	RN-15-090
Flow Transmitter FT003 Root Valve	PCS-PL-V012A	9	PB	1 yr	M	
Flow Transmitter FT003 Root Valve	PCS-PL-V012B	9	PB	1 yr	M	
Flow Transmitter FT004 Root Valve	PCS-PL-V013A	9	PB	1 yr	M	
Flow Transmitter FT004 Root Valve	PCS-PL-V013B	9	PB	1 yr	M	
PCCWST Drain Isolation Valve	PCS-PL-V016	9	PB	1 yr	M	
Makeup to Distr. Bucket Isolation Valve	PCS-PL-V026	6	ESF	2 wks	M	RN-16-015
PCCWST Isolation Valve Leakage Detection Drain	PCS-PL-V029	9	PB	1 yr	M	
PCCWST Isolation Valve Leakage Detection Crossconn	PCS-PL-V030	9	PB	1 yr	M	
PCCWST Level Instrument Root Valve	PCS-PL-V031A	9	PB	1 yr	M	
PCCWST Level Instrument Root Valve	PCS-PL-V031B	9	PB	1 yr	M	
Recirculation Pump Suction from Long Term Makeup Isolation Valve	PCS-PL-V033	10	ESF	2 wks	M *	
Spent Fuel Pool Emergency Makeup Isolation	PCS-PL-V052	7	PB	1 yr	M	
Shutoff Valve for Leakage Sensor	PCS-PL-V060A	9	PB	1 yr	M	RN-14-019
Shutoff Valve for Leakage Sensor	PCS-PL-V060B	9	PB	1 yr	M	
Recirculation Header Discharge to SFS Pool Vent Isolation Valve	PCS-PL-V303	10	PB	1 yr	M*	RN-14-029
Recirculation Header Discharge to SFS Pool Drain Isolation Valve	PCS-PL-V304	7	PB	1 yr	M	
PCCWST Recirculation Return Drain Isolation Valve	PCS-PL-V305	7	PB	1 yr	M	
Hot Leg 1 Sample Isolation Limit Switch	PSS-PL-V001A	1	PB	1 yr	M *	
	PSS-PL-V001A-L	1	PAMS	1 yr	E *	
Solenoid Valve	PSS-PL-V001A-S	1	ESF	24 hr	E*	RN-13-079

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 34 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Hot Leg 2 Sample Isolation	PSS-PL-V001B	1	PB	1 yr	M *
Limit Switch	PSS-PL-V001B-L	1	PAMS	1 yr	E *
Solenoid Valve	PSS-PL-V001B-S	1	ESF	24 hr	E *
Pressurizer Sample Isolation	PSS-PL-V003	1	PB	1 yr	M *
PXS Accumulator Sample Isolation	PSS-PL-V004A	1	PB	1 yr	M *
PXS Accumulator Sample Isolation	PSS-PL-V004B	1	PB	1 yr	M *
PXS CMT A Sample Isolation	PSS-PL-V005A	1	PB	1 yr	M *
PXS CMT B Sample Isolation	PSS-PL-V005B	1	PB	1 yr	M *
PXS CMT A Sample Isolation	PSS-PL-V005C	1	PB	1 yr	M *
PXS CMT B Sample Isolation	PSS-PL-V005D	1	PB	1 yr	M *
Liquid Sample Isolation Valve	PSS-PL-V012A	1	PB	1 yr	M *
Liquid Sample Check Valve	PSS-PL-V012B	1	PB	1 yr	M *
RCS Pressurizer Sample Isolation Valve	PSS-PL-V013	1	PB	1 yr	M *
RCS Hot Leg 1 Sample Isolation Valve	PSS-PL-V014A	1	PB	1 yr	M *
RCS Hot Leg 2 Sample Isolation Valve	PSS-PL-V014B	1	PB	1 yr	M *
PXS Accumulator Sample Isolation Valve	PSS-PL-V015A	1	PB	1 yr	M *
PXS Accumulator Sample Isolation Valve	PSS-PL-V015B	1	PB	1 yr	M *
PXS CMT A Sample Isolation Valve	PSS-PL-V016A	1	PB	1 yr	M *
PXS CMT B Sample Isolation Valve	PSS-PL-V016B	1	PB	1 yr	M *
PXS CMT A Sample Isolation Valve	PSS-PL-V016C	1	PB	1 yr	M *
PXS CMT B Sample Isolation Valve	PSS-PL-V016D	1	PB	1 yr	M *
Containment Testing Boundary Isolation Valve	PSS-PL-V076A	1	PB	1 yr	M *
Containment Testing Boundary Isolation Valve	PSS-PL-V076B	1	PB	1 yr	M *
Containment Isolation Test Connection Isolation Valve	PSS-PL-V082	1	PB	1 yr	M *
Containment Isolation Test Connection Isolation Valve	PSS-PL-V083	1	PB	1 yr	M *
Containment Isolation Test Connection Isolation Valve	PSS-PL-V085	1	PB	1 yr	M *
Containment Isolation Test Connection Isolation Valve	PSS-PL-V086	1	PB	1 yr	M *

RN-13-079

RN-12-033

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 35 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Core Makeup Tank A CL Inlet	PXS-PL-V002A	1	PB	1 yr	M *
Isolation					
Limit Switch	PXS-PL-V002A-L	1	PAMS	1 yr	E *
Motor Operator	PXS-PL-V002A-M	1	ESF	5 min	E *
Core Makeup Tank B CL Inlet	PXS-PL-V002B	1	PB	1 yr	M *
Isolation					
Limit Switch	PXS-PL-V002B-L	1	PAMS	1 yr	E *
Motor Operator	PXS-PL-V002B-M	1	ESF	5 min	E *
Core Makeup Tank A Upper Sample	PXS-PL-V010A	1	PB	1 yr	M *
Core Makeup Tank B Upper Sample	PXS-PL-V010B	1	PB	1 yr	M *
Core Makeup Tank A Lower Sample	PXS-PL-V011A	1	PB	1 yr	M *
Core Makeup Tank B Lower Sample	PXS-PL-V011B	1	PB	1 yr	M *
Core Makeup Tank A Drain	PXS-PL-V012A	1	PB	1 yr	M *
Core Makeup Tank B Drain	PXS-PL-V012B	1	PB	1 yr	M *
Core Makeup Tank Discharge Manual Isolation	PXS-PL-V013A	1	PB	1 yr	M *
Core Makeup Tank B Discharge Manual Isolation	PXS-PL-V013B	1	PB	1 yr	M *
RNS to CMT Injection Line A Drain	PXS-PL-V019A	1	PB	1 yr	M *
RNS to CMT Injection Line B Drain	PXS-PL-V019B	1	PB	1 yr	M *
IRWST Injection Line A Drain	PXS-PL-V020A	1	PB	1 yr	M *
IRWST Injection Line B Drain	PXS-PL-V020B	1	PB	1 yr	M *
Accumulator A N ₂ Vent	PXS-PL-V021A	1	PB	1 yr	M *
Accumulator B N ₂ Vent	PXS-PL-V021B	1	PB	1 yr	M *
Accumulator A PZR Transmitter Isolation	PXS-PL-V023A	1	PB	1 yr	M *
Accumulator B PZR Transmitter Isolation	PXS-PL-V023B	1	PB	1 yr	M *
Accumulator A PZR Transmitter Isolation	PXS-PL-V024A	1	PB	1 yr	M *
Accumulator B PZR Transmitter Isolation	PXS-PL-V024B	1	PB	1 yr	M *
Accumulator A Sample	PXS-PL-V025A	1	PB	1 yr	M *
Accumulator B Sample	PXS-PL-V025B	1	PB	1 yr	M *

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 36 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Accumulator A Drain	PXS-PL-V026A	1	PB	1 yr	M *
Accumulator B Drain	PXS-PL-V026B	1	PB	1 yr	M *
Accumulator A Discharge Isolation	PXS-PL-V027A	1	PB	1 yr	M *
Accumulator B Discharge Isolation	PXS-PL-V027B	1	PB	1 yr	M *
Core Makeup Tank A Highpoint Vent	PXS-PL-V030A	1	PB	1 yr	M *
Core Makeup Tank B Highpoint Vent	PXS-PL-V030B	1	PB	1 yr	M *
Core Makeup Tank A Highpoint Vent	PXS-PL-V031A	1	PB	1 yr	M *
Core Makeup Tank B Highpoint Vent	PXS-PL-V031B	1	PB	1 yr	M *
Accumulator A Check Valve Drain	PXS-PL-V033A	1	PB	1 yr	M *
Accumulator B Check Valve Drain	PXS-PL-V033B	1	PB	1 yr	M *
Accumulator N ₂ Containment Penetration Test Connection	PXS-PL-V052	1	PB	1 yr	M *
CMT A Wide Level Upper Root	PXS-PL-V080A	1	PB	1 yr	M *
CMT B Wide Level Upper Root	PXS-PL-V080B	1	PB	1 yr	M *
CMT A Wide Level Lower Root	PXS-PL-V081A	1	PB	1 yr	M *
CMT B Wide Level Lower Root	PXS-PL-V081B	1	PB	1 yr	M *
CMT A Upper Level A Isolation 1	PXS-PL-V082A	1	PB	1 yr	M *
CMT B Upper Level A Isolation 1	PXS-PL-V082B	1	PB	1 yr	M *
CMT A Upper Level A Isolation 2	PXS-PL-V083A	1	PB	1 yr	M *
CMT B Upper Level A Isolation 2	PXS-PL-V083B	1	PB	1 yr	M *
CMT A Upper Level A Vent	PXS-PL-V084A	1	PB	1 yr	M *
CMT B Upper Level A Vent	PXS-PL-V084B	1	PB	1 yr	M *
CMT A Upper Level A Drain	PXS-PL-V085A	1	PB	1 yr	M *
CMT B Upper Level A Drain	PXS-PL-V085B	1	PB	1 yr	M *
CMT A Upper Level B Isolation 1	PXS-PL-V086A	1	PB	1 yr	M *
CMT B Upper Level B Isolation 1	PXS-PL-V086B	1	PB	1 yr	M *
CMT A Upper Level B Isolation 2	PXS-PL-V087A	1	PB	1 yr	M *
CMT B Upper Level B Isolation 2	PXS-PL-V087B	1	PB	1 yr	M *
CMT A Upper Level B Vent	PXS-PL-V088A	1	PB	1 yr	M *
CMT B Upper Level B Vent	PXS-PL-V088B	1	PB	1 yr	M *
CMT A Upper Level B Drain	PXS-PL-V089A	1	PB	1 yr	M *
CMT B Upper Level B Drain	PXS-PL-V089B	1	PB	1 yr	M *
CMT A Lower Level A Isolation 1	PXS-PL-V092A	1	PB	1 yr	M *
CMT B Lower Level A Isolation 1	PXS-PL-V092B	1	PB	1 yr	M *
CMT A Lower Level A Isolation 2	PXS-PL-V093A	1	PB	1 yr	M *

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 37 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
CMT B Lower Level A Isolation 2	PXS-PL-V093B	1	PB	1 yr	M *
CMT A Lower Level A Vent	PXS-PL-V094A	1	PB	1 yr	M *
CMT B Lower Level A Vent	PXS-PL-V094B	1	PB	1 yr	M *
CMT A Lower Level A Drain	PXS-PL-V095A	1	PB	1 yr	M *
CMT B Lower Level A Drain	PXS-PL-V095B	1	PB	1 yr	M *
CMT A Lower Level B Isolation 1	PXS-PL-V096A	1	PB	1 yr	M *
CMT B Lower Level B Isolation 1	PXS-PL-V096B	1	PB	1 yr	M *
CMT A Lower Level B Isolation 2	PXS-PL-V097A	1	PB	1 yr	M *
CMT B Lower Level B Isolation 2	PXS-PL-V097B	1	PB	1 yr	M *
CMT A Lower Level B Vent	PXS-PL-V098A	1	PB	1 yr	M *
CMT B Lower Level B Vent	PXS-PL-V098B	1	PB	1 yr	M *
CMT A Lower Level B Drain	PXS-PL-V099A	1	PB	1 yr	M *
CMT B Lower Level B Drain	PXS-PL-V099B	1	PB	1 yr	M *
PRHR HX Inlet Isolation	PXS-PL-V101	1	PB	1 yr	M *
Limit Switch	PXS-PL-V101-L	1	PAMS	1 yr	E *
Motor Operator	PXS-PL-V101-M	1	ESF	5 min	E *
PRHR HX Inlet Head Vent	PXS-PL-V102A	1	PB	1 yr	M *
PRHR HX Inlet Head Drain	PXS-PL-V102B	1	PB	1 yr	M *
PRHR HX Outlet Head Vent	PXS-PL-V103A	1	PB	1 yr	M *
PRHR HX Outlet Head Drain	PXS-PL-V103B	1	PB	1 yr	M *
PRHR HX Flow Transmitter A Isolation	PXS-PL-V104A	1	PB	1 yr	M *
PRHR HX Flow Transmitter B Isolation	PXS-PL-V104B	1	PB	1 yr	M *
PRHR HX Flow Transmitter A Isolation	PXS-PL-V105A	1	PB	1 yr	M *
PRHR HX Flow Transmitter B Isolation	PXS-PL-V105B	1	PB	1 yr	M *
Containment Recirculation A Highpoint Vent	PXS-PL-V106	1	PB	1 yr	M *
Containment Recirculation A Highpoint Vent	PXS-PL-V107	1	PB	1 yr	M *
PRHR HX/RCS Return Isolation	PXS-PL-V109	1	PB	1 yr	M *
PRHR HX Highpoint Vent	PXS-PL-V111A	1	PB	1 yr	M *

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 38 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
PRHR HX Highpoint Vent	PXS-PL-V111B	1	PB	1 yr	M *
PRHR HX Pressure Transmitter Isolation	PXS-PL-V113	1	PB	1 yr	M *
Containment Recirculation A Drain	PXS-PL-V115A	1	PB	1 yr	M *
Containment Recirculation B Drain	PXS-PL-V115B	1	PB	1 yr	M *
Containment Recirculation A Drain	PXS-PL-V116A	1	PB	1 yr	M *
Containment Recirculation B Drain	PXS-PL-V116B	1	PB	1 yr	M *
Recirc Sump A Isolation	PXS-PL-V117A	1	ESF	24 hr	M *
Limit Switch	PXS-PL-V117A-L	1	PAMS	1 yr	E *
Motor Operator	PXS-PL-V117A-M	1	ESF	24 hr	E *
Recirc Sump B Isolation	PXS-PL-V117B	1	ESF	24 hr	M *
Limit Switch	PXS-PL-V117B-L	1	PAMS	1 yr	E *
Motor Operator	PXS-PL-V117B-M	1	ESF	24 hr	E *
IRWST Line A Isolation	PXS-PL-V121A	1	PB	1 yr	M *
IRWST Line B Isolation	PXS-PL-V121B	1	PB	1 yr	M *
IRWST Injection Check Test	PXS-PL-V126A	1	PB	1 yr	M *
IRWST Injection Check Test	PXS-PL-V126B	1	PB	1 yr	M *
IRWST Injection Line A Drain	PXS-PL-V127	1	PB	1 yr	M *
IRWST Injection Check Test	PXS-PL-V128A	1	PB	1 yr	M *
IRWST Injection Check Test	PXS-PL-V128B	1	PB	1 yr	M *
IRWST Injection Check Test	PXS-PL-V129A	1	PB	1 yr	M *
IRWST Injection Check Test	PXS-PL-V129B	1	PB	1 yr	M *
IRWST Injection Line A Drain	PXS-PL-V131A	1	PB	1 yr	M *
IRWST Injection Line B Drain	PXS-PL-V131B	1	PB	1 yr	M *
IRWST Injection Line A Drain	PXS-PL-V132A	1	PB	1 yr	M *
IRWST Injection Line B Drain	PXS-PL-V132B	1	PB	1 yr	M *
IRWST Injection Line A Highpoint Vent	PXS-PL-V133A	1	PB	1 yr	M *
IRWST Injection Line B Highpoint Vent	PXS-PL-V133B	1	PB	1 yr	M *
IRWST Injection Line A Highpoint Vent	PXS-PL-V134A	1	PB	1 yr	M *

RN-16-015

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 39 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
IRWST Injection Line B Highpoint Vent	PXS-PL-V134B	1	PB	1 yr	M *
IRWST Injection Line A Highpoint Vent Isolation	PXS-PL-V135A	1	PB	1 yr	M *
IRWST Injection Line B Highpoint Vent Isolation	PXS-PL-V135B	1	PB	1 yr	M *
RNS Suction Pump Line Drain	PXS-PL-V149	1	PB	1 yr	M *
IRWST Level Transmitter A Isolation	PXS-PL-V150A	1	PB	1 yr	M *
IRWST Level Transmitter B Isolation	PXS-PL-V150B	1	PB	1 yr	M *
IRWST Level Transmitter C Isolation	PXS-PL-V150C	1	PB	1 yr	M *
IRWST Level Transmitter D Isolation	PXS-PL-V150D	1	PB	1 yr	M *
IRWST Level Transmitter A Isolation	PXS-PL-V151A	1	PB	1 yr	M *
IRWST Level Transmitter B Isolation	PXS-PL-V151B	1	PB	1 yr	M *
IRWST Level Transmitter C Isolation	PXS-PL-V151C	1	PB	1 yr	M *
IRWST Level Transmitter D Isolation	PXS-PL-V151D	1	PB	1 yr	M *
PRHR Flow Transmitter A Vent	PXS-PL-V170A	1	PB	1 yr	M*
PRHR Flow Transmitter B Vent	PXS-PL-V170B	1	PB	1 yr	M*
PRHR Flow Transmitter A Vent	PXS-PL-V171A	1	PB	1 yr	M*
PRHR Flow Transmitter B Vent	PXS-PL-V171B	1	PB	1 yr	M*
Accumulator A Leak Test	PXS-PL-V201A	1	PB	1 yr	M *
Accumulator B Leak Test	PXS-PL-V201B	1	PB	1 yr	M *
Accumulator A Leak Test	PXS-PL-V202A	1	PB	1 yr	M *
Accumulator B Leak Test	PXS-PL-V202B	1	PB	1 yr	M *
RNS Discharge Leak Test	PXS-PL-V205A	1	PB	1 yr	M *
RNS Discharge Leak Test	PXS-PL-V205B	1	PB	1 yr	M *
RNS Discharge Leak Test	PXS-PL-V206	1	PB	1 yr	M *
RNS Suction Leak Test	PXS-PL-V207A	1	PB	1 yr	M *

RN-15-057

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 40 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
RNS Suction Leak Test	PXS-PL-V207B	1	PB	1 yr	M *
RNS Suction Leak Test	PXS-PL-V208A	1	PB	1 yr	M *
Core Makeup Tank A Fill Isolation	PXS-PL-V230A	1	PB	1 yr	M *
Core Makeup Tank B Fill Isolation	PXS-PL-V230B	1	PB	1 yr	M *
Core Makeup Tank A Fill Check	PXS-PL-V231A	1	PB	1 yr	M *
Core Makeup Tank B Fill Check	PXS-PL-V231B	1	PB	1 yr	M *
Accumulator A Fill/Drain Isolation	PXS-PL-V232A	1	PB	1 yr	M *
Accumulator B Fill/Drain Isolation	PXS-PL-V232B	1	PB	1 yr	M *
CMT A Check Valve Test Valve	PXS-PL-V250A	1	PB	1 yr	M *
CMT B Check Valve Test Valve	PXS-PL-V250B	1	PB	1 yr	M *
CMT A Check Valve Test Valve	PXS-PL-V251A	1	PB	1 yr	M *
CMT B Check Valve Test Valve	PXS-PL-V251B	1	PB	1 yr	M *
CMT A Check Valve Test Valve	PXS-PL-V252A	1	PB	1 yr	M *
CMT B Check Valve Test Valve	PXS-PL-V252B	1	PB	1 yr	M *
ADS Test Valve	RCS-PL-V007A	1	PB	1 yr	M *
ADS Test Valve	RCS-PL-V007B	1	PB	1 yr	M *
ADS Test Valve	RCS-PL-V007C	1	PB	1 yr	M *
Fourth Stage ADS Isolation	RCS-PL-V014A	1	PB	1 yr	M *
Limit Switch	RCS-PL-V014A-L	1	PAMS	1 yr	E *
Motor Operator	RCS-PL-V014A-M	1	ESF	24 hr	E *
Fourth Stage ADS Isolation	RCS-PL-V014B	1	PB	1 yr	M *
Limit Switch	RCS-PL-V014B-L	1	PAMS	1 yr	E *
Motor Operator	RCS-PL-V014B-M	1	ESF	24 hr	E *
Fourth Stage ADS Isolation	RCS-PL-V014C	1	PB	1 yr	M *
Limit Switch	RCS-PL-V014C-L	1	PAMS	1 yr	E *
Motor Operator	RCS-PL-V014C-M	1	ESF	24 hr	E *
Fourth Stage ADS Isolation	RCS-PL-V014D	1	PB	1 yr	M *
Limit Switch	RCS-PL-V014D-L	1	PAMS	1 yr	E *
Motor Operator	RCS-PL-V014D-M	1	ESF	24 hr	E *
Hot Leg 2 Level Instrument Root	RCS-PL-V095	1	PB	1 yr	M *
Hot Leg 2 Level Instrument Root	RCS-PL-V096	1	PB	1 yr	M *
Hot Leg 1 Level Instrument Root	RCS-PL-V097	1	PB	1 yr	M *
Hot Leg 1 Level Instrument Root	RCS-PL-V098	1	PB	1 yr	M *
Hot Leg 1 Flow Instrument Root	RCS-PL-V101A	1	PB	1 yr	M *
Hot Leg 1 Flow Instrument Root	RCS-PL-V101B	1	PB	1 yr	M *

RN-14-068

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 41 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Hot Leg 1 Flow Instrument Root	RCS-PL-V101C	1	PB	1 yr	M *
Hot Leg 1 Flow Instrument Root	RCS-PL-V101D	1	PB	1 yr	M *
Hot Leg 1 Flow Instrument Root	RCS-PL-V101E	1	PB	1 yr	M *
Hot Leg 1 Flow Instrument Root	RCS-PL-V101F	1	PB	1 yr	M *
Hot Leg 2 Flow Instrument Root	RCS-PL-V102A	1	PB	1 yr	M *
Hot Leg 2 Flow Instrument Root	RCS-PL-V102B	1	PB	1 yr	M *
Hot Leg 2 Flow Instrument Root	RCS-PL-V102C	1	PB	1 yr	M *
Hot Leg 2 Flow Instrument Root	RCS-PL-V102D	1	PB	1 yr	M *
Hot Leg 2 Flow Instrument Root	RCS-PL-V102E	1	PB	1 yr	M *
Hot Leg 2 Flow Instrument Root	RCS-PL-V102F	1	PB	1 yr	M *
PRHR HX Outlet Line Drain	RCS-PL-V103	1	PB	1 yr	M *
Hot Leg 1 Sample Isolation	RCS-PL-V108A	1	PB	1 yr	M *
Hot Leg 2 Sample Isolation	RCS-PL-V108B	1	PB	1 yr	M *
PZR Spray Valve	RCS-PL-V110A	1	PB	1 yr	M *
PZR Spray Valve	RCS-PL-V110B	1	PB	1 yr	M *
PZR Spray Block Valve	RCS-PL-V111A	1	PB	1 yr	M *
PZR Spray Block Valve	RCS-PL-V111B	1	PB	1 yr	M *
Cold Leg 1A Bend Instrument Root	RCS-PL-V171A	1	PB	1 yr	M *
Cold Leg 1A Bend Instrument Root	RCS-PL-V171B	1	PB	1 yr	M *
Cold Leg 1B Bend Instrument Root	RCS-PL-V172A	1	PB	1 yr	M *
Cold Leg 1B Bend Instrument Root	RCS-PL-V172B	1	PB	1 yr	M *
Cold Leg 2A Bend Instrument Root	RCS-PL-V173A	1	PB	1 yr	M *
Cold Leg 2A Bend Instrument Root	RCS-PL-V173B	1	PB	1 yr	M *
Cold Leg 2B Bend Instrument Root	RCS-PL-V174A	1	PB	1 yr	M *
Cold Leg 2B Bend Instrument Root	RCS-PL-V174B	1	PB	1 yr	M *
PZR Manual Vent	RCS-PL-V204	1	PB	1 yr	M *
PZR Manual Vent	RCS-PL-V205	1	PB	1 yr	M *

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 42 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
PZR Spray Bypass	RCS-PL-V210A	1	PB	1 yr	M *
PZR Spray Bypass	RCS-PL-V210B	1	PB	1 yr	M *
PZR Level Steam Space Instrument Root	RCS-PL-V225A	1	PB	1 yr	M *
PZR Level Steam Space Instrument Root	RCS-PL-V225B	1	PB	1 yr	M *
PZR Level Steam Space Instrument Root	RCS-PL-V225C	1	PB	1 yr	M *
PZR Level Steam Space Instrument Root	RCS-PL-V225D	1	PB	1 yr	M *
PZR Level Liquid Space Instrument Root	RCS-PL-V226A	1	PB	1 yr	M *
PZR Level Liquid Space Instrument Root	RCS-PL-V226B	1	PB	1 yr	M *
PZR Level Liquid Space Instrument Root	RCS-PL-V226C	1	PB	1 yr	M *
PZR Level Liquid Space Instrument Root	RCS-PL-V226D	1	PB	1 yr	M *
Wide Range PZR Level Steam Space Instrument Root	RCS-PL-V228	1	PB	1 yr	M *
Wide Range PZR Level Liquid Space Instrument Root	RCS-PL-V229	1	PB	1 yr	M *
Manual Head Vent	RCS-PL-V232	1	PB	1 yr	M *
Head Vent Isolation	RCS-PL-V233	1	PB	1 yr	M *
ADS Valve Discharge Header Drain Isolation	RCS-PL-V241	1	PB	1 yr	M *
ADS Discharge Line Isolation	RCS-PL-V250	1	PB	1 yr	M *
RCP 1A Vent	RCS-PL-V260A	1	PB	1 yr	M *
RCP 1B Vent	RCS-PL-V260B	1	PB	1 yr	M *
RCP 2A Vent	RCS-PL-V260C	1	PB	1 yr	M *
RCP 2B Vent	RCS-PL-V260D	1	PB	1 yr	M *
RCP 1A Drain	RCS-PL-V261A	1	PB	1 yr	M *
RCP 1B Drain	RCS-PL-V261B	1	PB	1 yr	M *
RCP 2A Drain	RCS-PL-V261C	1	PB	1 yr	M *
RCP 2B Drain	RCS-PL-V261D	1	PB	1 yr	M *
RCS Pressure Boundary Valve Thermal Relief Isolation	RNS-PL-V004A	1	PB	1 yr	M *

RN-16-015

RN-16-015

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 43 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
RCS Pressure Boundary Valve Thermal Relief Isolation	RNS-PL-V004B	1	PB	1 yr	M *
RNS Pump A Suction Isolation	RNS-PL-V005A	6	PB	1 yr	M **
RNS Pump B Suction Isolation	RNS-PL-V005B	6	PB	1 yr	M **
RNS HX A Outlet Flow Control	RNS-PL-V006A	6	PB	1 yr	M **
RNS HX B Outlet Flow Control	RNS-PL-V006B	6	PB	1 yr	M **
RNS Pump A Discharge Isolation	RNS-PL-V007A	6	PB	1 yr	M **
RNS Pump B Discharge Isolation	RNS-PL-V007B	6	PB	1 yr	M **
RNS HX A Bypass Flow Control	RNS-PL-V008A	6	PB	1 yr	M **
RNS HX B Bypass Flow Control	RNS-PL-V008B	6	PB	1 yr	M **
RNS Discharge Containment Isolation Valve Test	RNS-PL-V010	6	PB	1 yr	M **
RNS Discharge Containment Isolation Valve Test Connection	RNS-PL-V014	1	PB	1 yr	M *
RNS Discharge Containment Penetration Isolation Valves Test	RNS-PL-V016	1	PB	1 yr	M *
RNS Discharge to IRWST Isolation	RNS-PL-V024	1	PB	1 yr	M *
RNS Discharge to CVS	RNS-PL-V029	1	PB	1 yr	M *
RNS Train A Discharge Flow Instrument Isolation	RNS-PL-V031A	6	PB	1 yr	M **
RNS Train B Discharge Flow Instrument Isolation	RNS-PL-V031B	6	PB	1 yr	M **
RNS Train A Discharge Flow Instrument Isolation	RNS-PL-V032A	6	PB	1 yr	M **
RNS Train B Discharge Flow Instrument Isolation	RNS-PL-V032B	6	PB	1 yr	M **
RNS Pump A Suction Pressure Instrument Isolation	RNS-PL-V033A	6	PB	1 yr	M **
RNS Pump B Suction Pressure Instrument Isolation	RNS-PL-V033B	6	PB	1 yr	M **
RNS Pump A Discharge Pressure Instrument Isolation	RNS-PL-V034A	6	PB	1 yr	M **
RNS Pump B Discharge Pressure Instrument Isolation	RNS-PL-V034B	6	PB	1 yr	M **
RNS Pump A Suction Piping Drain Isolation	RNS-PL-V036A	6	PB	1 yr	M **

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 44 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)	
RNS Pump B Suction Piping Drain Isolation	RNS-PL-V036B	6	PB	1 yr	M **	RN-12-055
RNS Pump Discharge Relief	RNS-PL-V045	6	PB	1 yr	M **	RN-15-002
RNS Pump Seal Cooler A Vent Isolation	RNS-PL-V048A	6	PB	1 yr	M **	RN-12-007
RNS Pump Seal Cooler B Vent Isolation	RNS-PL-V048B	6	PB	1 yr	M **	
RNS Pump Seal Cooler A Drain Isolation	RNS-PL-V049A	6	PB	1 yr	M **	
RNS Pump Seal Cooler B Drain Isolation	RNS-PL-V049B	6	PB	1 yr	M **	
RNS Pump A Casing Drain Isolation	RNS-PL-V050	6	PB	1 yr	M **	
RNS Pump B Casing Drain Isolation	RNS-PL-V051	6	PB	1 yr	M **	
RNS Suction from SFP Isolation	RNS-PL-V052	6	PB	1 yr	M **	
RNS Discharge to SFP Isolation	RNS-PL-V053	6	PB	1 yr	M **	
RNS Suction from Cask Loading Pit Isolation Valve	RNS-PL-V055	6	PB	1 yr	M **	
RNS Pump Suction to Cask Loading Pit Isolation	RNS-PL-V056	6	PB	1 yr	M **	
RNS Train A Miniflow Isolation Valve	RNS-PL-V057A	6	PB	1 yr	M **	
RNS Train B Miniflow Isolation Valve	RNS-PL-V057B	6	PB	1 yr	M **	
RNS Pump Suction Containment Isolation Test Connection	RNS-PL-V059	6	PB	1 yr	M **	
RNS Discharge Drain Valve	RNS-PL-V065	6	PB	1 yr	M **	RN-12-006
RNS Discharge to DVI Line A Drain	RNS-PL-V066A	1	PB	1 yr	M *	
RNS Discharge to DVI Line B Drain	RNS-PL-V066B	1	PB	1 yr	M *	
RNS Discharge to DVI Line A Drain	RNS-PL-V067A	1	PB	1 yr	M *	
RNS Discharge to DVI Line B Drain	RNS-PL-V067B	1	PB	1 yr	M *	
RNS Discharge to IRWST Drain	RNS-PL-V068	1	PB	1 yr	M *	
RNS HX A Channel Head Drain Isolation	RNS-PL-V071A	6	PB	1 yr	M **	RN-12-055
RNS HX B Channel Head Drain Isolation	RNS-PL-V071B	6	PB	1 yr	M **	
RNS HX A Channel Head Drain Isolation	RNS-PL-V072A	6	PB	1 yr	M **	
RNS HX B Channel Head Drain Isolation	RNS-PL-V072B	6	PB	1 yr	M **	
RNS HX A Channel Head Drain Isolation	RNS-PL-V073A	6	PB	1 yr	M **	

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 45 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
RNS HX B Channel Head Drain Isolation	RNS-PL-V073B	6	PB	1 yr	M **
RNS HX A Channel Head Drain Isolation	RNS-PL-V074A	6	PB	1 yr	M **
RNS HX B Channel Head Drain Isolation	RNS-PL-V074B	6	PB	1 yr	M **
RNS HX A Channel Head Drain Isolation	RNS-PL-V075A	6	PB	1 yr	M **
RNS HX B Channel Head Drain Isolation	RNS-PL-V075B	6	PB	1 yr	M **
LT019A Root Isolation Valve	SFS-PL-V024A	6	PB	1 yr	M **
LT019B Root Isolation Valve	SFS-PL-V024B	6	PB	1 yr	M **
LT019C Root Isolation Valve	SFS-PL-V024C	6	PB	1 yr	M **
LT020 Root Isolation Valve	SFS-PL-V028	6	PB	1 yr	M **
SFS Refueling Cavity Drain to SGS Compartment Isolation Limit Switch	SFS-PL-V031	1	PB	1 yr	M *
	SFS-PL-V031-L	1	PAMS	1 yr	E *
SFS Refueling Cavity Suction Isolation	SFS-PL-V032	1	PB	1 yr	M *
SFS Refueling Cavity Drain to Containment Sump Isolation Limit Switch	SFS-PL-V033	1	PB	1 yr	M *
	SFS-PL-V033-L	1	PAMS	1 yr	E *
SFS Suction Line from IRWST Isolation	SFS-PL-V039	1	PB	1 yr	M *
SFS Fuel Transfer Canal Suction Isolation	SFS-PL-V040	6	PB	1 yr	M **
SFS Cask Loading Pit Suction Isolation	SFS-PL-V041	6	PB	1 yr	M **
Cask Loading Pit Level Transmitter Root Isolation Valve	SFS-PL-V043	6	PB	1 yr	M **
SFS Containment Penetration Test Connection	SFS-PL-V048	6	PB	1 yr	M **
SFS Containment Penetration Test Connection Isolation	SFS-PL-V056	1	PB	1 yr	M *
SFS Containment Isolation Valve V034 Test	SFS-PL-V058	1	PB	1 yr	M *
SFS Containment Floodup Isolation Valve Limit Switch	SFS-PL-V075	1	PB	1 yr	M *
	SFS-PL-V075-L	1	PAMS	1 yr	E *

RN-12-055

RN-16-015

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 46 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Refueling Cavity Drain Line Test Connection	SFS-PL-V117	1	PB	1 yr	M *
LT001 Root Isolation Valve	SGS-PL-V001A	1	PB	1 yr	M *
LT005 Root Isolation Valve	SGS-PL-V001B	1	PB	1 yr	M *
LT001 Root Isolation Valve	SGS-PL-V002A	1	PB	1 yr	M *
LT005 Root Isolation Valve	SGS-PL-V002B	1	PB	1 yr	M *
LT002 Root Isolation Valve	SGS-PL-V003A	1	PB	1 yr	M *
LT006 Root Isolation Valve	SGS-PL-V003B	1	PB	1 yr	M *
LT002 Root Isolation Valve	SGS-PL-V004A	1	PB	1 yr	M *
LT006 Root Isolation Valve	SGS-PL-V004B	1	PB	1 yr	M *
LT003 Root Isolation Valve	SGS-PL-V005A	1	PB	1 yr	M *
LT007 Root Isolation Valve	SGS-PL-V005B	1	PB	1 yr	M *
LT003 Root Isolation Valve	SGS-PL-V006A	1	PB	1 yr	M *
LT007 Root Isolation Valve	SGS-PL-V006B	1	PB	1 yr	M *
LT004 Root Isolation Valve	SGS-PL-V007A	1	PB	1 yr	M *
LT008 Root Isolation Valve	SGS-PL-V007B	1	PB	1 yr	M *
LT004 Root Isolation Valve	SGS-PL-V008A	1	PB	1 yr	M *
LT008 Root Isolation Valve	SGS-PL-V008B	1	PB	1 yr	M *
LT011 Root Isolation Valve	SGS-PL-V010A	1	PB	1 yr	M *
LT013 Root Isolation Valve	SGS-PL-V010B	1	PB	1 yr	M *
LT011 Root Isolation Valve	SGS-PL-V011A	1	PB	1 yr	M *
LT013 Root Isolation Valve	SGS-PL-V011B	1	PB	1 yr	M *
LT012 Root Isolation Valve	SGS-PL-V012A	1	PB	1 yr	M *
LT014 Root Isolation Valve	SGS-PL-V012B	1	PB	1 yr	M *
LT012 Root Isolation Valve	SGS-PL-V013A	1	PB	1 yr	M *
LT014 Root Isolation Valve	SGS-PL-V013B	1	PB	1 yr	M *
FT021 Root Isolation Valve	SGS-PL-V015A	1	PB	1 yr	M *
FT023 Root Isolation Valve	SGS-PL-V015B	1	PB	1 yr	M *
FT020 Root Isolation Valve	SGS-PL-V016A	1	PB	1 yr	M *
FT022 Root Isolation Valve	SGS-PL-V016B	1	PB	1 yr	M *
FT021 Root Isolation Valve	SGS-PL-V017A	1	PB	1 yr	M *
FT023 Root Isolation Valve	SGS-PL-V017B	1	PB	1 yr	M *
FT020 Root Isolation Valve	SGS-PL-V018A	1	PB	1 yr	M *
FT022 Root Isolation Valve	SGS-PL-V018B	1	PB	1 yr	M *
Main Steam Line Vent Isolation	SGS-PL-V019A	1	PB	1 yr	M *
Main Steam Line Vent Isolation	SGS-PL-V019B	1	PB	1 yr	M *
PT030 Root Isolation Valve	SGS-PL-V022A	1	PB	1 yr	M *
PT034 Root Isolation Valve	SGS-PL-V022B	1	PB	1 yr	M *
PT031 Root Isolation Valve	SGS-PL-V023A	5	PB	1 yr	M *

RN-14-077

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 47 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
PT035 Root Isolation Valve	SGS-PL-V023B	5	PB	1 yr	M *
PT032 Root Isolation Valve	SGS-PL-V024A	1	PB	1 yr	M *
PT036 Root Isolation Valve	SGS-PL-V024B	1	PB	1 yr	M *
PT033 Root Isolation Valve	SGS-PL-V025A	5	PB	1 yr	M *
PT037 Root Isolation Valve	SGS-PL-V025B	5	PB	1 yr	M *
Steam Line 1 Nitrogen Supply Isolation	SGS-PL-V038A	5	PB	1 yr	M *
Steam Line 2 Nitrogen Supply Isolation	SGS-PL-V038B	5	PB	1 yr	M *
MSIV Bypass Control Isolation	SGS-PL-V042A	5	PB	1 yr	M *
MSIV Bypass Control Isolation	SGS-PL-V042B	5	PB	1 yr	M *
MSIV Bypass Control Isolation	SGS-PL-V043A	5	PB	1 yr	M *
MSIV Bypass Control Isolation	SGS-PL-V043B	5	PB	1 yr	M *
SG1 Condensate Pipe Drain Valve	SGS-PL-V045A	5	PB	1 yr	M *
SG2 Condensate Pipe Drain Valve	SGS-PL-V045B	5	PB	1 yr	M *
LT015 Root Isolation Valve	SGS-PL-V046A	1	PB	1 yr	M *
LT017 Root Isolation Valve	SGS-PL-V046B	1	PB	1 yr	M *
LT015 Root Isolation Valve	SGS-PL-V047A	1	PB	1 yr	M *
LT017 Root Isolation Valve	SGS-PL-V047B	1	PB	1 yr	M *
LT016 Root Isolation Valve	SGS-PL-V048A	1	PB	1 yr	M *
LT018 Root Isolation Valve	SGS-PL-V048B	1	PB	1 yr	M *
LT016 Root Isolation Valve	SGS-PL-V049A	1	PB	1 yr	M *
LT018 Root Isolation Valve	SGS-PL-V049B	1	PB	1 yr	M *
LT044 Root Isolation Valve	SGS-PL-V050A	1	PB	1 yr	M *
LT046 Root Isolation Valve	SGS-PL-V050B	1	PB	1 yr	M *
LT044 Root Isolation Valve	SGS-PL-V051A	1	PB	1 yr	M *
LT046 Root Isolation Valve	SGS-PL-V051B	1	PB	1 yr	M *
LT045 Root Isolation Valve	SGS-PL-V052A	1	PB	1 yr	M *
LT047 Root Isolation Valve	SGS-PL-V052B	1	PB	1 yr	M *
LT045 Root Isolation Valve	SGS-PL-V053A	1	PB	1 yr	M *
LT047 Root Isolation Valve	SGS-PL-V053B	1	PB	1 yr	M *
PT062 Root Isolation Valve	SGS-PL-V056A	5	PB	1 yr	M *
PT063 Root Isolation Valve	SGS-PL-V056B	5	PB	1 yr	M *
Main Feedwater Check	SGS-PL-V058A	5	PB	1 yr	M *
Main Feedwater Check	SGS-PL-V058B	5	PB	1 yr	M *
FT055A Root Isolation Valve	SGS-PL-V062A	5	PB	1 yr	M *
FT056A Root Isolation Valve	SGS-PL-V062B	5	PB	1 yr	M *
FT055A Root Isolation Valve	SGS-PL-V063A	5	PB	1 yr	M *
FT056A Root Isolation Valve	SGS-PL-V063B	5	PB	1 yr	M *
FT055A Root Isolation Valve	SGS-PL-V064A	5	PB	1 yr	M *

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 48 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
FT056A Root Isolation Valve	SGS-PL-V064B	5	PB	1 yr	M *
FT055A Root Isolation Valve	SGS-PL-V065A	5	PB	1 yr	M *
FT056A Root Isolation Valve	SGS-PL-V065B	5	PB	1 yr	M *
FT055 Root Isolation Valve	SGS-PL-V066A	5	PB	1 yr	M*
FT056 Root Isolation Valve	SGS-PL-V066B	5	PB	1 yr	M*
FT055 Root Isolation Valve	SGS-PL-V068A	5	PB	1 yr	M*
FT056 Root Isolation Valve	SGS-PL-V068B	5	PB	1 yr	M*
SG1 Nitrogen Sparging Isolation	SGS-PL-V084A	1	PB	1 yr	M *
SG2 Nitrogen Sparging Isolation	SGS-PL-V084B	1	PB	1 yr	M *
Orifice Isolation Valve	SGS-PL-V093A	5	PB	1 yr	M *
Orifice Isolation Valve	SGS-PL-V093B	5	PB	1 yr	M *
Orifice Cleanout Line Isolation Valve	SGS-PL-V094A	5	PB	1 yr	M *
Orifice Cleanout Line Isolation Valve	SGS-PL-V094B	5	PB	1 yr	M *
Orifice Isolation Valve	SGS-PL-V095A	5	PB	1 yr	M *
Orifice Isolation Valve	SGS-PL-V095B	5	PB	1 yr	M *
Steam Line Condensate Drain Level Isolation Valve	SGS-PL-V096A	5	PB	1 yr	M *
Steam Line Condensate Drain Level Isolation Valve	SGS-PL-V096B	5	PB	1 yr	M *
Steam Line Condensate Drain Level Isolation Valve	SGS-PL-V097A	5	PB	1 yr	M *
Steam Line Condensate Drain Level Isolation Valve	SGS-PL-V097B	5	PB	1 yr	M *
Startup Feedwater Drain Isolation Valve	SGS-PL-V100A	5	PB	1 yr	M*
Startup Feedwater Drain Isolation Valve	SGS-PL-V100B	5	PB	1 yr	M*
Main Feedwater Drain Isolation Valve	SGS-PL-V101A	5	PB	1 yr	M*
Main Feedwater Drain Isolation Valve	SGS-PL-V101B	5	PB	1 yr	M*
Startup Feedwater Vent Isolation Valve	SGS-PL-V102A	5	PB	1 yr	M*
Startup Feedwater Vent Isolation Valve	SGS-PL-V102B	5	PB	1 yr	M*
Main Feedwater Vent Isolation Valve	SGS-PL-V103A	5	PB	1 yr	M*
Main Feedwater Vent Isolation Valve	SGS-PL-V103B	5	PB	1 yr	M*
Main Feedwater Drain Isolation Valve	SGS-PL-V104A	5	PB	1 yr	M*
Main Feedwater Drain Isolation Valve	SGS-PL-V104B	5	PB	1 yr	M*

RN-16-015

RN-15-049

RN-15-049

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 49 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Startup Feedwater Check Valve	SGS-PL-V256A	5	PB	1 yr	M *
Startup Feedwater Check Valve	SGS-PL-V256B	5	PB	1 yr	M *
Air Delivery Line Pressure Instrument Isolation Valve A	VES-PL-V006A	7	PB	1 yr	M
Air Delivery Line Pressure Instrument Isolation Valve B	VES-PL-V006B	7	PB	1 yr	M
Air Delivery Line Maintenance Isolation Valve A	VES-PL-V010A	7	PB	1 yr	M
Air Delivery Line Maintenance Isolation Valve B	VES-PL-V010B	7	PB	1 yr	M
Air Delivery Line Maintenance Isolation Valve A	VES-PL-V011A	7	PB	1 yr	M
Air Delivery Line Maintenance Isolation Valve B	VES-PL-V011B	7	PB	1 yr	M
Temporary Instrument Isolation Valve A	VES-PL-V016	7	PB	1 yr	M
Temporary Instrument Isolation Valve A	VES-PL-V018	7	PB	1 yr	M
Temporary Instrument Isolation Valve B	VES-PL-V019	7	PB	1 yr	M
Temporary Instrument Isolation Valve B	VES-PL-V020	7	PB	1 yr	M
Air Bank 1 Isolation Valve A	VES-PL-V024A	7	PB	1 yr	M
Air Bank 2 Isolation Valve B	VES-PL-V024B	7	PB	1 yr	M
Air Bank 3 Isolation Valve C	VES-PL-V024C	7	PB	1 yr	M
Air Bank 4 Isolation Valve D	VES-PL-V024D	7	PB	1 yr	M
Air Bank 1 Isolation Valve A	VES-PL-V025A	7	PB	1 yr	M
Air Bank 2 Isolation Valve B	VES-PL-V025B	7	PB	1 yr	M
Air Bank 3 Isolation Valve C	VES-PL-V025C	7	PB	1 yr	M
Air Bank 4 Isolation Valve D	VES-PL-V025D	7	PB	1 yr	M
Air Bank 1 Fill/Vent Isolation Valve A	VES-PL-V026A	7	PB	1 yr	M
Air Bank 2 Fill/Vent Isolation Valve B	VES-PL-V026B	7	PB	1 yr	M
Air Bank 3 Fill/Vent Isolation Valve C	VES-PL-V026C	7	PB	1 yr	M
Air Bank 4 Fill/Vent Isolation Valve D	VES-PL-V026D	7	PB	1 yr	M
DP Instrument Line Isolation Valve A	VES-PL-V043A	3	PB	1 yr	M
DP Instrument Line Isolation Valve B	VES-PL-V043B	3	PB	1 yr	M
Containment Isolation Test Connection	VFS-PL-V008	6	PB	1 yr	M **
Containment Isolation Test Connection	VFS-PL-V012	1	PB	1 yr	M *
Containment Isolation Test Connection	VFS-PL-V015	1	PB	1 yr	M *

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 50 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Main Equipment Hatch Test Connection	VUS-PL-V015	7	PB	1 yr	M
Maintenance Equipment Hatch Test Connection	VUS-PL-V016	7	PB	1 yr	M
Personnel Hatch Test Connection	VUS-PL-V017	7	PB	1 yr	M
Personnel Hatch Test Connection	VUS-PL-V018	7	PB	1 yr	M
Personnel Hatch Test Connection	VUS-PL-V019	7	PB	1 yr	M
Personnel Hatch Test Connection	VUS-PL-V020	7	PB	1 yr	M
Personnel Hatch Test Connection	VUS-PL-V021	7	PB	1 yr	M
Personnel Hatch Test Connection	VUS-PL-V022	7	PB	1 yr	M
Fuel Transfer Tube Test Connection	VUS-PL-V023	1	PB	1 yr	M *
Spare Penetration Test Connection	VUS-PL-V140	6	PB	1 yr	M **
Spare Penetration Test Connection	VUS-PL-V141	6	PB	1 yr	M **
Spare Penetration Test Connection	VUS-PL-V142	6	PB	1 yr	M **
VWS Supply Containment Penetration IRC Test Connection/Vent	VWS-PL-V424	1	PB	1 yr	M *
VWS Return Containment Penetration ORC Test Connection/Vent	VWS-PL-V425	2	PB	1 yr	M
WWS Main Control Room Isolation Valve	WWS-PL-V506	3	PB	1 yr	M
Heat Exchangers					
Normal Residual Heat Removal Heat Exchanger A	RNS-ME-01A	6	PB	1 yr	M **
Normal Residual Heat Removal Heat Exchanger B	RNS-ME-01B	6	PB	1 yr	M **
Tanks					
Spent Fuel Pool	FHS-MT-01	11	ESF	1 yr	M **
Fuel Transfer Canal	FHS-MT-02	11	ESF	1 yr	M **
Spent Fuel Cask Loading Pit	FHS-MT-05	6	ESF	1 yr	M **
Passive Containment Cooling Water Storage Tank	PCS-MT-01	9	ESF	1 yr	M
Water Distribution Bucket	PCS-MT-03	9	ESF	1 yr	M
Water Collection Troughs	PCS-MT-04	9	ESF	1 yr	M
Passive RHR Heat Exchanger	PXS-ME-01	1	ESF	1 yr	M *
Accumulator Tank A	PXS-MT-01A	1	ESF	1 yr	M *
Accumulator Tank B	PXS-MT-01B	1	ESF	1 yr	M *
Core Makeup Tank A	PXS-MT-02A	1	ESF	1 yr	M *
Core Makeup Tank B	PXS-MT-02B	1	ESF	1 yr	M *
In-Containment Refueling Water Storage Tank	PXS-MT-03	1	ESF	1 yr	M *

RN-15-046

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

Table 3.11-1 (Sheet 51 of 51)
Environmentally Qualified Electrical and Mechanical Equipment

Description	AP1000 Tag No.	Envir. Zone (Note 2)	Function (Note 1)	Operating Time Required (Note 5)	Qualification Program (Note 6)
Emergency Air Storage Tank 01	VES-MT-01	7	ESF	1 yr	M
Emergency Air Storage Tank 02	VES-MT-02	7	ESF	1 yr	M
Emergency Air Storage Tank 03	VES-MT-03	7	ESF	1 yr	M
Emergency Air Storage Tank 04	VES-MT-04	7	ESF	1 yr	M
Emergency Air Storage Tank 05	VES-MT-05	7	ESF	1 yr	M
Emergency Air Storage Tank 06	VES-MT-06	7	ESF	1 yr	M
Emergency Air Storage Tank 07	VES-MT-07	7	ESF	1 yr	M
Emergency Air Storage Tank 08	VES-MT-08	7	ESF	1 yr	M
Emergency Air Storage Tank 09	VES-MT-09	7	ESF	1 yr	M
Emergency Air Storage Tank 10	VES-MT-10	7	ESF	1 yr	M
Emergency Air Storage Tank 11	VES-MT-11	7	ESF	1 yr	M
Emergency Air Storage Tank 12	VES-MT-12	7	ESF	1 yr	M
Emergency Air Storage Tank 13	VES-MT-13	7	ESF	1 yr	M
Emergency Air Storage Tank 14	VES-MT-14	7	ESF	1 yr	M
Emergency Air Storage Tank 15	VES-MT-15	7	ESF	1 yr	M
Emergency Air Storage Tank 16	VES-MT-16	7	ESF	1 yr	M
Emergency Air Storage Tank 17	VES-MT-17	7	ESF	1 yr	M
Emergency Air Storage Tank 18	VES-MT-18	7	ESF	1 yr	M
Emergency Air Storage Tank 19	VES-MT-19	7	ESF	1 yr	M
Emergency Air Storage Tank 20	VES-MT-20	7	ESF	1 yr	M
Emergency Air Storage Tank 21	VES-MT-21	7	ESF	1 yr	M
Emergency Air Storage Tank 22	VES-MT-22	7	ESF	1 yr	M
Emergency Air Storage Tank 23	VES-MT-23	7	ESF	1 yr	M
Emergency Air Storage Tank 24	VES-MT-24	7	ESF	1 yr	M
Emergency Air Storage Tank 25	VES-MT-25	7	ESF	1 yr	M
Emergency Air Storage Tank 26	VES-MT-26	7	ESF	1 yr	M
Emergency Air Storage Tank 27	VES-MT-27	7	ESF	1 yr	M
Emergency Air Storage Tank 28	VES-MT-28	7	ESF	1 yr	M
Emergency Air Storage Tank 29	VES-MT-29	7	ESF	1 yr	M
Emergency Air Storage Tank 30	VES-MT-30	7	ESF	1 yr	M
Emergency Air Storage Tank 31	VES-MT-31	7	ESF	1 yr	M
Emergency Air Storage Tank 32	VES-MT-32	7	ESF	1 yr	M
Main Feed Pump A Breaker Auxiliary Switch (Status)	FWS-MP-02A(52)	8	PAMS	2 wks	E +
Main Feed Pump B Breaker Auxiliary Switch (Status)	FWS-MP-02B(52)	8	PAMS	2 wks	E +
Main Feed Pump C Breaker Auxiliary Switch (Status)	FWS-MP-02C(52)	8	PAMS	2 wks	E+

RN-15-090

Notes:

1. RT (Reactor Trip), ESF (Engineered Safeguards Feature), PAMS (Post-Accident Monitoring), ISOL (Isolation), PB (Pressure Boundary); all active valves in this table have "PB-1 yr" in addition to any other requirements.
2. Zones identified in [Table 3D.5-1](#)
3. Not required post-accident

V.C. Summer Nuclear Station, Units 2 and 3
Updated Final Safety Analysis Report

4. Note deleted
5. Reference **Table 3D.4-2**
6. E = Electrical Equipment Program
M=Mechanical Equipment Program
* = Harsh Environment
** = Radiation-Harsh Environment (See **Appendix 3D, Subsection 3D.4.3.**)
+ = Seismic Qualification not required
S = Qualified for operation with spray from a moderate-energy pipe crack or spray from a cold high energy pipe crack.
7. The Protection and Safety Monitoring Cabinets will be qualified to meet the function operating times identified in this table.