

**From:** [Miller, Stephen](#)  
**To:** [Montgomery, Cindy](#)  
**Subject:** [External\_Sender] Cooling tower secondary water treatment  
**Date:** Monday, September 26, 2016 3:40:18 PM

---

Dear Ms. Montgonery;

in response to our recent discussion,

For the secondary coolant system, a commercial cooling water treatment system is used to control growth of organisms, keep the stainless steel heat exchanger surfaces clean, and prevent corrosion and scale. These chemicals are highly diluted and possess minimal hazards to the environment and operating staff.

If you require additional information please advise.

Stephen Miller  
Head, Radiation Sciences Department  
Armed Forces Radiobiology Research Institute  
Uniformed Services University of the Health Sciences  
[stephen.miller@usuhs.edu](mailto:stephen.miller@usuhs.edu)  
(301) 295-9245