

## Staff Feedback on KHNP Responses to RAI Question 3.7.1-2

In letter MKD/NW-16-0887L, dated August 12, 2016

### 1 Staff Feedback provided on August 18, 2016

Per staff's request, the applicant provided the justification on its application of low pass filters on the CSDRS matched design time histories through an email attachment "**3.7\_1 Response to Staff feedback (DCD 3.7.1) on Synthetic Acceleration Time Histories.pdf**". The staff reviewed the applicant's response to the feedback and found the information contained therein acceptable. Therefore, the applicant is requested to incorporate the staff feedback and the applicant's justification, which are documented in the file described above in bold, into the RAI response to RAI Question 3.7.1-2. This request is for the purpose of documenting the technical resolution in support of the appropriate regulatory findings in the staff's safety evaluation of APR1400 DCD Section 3.7.1.