

Final Safety Evaluation Report for Combined Licenses for Turkey Point Units 6 and 7

U. S. Nuclear Regulatory Commission
Office of New Reactors
Washington, DC 20555-0001

November 2016

ABSTRACT

This final safety evaluation report¹ (FSER) documents the U.S. Nuclear Regulatory Commission (NRC) staff's technical review of the combined license (COL) application submitted by the applicant for Turkey Point Units 6 and 7 by Florida Power & Light Company (FPL).

By letter dated June 30, 2009, the applicant submitted its application to the NRC for COLs for two AP1000 advanced passive pressurized-water reactors pursuant to the requirements of Sections 103 and 185(b) of the Atomic Energy Act of 1954, as amended; Title 10 of the *Code of Federal Regulations* (10 CFR) Part 52, "Licenses, certifications and approvals for nuclear power plants," and the associated material licenses under 10 CFR Part 30, "Rules of general applicability to domestic licensing of byproduct material"; 10 CFR Part 40, "Domestic licensing of source material"; and 10 CFR Part 70, "Domestic licensing of special nuclear material." These reactors are identified as Turkey Point Units 6 and 7, and would be located on the Turkey Point plant property, comprised of approximately 9,400 acres (38 square km) in unincorporated southeast Miami-Dade County, Florida, east of Florida City and the City of Homestead and bordered by Biscayne Bay to the east. The applicant submitted its final update to the COL application, Revision 8, on August 26, 2016.

The application incorporated by reference 10 CFR Part 52, Appendix D, "Design Certification Rule for the AP1000 Design," including the AP1000 Design Certification Document (DCD) Revision 19. The results of the NRC staff's evaluation of the AP1000 DCD are documented in NUREG-1793, "Final Safety Evaluation Report Related to Certification of the AP1000 Standard Design," and its supplements.

This FSER presents the results of the staff's review of information submitted in conjunction with the COL application, except those matters resolved as part of the referenced design certification rule. Appendix A to this FSER identifies certain license conditions and inspections, tests, analyses and acceptance criteria (ITAAC) that the staff recommends the Commission impose, should COLs be issued to the applicant. In addition to the ITAAC in Appendix A, the ITAAC found in the AP1000 DCD Revision 19 Tier 1 material will also be incorporated into the COLs, should COLs be issued to the applicant.

¹ This FSER documents the NRC staff's position on all safety issues associated with the combined license application. The Advisory Committee on Reactor Safeguards (ACRS) independently reviewed those aspects of the application that concern safety, as well as the advanced safety evaluation report without open items (an earlier version of this document), and provided the results of its review to the Commission in reports dated April 18, 2016 and September 16, 2016. These reports are included as Appendix F to this FSER.

The staff's review² of the application, as documented in this FSER, supports the following conclusions with respect to the safety aspects of the COL application: 1) the applicable standards and requirements of the Atomic Energy Act and Commission regulations have been met; 2) required notifications to other agencies or bodies have been duly made; 3) there is reasonable assurance that the facility will be constructed and will operate in conformity with the license, the provisions of the Atomic Energy Act, and the Commission's regulations; 4) the applicant is technically and financially qualified to engage in the activities authorized; and 5) issuance of the license will not be inimical to the common defense and security or to the health and safety of the public.

² An environmental review was also performed of the COL application, and its evaluation and conclusions are documented in NUREG-2176, "Final Environmental Impact Statement for Combined Licenses for Turkey Point Nuclear Plant Units 6 and 7," dated October 2016.

CONTENTS

The chapter and section layout of this FSER is consistent with the format of (1) NUREG-0800, “Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)”; (2) Regulatory Guide (RG) 1.206, “Combined License Applications for Nuclear Power Plants”; and (3) the applicant’s final safety analysis report (FSAR). Where applicable, references to other regulatory actions (e.g., design certifications) are included in the text of the safety evaluation report (SER).

1.0	INTRODUCTION AND INTERFACES	1-1
1.1	Summary of Application	1-1
1.2	Regulatory Basis	1-4
1.2.1	Applicable Regulations	1-4
1.2.2	Finality of Referenced NRC Approvals	1-6
1.2.3	Overview of the Design-Centered Review Approach	1-6
1.3	Principal Review Matters	1-9
1.4	Staff Review of Turkey Point Units 6 and 7 COL FSAR Chapter 1	1-13
1.4.1	Introduction	1-13
1.4.2	Summary of Application	1-13
1.4.3	Regulatory Basis	1-19
1.4.4	Technical Evaluation	1-21
1.4.5	Post Combined License Activities	1-35
1.4.6	Conclusion	1-35
1.5	Additional Regulatory Considerations	1-35
1.5.1	10 CFR 52.97(a)(1)(iv) Applicant Financial Qualifications and Evaluation of Financial Qualification in Accordance with 10 CFR 50.33	1-35
1.5.2	Nuclear Waste Policy Act	1-44
1.5.3	Consultation with Department of Homeland Security and Notifications	1-45
1.5.3.1	Consultation with Department of Homeland Security	1- Error!
1.5.3.2	Notifications	1-45
1.5.4	Evaluation of Departures and Exemption Associated with Numbering in the Application and Exemption Associated with Special Nuclear Material Material Control and Accounting Program	1-45
1.5.5	Receipt, Possession, Use, and Transport of Source, Byproduct and Special Nuclear Material Authorized by 10 CFR Part 52 Combined Licenses	1-48

1.5.5.1	Physical Protection of Special Nuclear Material	1-62
1.5.5.2	Conclusion and Post Combined License Activities	1-86
2.0	SITE CHARACTERISTICS	2-1
2.0.1	Introduction	2-1
2.0.2	Summary of Application	2-1
2.0.3	Regulatory Basis	2-2
2.0.4	Technical Evaluation	2-4
2.0.5	Post Combined License Activities	2-11
2.0.6	Conclusion	2-12
2.1	Geography and Demography	2-12
2.1.1	Site Location and Description	2-12
2.1.1.1	Introduction	2-12
2.1.1.2	Summary of Application	2-12
2.1.1.3	Regulatory Basis	2-13
2.1.1.4	Technical Evaluation	2-14
2.1.1.5	Post Combined License Activities	2-15
2.1.1.6	Conclusion	2-15
2.1.2	Exclusion Area Authority and Control	2-16
2.1.2.1	Introduction	2-16
2.1.2.2	Summary of Application	2-16
2.1.2.3	Regulatory Basis	2-17
2.1.2.4	Technical Evaluation	2-18
2.1.2.5	Post Combined License Activities	2-19
2.1.2.6	Conclusion	2-20
2.1.3	Population Distribution	2-20
2.1.3.1	Introduction	2-20
2.1.3.2	Summary of Application	2-20
2.1.3.3	Regulatory Basis	2-21
2.1.3.4	Technical Evaluation	2-22
2.1.3.5	Post Combined License Activities	2-24
2.1.3.6	Conclusion	2-24
2.2	Nearby Industrial, Transportation, and Military Facilities	2-25
2.2.1	Locations and Routes	2-25
2.2.1.1	Introduction	2-25
2.2.1.2	Summary of Application	2-25
2.2.1.3	Regulatory Basis	2-26
2.2.1.4	Technical Evaluation	2-27
2.2.1.5	Post Combined License Activities	2-30
2.2.1.6	Conclusion	2-30
2.2.2	Descriptions	2-31
2.2.3	Evaluation of Potential Accidents	2-31
2.2.3.1	Introduction	2-31
2.2.3.2	Summary of Application	2-31
2.2.3.3	Regulatory Basis	2-32
2.2.3.4	Technical Evaluation	2-33
2.2.3.5	Post Combined License Activities	2-37
2.2.3.6	Conclusion	2-37

2.3	Meteorology.....	2-37
2.3.1	Regional Climatology.....	2-38
2.3.1.2	Introduction	2-38
2.3.1.2	Summary of Application	2-38
2.3.1.3	Regulatory Basis.....	2-39
2.3.1.4	Technical Evaluation.....	2-41
2.3.1.5	Post Combined License Activities.....	2-51
2.3.1.6	Conclusion	2-51
2.3.2	Local Meteorology	2-52
2.3.2.1	Introduction	2-52
2.3.2.2	Summary of Application	2-52
2.3.2.3	Regulatory Basis.....	2-52
2.3.2.4	Technical Evaluation.....	2-53
2.3.2.5	Post Combined License Activities.....	2-59
2.3.2.6	Conclusion	2-59
2.3.3	Onsite Meteorological Measurements Program	2-59
2.3.3.1	Introduction	2-59
2.3.3.2	Summary of Application	2-60
2.3.3.3	Regulatory Basis.....	2-60
2.3.3.4	Technical Evaluation.....	2-61
2.3.3.5	Post Combined License Activities.....	2-66
2.3.3.6	Conclusion	2-67
2.3.4	Short-Term Dispersion Estimates for Accident Releases.....	2-67
2.3.4.1	Introduction	2-67
2.3.4.2	Summary of Application	2-68
2.3.4.3	Regulatory Basis.....	2-68
2.3.4.4	Technical Evaluation.....	2-70
2.3.4.5	Post Combined License Activities.....	2-75
2.3.4.6	Conclusion	2-75
2.3.5	Long-Term Atmospheric Diffusion Estimates for Routine Releases.....	2-76
2.3.5.1	Introduction	2-76
2.3.5.2	Summary of Application	2-76
2.3.5.3	Regulatory Basis.....	2-76
2.3.5.4	Technical Evaluation.....	2-78
2.3.5.5	Post Combined License Activities.....	2-81
2.3.5.6	Conclusion	2-81
2.4	Hydrologic Engineering	2-81
2.4.1	Hydrologic Description.....	2-82
2.4.1.1	Introduction	2-82
2.4.1.2	Summary of Application	2-82
2.4.1.3	Regulatory Basis.....	2-83
2.4.1.4	Technical Evaluation.....	2-83
2.4.1.5	Post Combined License Activities.....	2-91
2.4.1.6	Conclusion	2-91
2.4.2	Floods.....	2-92
2.4.2.1	Introduction	2-92
2.4.2.2	Summary of Application	2-92
2.4.2.3	Regulatory Basis.....	2-93

2.4.2.2	Technical Evaluation.....	2-93
2.4.2.4.4	Combined Flooding Events.....	2-102
2.4.2.5	Post Combined License Activities.....	2-103
2.4.2.6	Conclusion.....	2-103
2.4.3	Probable Maximum Flood On Streams and Rivers.....	2-104
2.4.3.1	Introduction.....	2-104
2.4.3.2	Summary of Application.....	2-104
2.4.3.3	Regulatory Basis.....	2-104
2.4.3.4	Technical Evaluation.....	2-105
2.4.3.5	Post Combined License Activities.....	2-107
2.4.3.6	Conclusions.....	2-107
2.4.4	Potential Dam Failures.....	2-108
2.4.4.1	Introduction.....	2-108
2.4.4.2	Summary of Application.....	2-108
2.4.4.3	Regulatory Basis.....	2-108
2.4.4.2	Technical Evaluation.....	2-109
2.4.4.5	Post Combined License Activities.....	2-111
2.4.4.6	Conclusion.....	2-111
2.4.5	Probable Maximum Surge and Seiche Flooding.....	2-111
2.4.5.1	Introduction.....	2-111
2.4.5.2	Summary of Application.....	2-112
2.4.5.3	Regulatory Basis.....	2-112
2.4.5.4	Technical Evaluation.....	2-113
2.4.5.5	Post Combined License Activities.....	2-139
2.4.5.6	Conclusion.....	2-139
2.4.6	Probable Maximum Tsunami Hazards.....	2-139
2.4.6.1	Introduction.....	2-139
2.4.6.2	Summary of Application.....	2-140
2.4.6.3	Regulatory Basis.....	2-140
2.4.6.4	Technical Evaluation.....	2-141
2.4.6.5	Conclusions.....	2-165
2.4.7	Ice Effects.....	2-166
2.4.7.1	Introduction.....	2-166
2.4.7.2	Summary of Application.....	2-166
2.4.7.3	Regulatory Basis.....	2-166
2.4.7.4	Technical Evaluation.....	2-167
2.4.7.5	Post Combined License Activities.....	2-169
2.4.7.6	Conclusions.....	2-169
2.4.8	Cooling Water Canals and Reservoirs.....	2-169
2.4.8.1	Introduction.....	2-169
2.4.8.2	Summary of Application.....	2-170
2.4.8.3	Regulatory Basis.....	2-170
2.4.8.4	Technical Evaluation.....	2-171
2.4.8.5	<i>Post Combined License Activities</i>	2-173
2.4.8.6	<i>Conclusions</i>	2-173
2.4.9	Channel Diversions.....	2-173
2.4.9.1	Introduction.....	2-173
2.4.9.2	Summary of Application.....	2-173

2.4.9.3	Regulatory Basis	2-174
2.4.9.4	Technical Evaluation	2-174
2.4.9.5	Post Combined License Activities	2-181
2.4.9.6	Conclusions	2-181
2.4.10	Flooding Protection Requirements	2-181
2.4.10.1	Introduction	2-181
2.4.10.2	Summary of Application	2-182
2.4.10.3	Regulatory Basis	2-182
2.4.10.4	Technical Evaluation	2-182
2.4.10.5	Post Combined License Activities	2-184
2.4.10.6	Conclusions	2-184
2.4.11	Low Water Considerations	2-184
2.4.11.1	Introduction	2-185
2.4.11.2	Summary of Application	2-185
2.4.11.3	Regulatory Basis	2-185
2.4.11.4	Technical Evaluation	2-186
2.4.11.5	Post Combined License Actions	2-187
2.4.11.6	Conclusions	2-187
2.4.12	Groundwater	2-187
2.4.12.1	Introduction	2-187
2.4.12.2	Summary of Application	2-188
2.4.12.3	Regulatory Basis	2-188
2.4.12.4	Technical Evaluation	2-189
2.4.12.5	Post Combined License Activities	2-229
2.4.12.6	Conclusions	2-229
2.4.13	Accidental Release of Radioactive Liquid Effluent in Ground and Surface Waters	2-229
2.4.13.1	Introduction	2-229
2.4.13.2	Summary of Application	2-230
2.4.13.3	Regulatory Basis	2-231
2.4.13.4	Technical Evaluation	2-231
2.4.13.5	Post Combined License Activities	2-240
2.4.13.6	Conclusions	2-240
2.4.14	Technical Specification And Emergency Operation Requirements ...	2-241
2.4.14.1	Introduction	2-241
2.4.14.2	Summary of Application	2-241
2.4.14.3	Regulatory Basis	2-241
2.4.14.4	Technical Evaluation	2-242
2.4.14.5	Post Combined License Activities	2-242
2.4.14.6	Conclusions	2-242
2.5	Geology, Seismology, and Geotechnical Engineering	2-243
2.5.1	Geologic Characterization Information	2-244
2.5.1.1	Introduction	2-244
2.5.1.2	Summary of Application	2-244
2.5.1.3	Regulatory Basis	2-263
2.5.1.4	Technical Evaluation	2-265
2.5.1.5	Post-Combined License Activities	2-317
2.5.1.6	Conclusion	2-317

2.5.2	Vibratory Ground Motion.....	2-318
2.5.2.1	Introduction	2-318
2.5.2.2	Summary of Application	2-318
2.5.2.3	Regulatory Basis.....	2-331
2.5.2.4	Technical Evaluation.....	2-332
2.5.2.5	Post Combined License Activities.....	2-360
2.5.2.6	Conclusion	2-360
2.5.3	Surface Deformation.....	2-361
2.5.3.1	Introduction	2-361
2.5.3.2	Summary of Application	2-361
2.5.3.3	Regulatory Basis.....	2-366
2.5.3.4	Technical Evaluation.....	2-367
2.5.3.5	Post-Combined License Activities.....	2-379
2.5.3.6	Conclusion	2-380
2.5.4	Stability of Subsurface Materials and Foundations.....	2-380
2.5.4.1	Introduction	2-380
2.5.4.2	Summary of Application	2-381
2.5.4.3	Regulatory Basis.....	2-404
2.5.4.4	Technical Evaluation.....	2-408
2.5.4.5	Post Combined License Activities.....	2-440
2.5.4.6	Conclusion	2-440
2.5.5	Stability of Slopes	2-441
2.5.5.1	Introduction	2-441
2.5.5.2	Summary of Application	2-442
2.5.5.3	Regulatory Basis.....	2-443
2.5.5.4	Technical Evaluation.....	2-444
2.5.5.5	Post Combined License Activities.....	2-446
2.5.5.6	Conclusion	2-446
3.0	DESIGN OF STRUCTURES, COMPONENTS, EQUIPMENT, AND SYSTEMS	3-1
3.1	Conformance with NRC General Design Criteria.....	3-1
3.2	Classification of Structures, Components, and Systems	3-1
3.2.1	Seismic Classification	3-1
3.2.1.1	Introduction	3-1
3.2.1.2	Summary of Application	3-2
3.2.1.3	Regulatory Basis.....	3-3
3.2.1.4	Technical Evaluation.....	3-3
3.2.1.5	Post-Combined License Activities.....	3-6
3.2.1.6	Conclusion	3-6
3.2.2	AP1000 Classification Systems (Related to RG 1.206, Section C.III.1, Chapter 3, C.I.3.2.2, "System Quality Group Classification").....	3-6
3.2.2.1	Introduction	3-6
3.2.2.2	Summary of Application	3-7
3.2.2.3	Regulatory Basis.....	3-7
3.2.2.4	Technical Evaluation.....	3-8
3.2.2.5	Post-Combined License Activities.....	3-10

	3.2.2.6	Conclusion	3-10
3.3		Wind and Tornado Loadings	3-11
	3.3.1	Wind Loadings	3-11
	3.3.1.1	Introduction	3-11
	3.3.1.2	Summary of Application	3-11
	3.3.1.3	Regulatory Basis	3-12
	3.3.1.4	Technical Evaluation	3-12
	3.3.1.5	Post-Combined License Activities	3-14
	3.3.1.6	Conclusion	3-14
	3.3.2	Tornado Loading	3-14
	3.3.2.1	Introduction	3-14
	3.3.2.2	Summary of Application	3-15
	3.3.2.3	Regulatory Basis	3-15
	3.3.2.4	Technical Evaluation	3-16
	3.3.2.5	Post-Combined License Activities	3-18
	3.3.2.6	Conclusion	3-19
3.4		Water Level (Flood) Design	3-19
	3.4.1	Flood Protection	3-19
	3.4.1.1	Introduction	3-19
	3.4.1.2	Summary of Application	3-19
	3.4.1.3	Regulatory Basis	3-20
	3.4.1.4	Technical Evaluation	3-20
	3.4.1.5	Post-Combined License Activities	3-21
	3.4.1.6	Conclusion	3-21
	3.4.2	Analytical and Test Procedures (Related to RG 1.206, Section C.III.1, Chapter 3, C.I.3.4.2, "Analysis Procedures")	3-22
3.5		Missile Protection	3-22
	3.5.1	Missile Selection and Description	3-22
	3.5.1.1	Introduction	3-22
	3.5.1.2	Summary of Application	3-23
	3.5.1.3	Regulatory Basis	3-24
	3.5.1.4	Technical Evaluation	3-24
	3.5.1.5	Post-Combined License Activities	3-28
	3.5.1.6	Conclusion	3-28
	3.5.2	Protection from Externally Generated Missiles	3-29
	3.5.2.1	Introduction	3-29
	3.5.2.2	Summary of Application	3-29
	3.5.2.3	Regulatory Basis	3-30
	3.5.2.4	Technical Evaluation	3-30
	3.5.2.5	Post-Combined License Activities	3-32
	3.5.2.6	Conclusion	3-32
	3.5.3	Barrier Design Procedures	3-32
3.6		Protection against Dynamic Effects Associated with the Postulated Rupture of Piping	3-32
	3.6.1	Introduction	3-32
	3.6.2	Summary of Application	3-33
	3.6.3	Regulatory Basis	3-34
	3.6.4	Technical Evaluation	3-34

	3.6.5	Post-Combined License Activities	3-38
	3.6.6	Conclusion	3-39
3.7		Seismic Design	3-39
	3.7.1	Seismic Design Parameters	3-40
	3.7.1.1	Introduction	3-40
	3.7.1.2	Summary of Application	3-40
	3.7.1.3	Regulatory Basis	3-41
	3.7.1.4	Technical Evaluation	3-41
	3.7.1.5	Post-Combined License Activities	3-47
	3.7.1.6	Conclusion	3-47
	3.7.2	Seismic System Analysis	3-47
	3.7.2.1	Introduction	3-47
	3.7.2.2	Summary of Application	3-48
	3.7.2.3	Regulatory Basis	3-49
	3.7.2.4	Technical Evaluation	3-49
	3.7.2.5	Post-Combined License Activities	3-54
	3.7.2.6	Conclusion	3-54
	3.7.3	Seismic Subsystem Analysis	3-54
	3.7.4	Seismic Instrumentation	3-55
	3.7.4.1	Introduction	3-55
	3.7.4.2	Summary of Application	3-56
	3.7.4.3	Regulatory Basis	3-57
	3.7.4.4	Technical Evaluation	3-57
	3.7.4.5	Post-Combined License Activities	3-62
	3.7.4.6	Conclusion	3-62
3.8		Design Of Category I Structures	3-63
	3.8.1	Concrete Containment	3-63
	3.8.2	Steel Containment	3-63
	3.8.3Concrete and Steel Internal Structures of Steel or Concrete Containment	3-64
	3.8.3.1	Introduction	3-64
	3.8.3.2	Summary of Application	3-64
	3.8.4	Other Seismic Category I Structures	3-65
	3.8.4.1	Introduction	3-65
	3.8.4.2	Summary of Application	3-65
	3.8.5	Foundations	3-66
	3.8.5.1	Introduction	3-66
	3.8.5.2	Summary of Application	3-66
	3.8.5.3	Regulatory Basis	3-68
	3.8.5.4	Technical Evaluation	3-68
	3.8.5.5	Post-Combined License Activities	3-74
	3.8.5.6	Conclusion	3-75
3.9		Mechanical Systems and Components	3-76
	3.9.1	Special Topics for Mechanical Components	3-76
	3.9.2	Dynamic Testing and Analysis of Systems, Structures, and Components	3-76
	3.9.3	ASME Code Class 1, 2, and 3 Components, Component Supports, and Core 3 Support Structures	3-77

	3.9.3.1	Introduction	3-77
	3.9.3.2	Summary of Application	3-77
	3.9.3.3	Regulatory Basis	3-79
	3.9.3.4	Technical Evaluation	3-78
	3.9.3.5	Post-Combined License Activities	3-82
	3.9.3.6	Conclusion	3-82
	3.9.4	Control Rod Drive System	3-82
	3.9.5	Reactor Pressure Vessel Internals	3-83
	3.9.6	Inservice Testing of Pumps and Valves (Related to RG 1.206, Section C.III.1, Chapter 3, C.I.3.9.6, "Functional Design, Qualification, and Inservice Testing Programs for Pumps, Valves, and Dynamic Restrains")	3-83
	3.9.6.1	Introduction	3-83
	3.9.6.2	Summary of Application	3-84
	3.9.6.3	Regulatory Basis	3-86
	3.9.6.4	Technical Evaluation	3-87
	3.9.6.5	Post-Combined License Activities	3-100
	3.9.6.6	Conclusion	3-102
	3.9.7	Integrated Head Package	3-102
3.10		Seismic and Dynamic Qualification of Mechanical and Electrical Equipment	3-103
	3.10.1	Introduction	3-103
	3.10.2	Summary of Application	3-103
	3.10.3	Regulatory Basis	3-103
	3.10.4	Technical Evaluation	3-104
	3.10.5	Post-Combined License Activities	3-105
	3.10.6	Conclusion	3-106
3.11		Environmental Qualification of Mechanical and Electrical Equipment	3-106
	3.11.1	Introduction	3-106
	3.11.2	Summary of Application	3-106
	3.11.3	Regulatory Basis	3-107
	3.11.4	Technical Evaluation	3-108
	3.11.5	Post-Combined License Activities	3-114
	3.11.6	Conclusion	3-115
3.12		Piping Design (Related to RG 1.206, Section C.III.1, Chapter 3, C.I.3.12, "Piping Design Review")	3-115
	3.12.1	Introduction	3-115
	3.12.2	Summary of Application	3-115
	3.12.3	Regulatory Basis	3-117
	3.12.4	Technical Evaluation	3-117
	3.12.5	Post-Combined License Activities	3-120
	3.12.6	Conclusion	3-121
4.0		REACTOR	4-1
	4.1	Introduction	4-1
	4.2	Summary of Application	4-1
	4.3	Regulatory Basis	4-1
	4.4	Technical Evaluation	4-2

4.5	Post Combined License Activities	4-5
4.6	Conclusion	4-5
5.0	REACTOR COOLANT SYSTEM AND CONNECTED SYSTEMS	5-1
5.1	Introduction.....	5-1
5.2	Integrity of Reactor Coolant Pressure Boundary	5-1
	5.2.1.1 Compliance with 10 CFR 50.55a	5-1
	5.2.1.2 Applicable Code Cases (Related to RG 1.206, Section C.III.1, Chapter 5, C.I.5.2.1.2, "Compliance with Applicable ASME Code Cases")	5-8
	5.2.1.3 Alternate Classification	5-12
5.2.2	Overpressure Protection.....	5-13
5.2.3	Reactor Coolant Pressure Boundary Materials	5-13
	5.2.3.1 Introduction	5-13
	5.2.3.2 Summary of Application	5-13
	5.2.3.3 Regulatory Basis.....	5-13
	5.2.3.4 Technical Evaluation.....	5-14
	5.2.3.5 Post Combined License Activities.....	5-17
	5.2.3.6 Conclusion	5-17
5.2.4	Inservice Inspection and Testing of Class 1 Components (Related to RG 1.206, Section C.III.1, Chapter 5, C.I.5.2.4, "Inservice Inspection and Testing of Reactor Coolant Pressure Boundary")	5-18
	5.2.4.1 Introduction	5-18
	5.2.4.2 Summary of Application	5-18
	5.2.4.3 Regulatory Basis.....	5-19
	5.2.4.4 Technical Evaluation.....	5-19
	5.2.4.5 Post Combined License Activities.....	5-32
	5.2.4.6 Conclusion	5-33
5.2.5	Detection of Leakage through Reactor Coolant Pressure Boundary (Related to RG 1.206, Section C.III.1, Chapter 5, C.I.5.2.5, "Reactor Coolant Pressure Boundary Leakage Detection")	5-34
	5.2.5.1 Introduction	5-34
	5.2.5.2 Summary of Application	5-34
	5.2.5.3 Regulatory Basis.....	5-34
	5.2.5.4 Technical Evaluation.....	5-34
	5.2.5.5 Post Combined License Activities.....	5-38
	5.2.5.6 Conclusion	5-38
5.3	Reactor Vessel	5-38
5.3.1	Reactor Vessel Design	5-38
5.3.2	Reactor Vessel Materials.....	5-39
	5.3.2.1 Introduction	5-39
	5.3.2.2 Summary of Application	5-39
	5.3.2.3 Regulatory Basis.....	5-39
	5.3.2.4 Technical Evaluation.....	5-40
	5.3.2.5 Post Combined License Activities.....	5-45
	5.3.2.6 Conclusion	5-46

5.3.3	Pressure Temperature Limits (Related to RG 1.206, Section C.III.1, Chapter 5, C.I.5.3.2, “Pressure-Temperature Limits, Pressurized Thermal Shock, and Charpy Upper-Shelf Energy Data and Analyses”)	5-46
5.3.3.1	Introduction	5-46
5.3.3.2	Summary of Application	5-46
5.3.3.3	Regulatory Basis	5-47
5.3.3.4	Technical Evaluation	5-47
5.3.3.5	Post Combined License Activities	5-49
5.3.3.6	Conclusion	5-50
5.3.4	Reactor Vessel Integrity (Related to RG 1.206, Section C.III.1, Chapter 5, C.I.5.3.3 “Reactor Vessel Integrity”)	5-50
5.3.4.1	Introduction	5-50
5.3.4.2	Summary of Application	5-50
5.3.4.3	Regulatory Basis	5-51
5.3.4.4	Technical Evaluation	5-51
5.3.4.5	Post Combined License Activities	5-53
5.3.4.6	Conclusion	5-53
5.3.5	Reactor Vessel Insulation	5-54
5.4	Component and Subsystem Design (Related to RG 1.206, Section C.III.1, Chapter 5, C.I.5.4, “Reactor Coolant System Component and Subsystem Design”)	5-54
5.4.1	Introduction	5-54
5.4.2	Summary of Application	5-55
5.4.3	Regulatory Basis	5-56
5.4.4	Technical Evaluation	5-57
5.4.5	Post Combined License Activities	5-60
5.4.6	Conclusion	5-61
6.0	Engineered Safety Features	6-1
6.1	Engineered Safety Features Materials	6-1
6.1.1	Metallic Materials	6-1
6.1.1.1	Introduction	6-1
6.1.1.2	Summary of Application	6-1
6.1.1.3	Regulatory Basis	6-2
6.1.1.4	Technical Evaluation	6-2
6.1.1.5	Post Combined License Activities	6-4
6.1.1.6	Conclusion	6-4
6.1.2	Organic Materials	6-5
6.1.2.1	Introduction	6-5
6.1.2.2	Summary of Application	6-5
6.1.2.3	Regulatory Basis	6-5
6.1.2.4	Technical Evaluation	6-6
6.1.2.5	Post Combined License Activities	6-14
6.1.2.6	Conclusion	6-14
6.2	Containment Systems	6-14
6.2.1	Introduction	6-14

6.2.2	Summary of Application	6-14
6.2.3	Regulatory Basis.....	6-16
6.2.4	Technical Evaluation.....	6-17
6.2.5	Post-Combined License Activities	6-19
6.2.6	Conclusion	6-19
6.3	Passive Core Cooling System (Related to RG 1.206, Section C.III.1, Chapter 6, C.I.6.3, “Emergency Core Cooling System”)	6-20
6.3.1	Introduction	6-20
6.3.2	Summary of Application	6-21
6.3.3	Regulatory Basis.....	6-22
6.3.4	Technical Evaluation.....	6-22
6.3.5	Post-Combined License Activities	6-24
6.3.6	Conclusion	6-24
6.4	Habitability Systems	6-25
6.4.1	Introduction	6-25
6.4.2	Summary of Application	6-25
6.4.3	Regulatory Basis.....	6-27
6.4.4	Technical Evaluation.....	6-28
6.4.5	Post-Combined License Activities	6-36
6.4.6	Conclusion	6-36
6.5	Fission Product Removal and Control Systems	6-37
6.6	Inservice Inspection of Class 2, 3, and MC Components (Related to RG 1.206, Section C.III.1, Chapter 6, C.I.6.6, “Inservice Inspection of Class 2 and 3 Components”).....	6-38
6.6.1	Introduction	6-38
6.6.2	Summary of Application	6-38
6.6.3	Regulatory Basis.....	6-39
6.6.4	Technical Evaluation.....	6-39
6.6.5	Post-Combined License Activities	6-43
6.6.6	Conclusion	6-43
7.0	INSTRUMENTATION AND CONTROLS	7-1
7.1	Introduction.....	7-1
7.1.1	Introduction	7-1
7.1.2	Summary of Application	7-1
7.1.3	Regulatory Basis.....	7-2
7.1.4	Technical Evaluation.....	7-2
7.1.5	Post Combined License Activities.....	7-4
7.1.6	Conclusion	7-4
7.2	Reactor Trip.....	7-4
7.3	Engineered Safety Features.....	7-5
7.4	Systems Required for Safe Shutdown.....	7-6
7.5	Safety-Related Display Information (Related to RG 1.206, Section C.III.1, Chapter 7, C.1.7.5, “Information Systems Important to Safety”)	7-7
7.5.1	Introduction	7-7
7.5.2	Summary of Application	7-7
7.5.3	Regulatory Basis.....	7-8
7.5.4	Technical Evaluation.....	7-8

7.5.5	Post Combined License Activities.....	7-9
7.5.6	Conclusion	7-9
7.6	Interlock Systems Important to Safety.....	7-10
7.7	Control and Instrumentation Systems (Related to RG 1.206, Section C.III.1, Chapter 7, C.I.7.7, “Control Systems Not Required for Safety”).....	7-10
8.0	ELECTRIC POWER.....	8-2
8.1	Introduction.....	8-2
8.1.1	Introduction	8-2
8.1.2	Summary of Application.....	8-2
8.1.3	Regulatory Basis.....	8-3
8.1.4	Technical Evaluation.....	8-3
8.1.5	Post Combined License Activities.....	8-5
8.1.6	Conclusion	8-5
8.2	Offsite Power System.....	8-5
8.2.1	Introduction	8-5
8.2.2	Summary of Application.....	8-6
8.2.3	Regulatory Basis.....	8-8
8.2.4	Technical Evaluation.....	8-9
8.2.5	Post Combined License Activities.....	8-23
8.2.6	Conclusion	8-23
8.2.A	Site-Specific ITAAC for Offsite Power Systems.....	8-24
8.3	Onsite Power Systems.....	8-28
8.3.1	Alternating Current Power Systems.....	8-28
8.3.1.1	Introduction	8-28
8.3.1.2	Summary of Application	8-28
8.3.1.3	Regulatory Basis.....	8-29
8.3.1.4	Technical Evaluation	8-29
8.3.1.5	Post Combined License Activities	8-34
8.3.1.6	Conclusion	8-34
8.3.2	Direct Current Power Systems	8-35
8.3.2.1	Introduction	8-35
8.3.2.2	Summary of Application	8-35
8.3.2.3	Regulatory Basis.....	8-36
8.3.2.4	Technical Evaluation	8-37
8.3.2.5	Post Combined License Activities	8-41
8.3.2.6	Conclusion	8-41
9.0	Auxiliary Systems.....	9-1
9.1	Fuel Storage and Handling	9-1
9.1.1	New Fuel Storage (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.1.1, “Criticality Safety of Fresh and Spent Fuel Storage and Handling,” and C.I.9.1.2, “New and Spent Fuel Storage”).....	9-1
9.1.2	Spent Fuel Storage (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.1.1, “Criticality Safety of Fresh and Spent Fuel	

Storage and Handling,” and C.I.9.1.2, “New and Spent Fuel Storage”).....	9-1
9.1.2.1 Introduction	9-1
9.1.2.2 Summary of Application	9-2
9.1.2.3 Regulatory Basis.....	9-2
9.1.2.4 Technical Evaluation.....	9-3
9.1.2.5 Post-Combined License Activities.....	9-7
9.1.2.6 Conclusion	9-8
9.1.3 Spent Fuel Pool Cooling System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.1.3, “Spent Fuel Pool Cooling and Cleanup System”).....	9-8
9.1.3.1 Introduction	9-8
9.1.3.2 Summary of Application	9-8
9.1.3.3 Regulatory Basis.....	9-10
9.1.3.4 Technical Evaluation.....	9-10
9.1.3.5 Post-Combined License Activities.....	9-12
9.1.3.6 Conclusion	9-12
9.1.4 Light Load Handling System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.1.4, “Light Load Handling System (Related to Refueling”).....	9-12
9.1.4.1 Introduction	9-12
9.1.4.2 Summary of Application	9-13
9.1.4.3 Regulatory Basis.....	9-13
9.1.4.4 Technical Evaluation.....	9-13
9.1.4.5 Post-Combined License Activities.....	9-17
9.1.4.6 Conclusion	9-17
9.1.5 Overhead Heavy Load Handling Systems (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.1.5, “Overhead Load Handling System”).....	9-17
9.1.5.1 Introduction	9-17
9.1.5.2 Summary of Application	9-18
9.1.5.3 Regulatory Basis.....	9-18
9.1.5.4 Technical Evaluation.....	9-19
9.1.5.5 Post-Combined License Activities.....	9-23
9.1.5.6 Conclusion	9-23
9.2 Water Systems.....	9-24
9.2.1 Service Water System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.2.1, “Station Service Water System (Open, Raw Water Cooling Systems”).....	9-24
9.2.1.1 Introduction	9-24
9.2.1.2 Summary of Application	9-24
9.2.1.3 Regulatory Basis.....	9-25
9.2.1.4 Technical Evaluation.....	9-26
9.2.1.5 Post-Combined License Activities.....	9-32

9.2.1.6	Conclusion	9-33
9.2.2	Component Cooling Water System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.2.2, "Cooling System for Reactor Auxiliaries (Closed Cooling Water Systems)").....	9-33
9.2.2.1	Introduction	9-33
9.2.2.2	Summary of Application	9-34
9.2.2.3	Regulatory Basis.....	9-35
9.2.2.4	Technical Evaluation.....	9-35
9.2.2.5	Post-Combined License Activities.....	9-35
9.2.2.6	Conclusion	9-39
9.2.3	Demineralized Water Treatment System.....	9-39
9.2.4	Demineralized Water Transfer and Storage System	9-40
9.2.5	Potable Water System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.2.4, "Potable and Sanitary Water Systems").....	9-40
9.2.5.1	Introduction	9-40
9.2.5.2	Summary of Application	9-40
9.2.5.3	Regulatory Basis.....	9-41
9.2.5.4	Technical Evaluation.....	9-41
9.2.5.5	Post-Combined License Activities.....	9-42
9.2.5.6	Conclusion	9-42
9.2.6	Sanitary Drains (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.2.4, "Potable and Sanitary Water Systems").....	9-43
9.2.6.1	Introduction	9-43
9.2.6.2	Summary of Application	9-43
9.2.6.3	Regulatory Basis.....	9-44
9.2.6.4	Technical Evaluation.....	9-44
9.2.6.5	Post-Combined License Activities.....	9-44
9.2.6.6	Conclusion	9-44
9.2.7	Central Chilled Water System (Related to RG 1.206 Section C.III.1, Chapter 9, C.I.9.2.2, "Cooling System for Reactor Auxiliaries (Closed Cooling Water Systems)").....	9-45
9.2.7.1	Introduction	9-45
9.2.7.2	Summary of Application	9-46
9.2.7.3	Regulatory Basis.....	9-47
9.2.7.4	Technical Evaluation.....	9-47
9.2.7.5	Post-Combined License Activities.....	9-52
9.2.7.6	Conclusion	9-52
9.2.8	Turbine Building Closed Cooling Water System.....	9-52
9.2.8.1	Introduction	9-52
9.2.8.2	Summary of Application	9-53
9.2.8.3	Regulatory Basis.....	9-53
9.2.8.4	Technical Evaluation.....	9-53
9.2.8.5	Post-Combined License Activities.....	9-54
9.2.8.6	Conclusion	9-54

9.2.9	Waste Water System (Related to RG 1.206 Section C.III.1, Chapter 9, C.I.9.3.3, "Equipment and Floor Drainage System).....	9-54
9.2.9.1	Introduction	9-54
9.2.9.2	Summary of Application	9-54
9.2.9.3	Regulatory Basis.....	9-55
9.2.9.4	Technical Evaluation.....	9-55
9.2.9.5	Post-Combined License Activities.....	9-58
9.2.9.6	Conclusion	9-58
9.2.10	Hot Water Heating System	9-58
9.2.11	Raw Water System.....	9-59
9.2.11.1	Introduction	9-59
9.2.11.2	Summary of Application	9-59
9.2.11.3	Regulatory Basis.....	9-60
9.2.11.4	Technical Evaluation.....	9-61
9.2.11.5	Post-Combined License Activities.....	9-73
9.2.11.6	Conclusion	9-74
9.2.12	Deep Well Injection System.....	9-74
9.2.12.1	Introduction	9-74
9.2.12.2	Summary of Application	9-74
9.2.12.3	Regulatory Basis.....	9-74
9.2.12.4	Technical Evaluation.....	9-75
9.2.12.5	Post-Combined License Activities.....	9-76
9.2.12.6	Conclusion	9-76
9.3	Process Auxiliaries.....	9-76
9.3.1	Compressed and Instrument Air System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.3.1, "Compressed Air Systems")	9-76
9.3.1.1	Introduction	9-76
9.3.1.2	Summary of Application	9-77
9.3.1.3	Regulatory Basis.....	9-77
9.3.1.4	Technical Evaluation.....	9-77
9.3.1.5	Post-Combined License Activities.....	9-79
9.3.1.6	Conclusion	9-79
9.3.2	Plant Gas System (Related to RG 1.206 Section C.III.1, Chapter 9, C.I.9.3.1, "Compressed Air Systems)	9-79
9.3.3	Primary Sampling System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.3.2, "Process and Postaccident Sampling Systems")	9-80
9.3.4	Secondary Sampling System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.3.2, "Process and Post Accident Sampling Systems")	9-80
9.3.5	Equipment and Floor Drainage Systems (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.3.3, "Equipment and Floor Drainage System")	9-80

9.3.6	Chemical and Volume Control System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.3.4, "Chemical and Volume Control System (PWR) including Boron Recovery System")	9-81
9.4	Air-Conditioning, Heating, Cooling, and Ventilation Systems.....	9-81
9.4.1	Nuclear Island Nonradioactive Ventilation System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.4.1, "Control Room Area Ventilation System")	9-81
9.4.1.1	Introduction	9-82
9.4.1.2	Summary of Application	9-82
9.4.1.3	Regulatory Basis.....	9-83
9.4.1.4	Technical Evaluation.....	9-83
9.4.1.5	Post-Combined License Activities.....	9-85
9.4.1.6	Conclusion	9-85
9.4.2	Annex/Auxiliary Buildings Nonradioactive HVAC System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.4.3, "Auxiliary and Radwaste Area Ventilation System")	9-86
9.4.3	Radiologically Controlled Area Ventilation System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.4.2, "Spent Fuel Pool Area Ventilation System," and C.I.9.4.3, "Auxiliary and Radwaste Area Ventilation System")	9-87
9.4.4	Balance-of-Plant Interface	9-87
9.4.5	Engineered Safety Features Ventilation System	9-87
9.4.6	Containment Recirculation Cooling System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.4.5, "Engineered Safety Feature Ventilation System")	9-87
9.4.7	Containment Air Filtration System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.4.5, "Engineered Safety Feature Ventilation System".....	9-87
9.4.7.1	Introduction	9-87
9.4.7.2	Summary of Application	9-88
9.4.7.3	Regulatory Basis.....	9-88
9.4.7.4	Technical Evaluation.....	9-88
9.4.7.5	Post-Combined License Activities.....	9-90
9.4.7.6	Conclusion	9-90
9.4.8	Radwaste Building HVAC System.....	9-90
9.4.9	Turbine Building Ventilation System.....	9-91
9.4.10	Diesel Generator Building Heating and Ventilation System	9-91
9.4.11	Health Physics and Hot Machine Shop HVAC System	9-91
9.5	Other Auxiliary Systems.....	9-92
9.5.1	Fire Protection System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.5.1, "Fire Protection Program")	9-92
9.5.1.1	Introduction	9-92

9.5.1.2	Summary of Application	9-92
9.5.1.3	Regulatory Basis.....	9-94
9.5.1.4	Technical Evaluation.....	9-94
9.5.1.5	Post-Combined License Activities.....	9-103
9.5.1.6	Conclusion	9-103
9.5.2	Communication System.....	9-104
9.5.2.1	Introduction	9-104
9.5.2.2	Summary of Application	9-104
9.5.2.3	Regulatory Basis.....	9-105
9.5.2.4	Technical Evaluation.....	9-106
9.5.2.5	Post-Combined License Activities.....	9-111
9.5.2.6	Conclusion	9-111
9.5.3	Plant Lighting System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.5.3, "Lighting Systems")	9-112
9.5.4	Diesel Generator Fuel Oil System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.5.4, "Diesel Generator Fuel Oil Storage and Transfer System")	9-Error! Bookmark not defined.
9.5.4.1	Introduction	9-112
9.5.4.2	Summary of Application	9-113
9.5.4.3	Regulatory Basis.....	9-113
9.5.4.4	Technical Evaluation.....	9-113
9.5.4.5	Post-Combined License Activities.....	9-116
9.5.4.6	Conclusion	9-117
9.5.5	Standby Diesel Generator Cooling Water System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.5.5, "Diesel Generator Cooling Water System").....	9-117
9.5.6	Standby Diesel Generator Starting Air System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.5.6, "Diesel Generator Starting System").....	9-117
9.5.7	Standby Diesel Generator Lubrication System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.5.7, "Diesel Generator Lubrication System").....	9-117
9.5.8	Standby Diesel Generator Combustion Air Intake and Exhaust System (Related to RG 1.206, Section C.III.1, Chapter 9, C.I.9.5.8, "Diesel Generator Combustion Air Intake and Exhaust System")	9-11
10.0	STEAM AND POWER CONVERSION	10-1
10.1	Summary Description	10-1
10.1.1	Introduction.....	10-1
10.1.2	Summary of Application.....	10-1
10.1.3	Regulatory Basis	10-1
10.1.4	Technical Evaluation	10-2

10.1.5	Post Combined License Activities	10-6
10.1.6	Conclusion.....	10-6
10.2	Turbine-Generator.....	10-7
10.2.1	Introduction.....	10-7
10.2.2	Summary of Application.....	10-7
10.2.3	Regulatory Basis	10-8
10.2.4	Technical Evaluation	10-8
10.2.5	Post Combined License Activities	10-11
10.2.6	Conclusion.....	10-11
10.3	Main Steam Supply System	10-12
10.3.1	Introduction.....	10-12
10.3.2	Summary of Application.....	10-12
10.3.3	Regulatory Basis	10-13
10.3.4	Technical Evaluation	10-14
10.3.5	Post Combined License Activities	10-17
10.3.6	Conclusion.....	10-17
10.4	Other Features of Steam and Power Conversion System	10-18
10.4.1	Main Condensers	10-18
10.4.2	Main Condenser Evacuation System	10-18
10.4.2.1	Introduction	10-18
10.4.2.2	Summary of Application	10-18
10.4.2.3	Regulatory Basis.....	10-19
10.4.2.4	Technical Evaluation.....	10-19
10.4.2.5	Post Combined License Activities.....	10-20
10.4.2.6	Conclusion	10-20
10.4.3	Gland Sealing System (Related to RG 1.206, Section C.III.1, Chapter 10, C.I.10.4.3, "Turbine Gland Sealing System").....	10-20
10.4.4	Turbine Bypass System.....	10-20
10.4.5	Circulating Water System	10-21
10.4.5.1	Introduction	10-21
10.4.5.2	Summary of Application	10-21
10.4.5.3	Regulatory Basis.....	10-22
10.4.5.4	Technical Evaluation.....	10-22
10.4.5.5	Post Combined License Activities.....	10-27
10.4.5.6	Conclusion	10-27
10.4.6	Condensate Polishing System (Related to RG 1.206, Section C.III.1, Chapter 10, C.I.10.4.6, "Condensate Cleanup System").....	10-28
10.4.7	Condensate and Feedwater System	10-28
10.4.7.1	Introduction	10-28
10.4.7.2	Summary of Application	10-28

10.4.7.3	Regulatory Basis.....	10-29
10.4.7.4	Technical Evaluation.....	10-30
10.4.7.5	Post Combined License Activities.....	10-34
10.4.7.6	Conclusion	10-34
10.4.8	Steam Generator Blowdown System (Related to RG 1.206, Section C.III.1, Chapter 10, C.I.10.4.8, "Steam Generator Blowdown System (PWR)")	10-35
10.4.9	Startup Feedwater System	10-35
10.4.10Auxiliary Steam System.....	10-35
10.4.11Turbine Island Chemical Feed	10-35
10.4.12Combined License Information.....	10-36
11.0	RADIOACTIVE WASTE MANAGEMENT	11-1
11.1	Source Terms.....	11-1
11.2	Liquid Waste Management Systems.....	11-1
11.2.1	Introduction.....	11-1
11.2.2	Summary of Application.....	11-2
11.2.3	Regulatory Basis	11-3
11.2.4	Technical Evaluation	11-4
11.2.5	Post-Combined License Activities	11-36
11.2.6	Conclusion.....	11-36
11.3	Gaseous Waste Management System.....	11-37
11.3.1	Introduction.....	11-37
11.3.2	Summary of Application.....	11-37
11.3.3	Regulatory Basis	11-38
11.3.4	Technical Evaluation	11-39
11.3.5	Post-Combined License Activities	11-48
11.3.6	Conclusion.....	11-48
11.4	Solid Waste Management System	11-49
11.4.1	Introduction.....	11-49
11.4.2	Summary of Application.....	11-49
11.4.3	Regulatory Basis	11-50
11.4.4	Technical Evaluation	11-50
11.4.5	Post-Combined License Activities	11-57
11.4.6	Conclusion.....	11-57
11.5	Radiation Monitoring	11-58
11.5.1	Introduction.....	11-58
11.5.2	Summary of Application.....	11-58

TURKEY POINT

UNITS 6 AND 7

11.5.3 Regulatory Basis	11-59
11.5.4 Technical Evaluation	11-60
11.5.5 Post-Combined License Activities	11-69
11.5.6 Conclusion.....	11-70

12.0	RADIATION PROTECTION	12-Error! Bookmark not defined.
12.1	Assuring That Occupational Radiation Exposures are As-Low-As-Reasonably Achievable (Related to RG 1.206, Section C.III.1, Chapter 12, C.I.12.1, “Ensuring that Occupational Radiation Exposures are As Low As Is Reasonably Achievable”)	12-Error! Bookmark not defined.
12.1.1	Introduction.....	12-Error! Bookmark not defined.
12.1.2	Summary of Application.....	12-Error! Bookmark not defined.
12.1.3	Regulatory Basis	12-Error! Bookmark not defined.
12.1.4	Technical Evaluation	12-Error! Bookmark not defined.
12.1.5	Post Combined License Application	12-Error! Bookmark not defined.
12.1.6	Conclusion.....	12-Error! Bookmark not defined.
12.2	Radiation Sources	12-Error! Bookmark not defined.
12.2.1	Introduction.....	12-Error! Bookmark not defined.
12.2.2	Summary of Application.....	12-Error! Bookmark not defined.
12.2.3	Regulatory Basis	12-Error! Bookmark not defined.
12.2.4	Technical Evaluation	12-Error! Bookmark not defined.
12.2.5	Post Combined License Activities	12-Error! Bookmark not defined.
12.2.6	Conclusion.....	12-Error! Bookmark not defined.
12.3	Radiation Protection Design Features.....	12-Error! Bookmark not defined.
12.3.1	Introduction.....	12-Error! Bookmark not defined.
12.3.2	Summary of Application.....	12-Error! Bookmark not defined.
12.3.3	Regulatory Basis	12-Error! Bookmark not defined.
12.3.4	Technical Evaluation	12-Error! Bookmark not defined.
12.3.5	Post Combined license Activities.....	12-Error! Bookmark not defined.
12.3.6	Conclusion.....	12-Error! Bookmark not defined.
12.4	Dose Assessment	12-Error! Bookmark not defined.
12.4.1	Introduction.....	12-Error! Bookmark not defined.
12.4.2	Summary of Application.....	12-Error! Bookmark not defined.
12.4.3	Regulatory Basis	12-Error! Bookmark not defined.
12.4.4	Technical Evaluation	12-Error! Bookmark not defined.
12.4.5	Post Combined License Activities	12-Error! Bookmark not defined.
12.4.6	Conclusion.....	12-Error! Bookmark not defined.
12.5	Health Physics Facilities Design (Related to RG 1.206, Section C.III.1, Chapter 12, C.I.12.5, “Operational Radiation Protection Program”)	12-Error! Bookmark not defined.
12.5.1	Introduction.....	12-Error! Bookmark not defined.
12.5.2	Summary of Application.....	12-Error! Bookmark not defined.
12.5.3	Regulatory Basis	12-Error! Bookmark not defined.
12.5.4	Technical Evaluation	12-Error! Bookmark not defined.
12.5.5	Post Combined License Activities	12-Error! Bookmark not defined.
12.5.6	Conclusion.....	12-Error! Bookmark not defined.

13.0	CONDUCT OF OPERATIONS.....	13-1
13.1	Organizational Structure of Applicant.....	13-1
13.1.1	Introduction.....	13-1
13.1.2	Summary of Application.....	13-1
13.1.3	Regulatory Basis.....	13-2
13.1.4	Technical Evaluation.....	13-3
13.1.5	Post Combined License Activities.....	13-8
13.1.6	Conclusion.....	13-8
13.2	Training.....	13-9
13.2.1	Introduction.....	13-9
13.2.2	Summary of Application.....	13-10
13.2.3	Regulatory Basis.....	13-10
13.2.4	Technical Evaluation.....	13-11
13.2.5	Post Combined License Activities.....	13-15
13.2.6	Conclusion.....	13-15
13.3	Emergency Planning.....	13-16
13.3.1	Introduction.....	13-16
13.3.2	Summary of Application.....	13-17
13.3.3	Regulatory Basis.....	13-22
13.3.4	Technical Evaluation.....	13-23
13.3.4.1	Assignment of Responsibility (Organization Control).....	13-25
13.3.4.2	Onsite Emergency Organization.....	13-27
13.3.4.3	Emergency Response Support and Resources.....	13-35
13.3.4.4	Emergency Classification System.....	13-37
13.3.4.5	Notification Methods and Procedures.....	13-40
13.3.4.6	Emergency Communications.....	13-43
13.3.4.7	Public Education and Information.....	13-46
13.3.4.8	Emergency Facilities and Equipment.....	13-48
13.3.4.9	Accident Assessment.....	13-58
13.3.4.10	Protective Response.....	13-62
13.3.4.11	Radiological Exposure Control.....	13-66
13.3.4.12	Medical and Public Health Support.....	13-69
13.3.4.13	Recovery and Reentry Planning and Post-Accident Operations.....	13-71
13.3.4.14	Exercises and Drills.....	13-73
13.3.4.15	Radiological Emergency Response Training.....	13-75
13.3.4.16	Responsibility for the Planning Effort—Development, Periodic Review, and Distribution of Emergency Plans.....	13-77
13.4	Operational Programs (Related to RG 1.206, Section C.III.1, Chapter 13, C.I.13.4, “Operational Program Implementation”).....	13-109
13.4.1	Introduction.....	13-109
13.4.2	Summary of Application.....	13-109
13.4.3	Regulatory Basis.....	13-110
13.4.4	Technical Evaluation.....	13-110
13.4.5	Post Combined License Activities.....	13-114
13.4.6	Conclusion.....	13-114
13.5	Plant Procedures.....	13-115
13.5.1	Introduction.....	13-115
13.5.2	Summary of Application.....	13-115

13.5.3	Regulatory Basis.....	13-116
13.5.4	Technical Evaluation.....	13-116
13.5.5	Post Combined License Activities.....	13-119
13.5.6	Conclusion	13-119
13.6	Physical Security	13-120
13.6.1	Introduction	13-120
13.6.2	Summary of Application	13-120
13.6.3	Regulatory Basis.....	13-121
13.6.4	Technical Evaluation.....	13-123
13.6.4.1	Physical Security Plan.....	13-127
13.6.4.1.1	Introduction and Physical Facility Layout.....	13-127
13.6.4.1.2	Performance Objectives	13-129
13.6.4.1.3	Performance Evaluation Program	13-130
13.6.4.1.4	Establishment of Security Organization	13-131
13.6.4.1.5	Qualification for Employment in Security.....	13-131
13.6.4.1.6	Training of Facility Personnel	13-132
13.6.4.1.7	Security Personnel Training	13-132
13.6.4.1.8	Local Law Enforcement Liaison.....	13-133
13.6.4.1.9	Security Personnel Equipment	13-133
13.6.4.1.10	Work Hour Controls	13-134
13.6.4.1.11	Physical Barriers.....	13-134
13.6.4.1.12	Security Posts and Structures	13-137
13.6.4.1.13	Access Control Devices.....	13-137
13.6.4.1.14	Access Requirements.....	13-138
13.6.4.1.15	Surveillance Observation and Monitoring.....	13-142
13.6.4.1.16	Communications.....	13-144
13.6.4.1.17	Review, Evaluation and Audit of the Physical Security Program	13-145
13.6.4.1.18	Response Requirements	13-147
13.6.4.1.19	Special Situations Affecting Security	13-148
13.6.4.1.20	Maintenance, Testing and Calibration ..	13-148
13.6.4.1.21	Compensatory Measures	13-149
13.6.4.1.22	Records	13-150
13.6.4.1.23	Digital Systems Security.....	13-151
13.6.4.1.24	Temporary Suspension of Security Measures.....	13-151
13.6.4.1.25	Appendix A Glossary of Terms and Acronyms.....	13-152
13.6.4.1.26	Conclusions on the Physical Security Plan	13-152
13.6.4.2	Appendix B Training and Qualification Plan.....	13-153
13.6.4.2.1	Introduction.....	13-153
13.6.4.2.2	Employment Suitability and Qualification.....	13-153
13.6.4.2.3	Individual Training and Qualification.....	13-153
13.6.4.2.4	Performance Evaluation Program	13-164
13.6.4.2.5	Definitions.....	13-165

	13.6.4.2.6	Conclusion on the Training and Qualification Plan.....	13-165
13.6.4.3		Appendix C Safeguards Contingency Plan	13-165
	13.6.4.3.1	Background Information	13-165
	13.6.4.3.2	Generic Planning Base.....	13-164
	13.6.4.3.3	Responsibility Matrix.....	13-167
	13.6.4.3.4	Licensee Planning Base	13-168
	13.6.4.3.5	Response Capabilities	13-170
	13.6.4.3.6	Defense-In-Depth	13-172
	13.6.4.3.7	Primary Security Functions.....	13-172
	13.6.4.3.8	Protective Strategy	13-173
	13.6.4.3.9	Conclusions on the Safeguards Contingency Plan	13-173
13.6.5		Post Combined License Activities.....	13-173
13.6.6		Conclusion	13-174
13.6.A		Site-Specific ITAAC for Physical Security.....	13-175
	13.6.A.1	Introduction	13-175
	13.6.A.2	Summary of Application	13-175
	13.6.A.3	Regulatory Basis	13-175
	13.6.A.4	Technical Evaluation	13-177
		13.6.A.4.1 Detection and Assessment Hardware ..	13-178
		13.6.A.4.2 Delay or Barrier Design	13-180
		13.6.A.4.3 Systems, Hardware, or Features Facilitating Security Response and Neutralization.....	13-181
	13.6.A.5	Post-Combined License Activities.....	13-181
	13.6.A.6	Conclusion	13-182
13.7		Fitness for Duty	13-187
	13.7.1	Introduction	13-187
	13.7.2	Summary of Application.....	13-187
	13.7.3	Regulatory Basis.....	13-188
	13.7.4	Technical Evaluation.....	13-188
	13.7.5	Post Combined License Activities.....	13-195
	13.7.6	Conclusion	13-195
13.8		Cyber Security	13-195
	13.8.1	Introduction	13-195
	13.8.2	Summary of Application.....	13-196
	13.8.3	Regulatory Basis.....	13-196
	13.8.4	Technical Evaluation.....	13-197
		13.8.4.1 Establishment of Cyber Security Program	13-199
		13.8.4.2 Security Assessment and Authorization (Section A.3.1.1 of Appendix A to RG 5.71).....	13-200
		13.8.4.3 Cyber Security Team (Section A.3.1.2 of Appendix A to RG 5.71).....	13-201
		13.8.4.4 Identification of Critical Digital Assets (Section A.3.1.3 of Appendix A to RG 5.71).....	13-202
		13.8.4.5 Reviews and Validation Testing (Section A.3.1.4 of Appendix A to RG 5.71)	13-202

13.8.4.6	Defense-In-Depth Protective Strategies (Section A.3.1.5 of Appendix A to RG 5.71).....	13-203
13.8.4.7	Application of Security Controls (Section A.3.1.6 of Appendix A to RG 5.71)	13-203
13.8.4.8	Incorporating the Cyber Security Program into the Physical Protection Program (Section A.3.2 of Appendix A to RG 5.71)	13-204
13.8.4.9	Policies and Implementing Procedures (Section A.3.3 of Appendix A to RG 5.71)	13-204
13.8.4.10	Maintaining the Cyber Security Program (Section A.4 of Appendix A to RG 5.71)	13-205
13.8.4.11	Continuous Monitoring and Assessment (Section A.4.1 of Appendix A to RG 5.71).....	13-205
13.8.4.12	Periodic Assessment of Security Controls (Section A.4.1.1 of Appendix A to RG 5.71).....	13-206
13.8.4.13	Effectiveness Analysis (Section A.4.1.2 of Appendix A to RG 5.71)	13-206
13.8.4.14	Vulnerability Assessments and Scans (Section A.4.1.3 of Appendix A to RG 5.71).....	13-207
13.8.4.15	Change Control (Section A.4.2 of Appendix A to RG 5.71)	13-208
13.8.4.16	Configuration Management (Section A.4.2.1 of Appendix A to RG 5.71)	13-208
13.8.4.17	Security Impact Analysis of Changes and Environment (Section A.4.2.2 of Appendix A to RG 5.71).....	13-208
13.8.4.18	Security Reassessment and Authorization (Section A.4.2.3 of Appendix A to RG 5.71).....	13-209
13.8.4.19	Updating Cyber Security Practices (Section A.4.2.4 of Appendix A to RG 5.71)	13-210
13.8.4.20	Review and Validation Testing of a Modification or Addition of a Critical Digital Asset (Section A.4.2.5 of Appendix A to RG 5.71)	13-211
13.8.4.21	Application of Security Controls Associated with a Modification or Addition (Section A.4.2.6 of Appendix A to RG 5.71)	13-211
13.8.4.22	Cyber Security Program Review (Section A.4.3 of Appendix A to RG 5.71)	13-212
13.8.4.23	Document Control and Records Retention and Handling (Section A.5 of Appendix A to RG 5.71)	13-213
13.8.4.24	Deviations Taken to RG 5.71, Sections C.1 Through C.5.....	13-214
13.8.4.24.1	RG 5.71, Section C.2, fourth paragraph, first sentence (page 8).....	13-214
13.8.4.24.2	RG 5.71, Section C.2, fourth paragraph, twelfth bullet, third sub-bullet (page 8)..	13-214
13.8.4.24.3	RG 5.71, Section C.2, fifteenth bullet (page 8)	13-214
13.8.4.24.4	RG 5.71, Section C.3, Figure 1 (Page 10).....	13-215
13.8.4.24.5	RG 5.71, Section C.3, third paragraph, first sentence (Page 10)	13-215

13.8.4.24.6	RG 5.71, Section C.3.1, first paragraph, first sentence (page 11).....	13-215
13.8.4.24.7	RG 5.71, Section C.3.1, first paragraph, second bullet (page 11).....	13-216
13.8.4.24.8	RG 5.71, Section C.3.1.2, third paragraph, second bullet (page 13).....	13-216
13.8.4.24.9	RG 5.71, Section C.3.1.2, third paragraph, sixth bullet (page 13).....	13-217
13.8.4.24.10	RG 5.71, Section C.3.1.2, third paragraph, seventh bullet (page 13).....	13-217
13.8.4.24.11	RG 5.71, Section C.3.1.2, fourth paragraph, first sentence (page 13)	13-218
13.8.4.24.12	RG 5.71, Section C.3.1.3, second paragraph (page 14).....	13-218
13.8.4.24.13	RG 5.71, Section C.3.1.3, fifth paragraph, first sentence (page 15)	13-219
13.8.4.24.14	RG 5.71, Section C.3.1.3, fifth paragraph, second sentence (page 15)	13-219
13.8.4.24.15	RG 5.71, Section C.3.1.3, fifth paragraph, fifth sentence (page 15)	13-219
13.8.4.24.16	RG 5.71, Section C.3.1.3, eighth paragraph, first bullet (page 16)	13-220
13.8.4.24.17	RG 5.71, Section C.3.1.3, eighth paragraph, second bullet (page 16).....	13-220
13.8.4.24.18	RG 5.71, Section C.3.2, first paragraph, first sentence (page 18).....	13-220
13.8.4.24.19	RG 5.71, Section C.3.2, second paragraph, fourth sentence (page 18) ..	13-221
13.8.4.24.20	RG 5.71, Section C.3.2, third paragraph, first sentence (page 18)	13-221
13.8.4.24.21	RG 5.71, Section C.3.2.1, Figure 5 (Page 19).....	13-222
13.8.4.24.22	RG 5.71, Section C.3.2.1, third paragraph (page 19).....	13-222
13.8.4.24.23	RG 5.71, Section C.3.2.1, third paragraph, first bullet (page 19)	13-222
13.8.4.24.24	RG 5.71, Section C.3.2.1, third paragraph, second bullet (page 19).....	13-223
13.8.4.24.25	RG 5.71, Section C.3.2.1, third paragraph, third bullet (page 19)	13-223
13.8.4.24.26	RG 5.71, Section C.3.2.1, third paragraph, new second bullet (page 19)	13-223
13.8.4.24.27	RG 5.71, Section C.3.2.1, third paragraph, new sixth bullet (page 19) ..	13-223
13.8.4.24.28	RG 5.71, Section C.3.2.1, third paragraph, seventh bullet (page 19).....	13-224
13.8.4.24.29	RG 5.71, Section C.3.2.1, third paragraph, eighth bullet (page 19)	13-224
13.8.4.24.30	RG 5.71, Section C.3.2.1, fourth	

	paragraph (page 19).....	13-224
13.8.4.24.31	RG 5.71, Section C.3.2.1, Prior to fifth paragraph (page 19).....	13-224
13.8.4.24.32	RG 5.71, Section C.3.3, first paragraph, second sentence (page 20)	13-225
13.8.4.24.33	RG 5.71, Section C.3.3, third paragraph, fourth sentence (page 20)	13-225
13.8.4.24.34	RG 5.71, Section C.3.3, third paragraph, first sentence (page 20).....	13-226
13.8.4.24.35	RG 5.71, Section C.3.3, third paragraph, first bullet (page 20).....	13-226
13.8.4.24.36	RG 5.71, Section C.3.3, third paragraph, second bullet (page 20)	13-226
13.8.4.24.37	RG 5.71, Section C.3.3, third paragraph, second bullet, second sub-bullet (page 20)	13-226
13.8.4.24.38	RG 5.71, Section C.3.3, third paragraph, second bullet, third sub-bullet (page 20)	13-227
13.8.4.24.39	RG 5.71, Section C.3.3, third paragraph, third bullet (page 20).....	13-227
13.8.4.24.40	RG 5.71, Section C.3.3, fourth paragraph, second sentence (page 20)	13-228
13.8.4.24.41	RG 5.71, Section C.3.3, fifth paragraph, second sentence (page 21)	13-228
13.8.4.24.42	RG 5.71, Sections C.3.3.1.1 through C.3.3.1.5, first paragraph and last bullet (pages 21 and 22)	13-229
13.8.4.24.43	RG 5.71, Section C.3.3.1.1, first paragraph, second bullet, fourth sub-bullet (page 21).....	13-229
13.8.4.24.44	RG 5.71, Sections C.3.3.2.1 through C.3.3.2.5, first paragraph and last bullet (pages 23 and 24)	13-230
13.8.4.24.45	RG 5.71, Sections C.3.3.2.6 through C.3.3.2.9, first paragraph and last bullet (pages 24-26)	13-230
13.8.4.24.46	RG 5.71, Section C.3.3.2.9, first paragraph, first bullet (page 25)	13-230
13.8.4.24.47	RG 5.71, Section C.3.3.3.1, first paragraph and last bullet (page 26).....	13-231
13.8.4.24.48	RG 5.71, Section C.3.3.3.1, second paragraph (page 26).....	13-231
13.8.4.24.49	RG 5.71, Section C.3.3.3.2, first paragraph, second sentence (page 26)	13-231
13.8.4.24.50	RG 5.71, Section C.3.4, second paragraph, first sentence (page 26)	13-231
13.8.4.24.51	RG 5.71, Section C.3.4, second paragraph, first bullet (page 27)	13-232
13.8.4.24.52	RG 5.71, Section C.4, first paragraph, first sentence (page 27).....	13-232

13.8.4.24.53	RG 5.71, Section C.4, first paragraph, first bullet (page 28).....	13-232
13.8.4.24.54	RG 5.71, Section C.4.1, section heading and first paragraph, first sentence (page 28).....	13-233
13.8.4.24.55	RG 5.71, Section C.4.1, second paragraph, first sentence (page 28)	13-233
13.8.4.24.56	RG 5.71, Section C.4.1, second paragraph, first bullet (page 28)	13-233
13.8.4.24.57	RG 5.71, Section C.4.1, third paragraph, first and second sentences (page 28).....	13-233
13.8.4.24.58	RG 5.71, Section C.4.1.1, first paragraph, second sentence (page 28)	13-234
13.8.4.24.59	RG 5.71, Section C.4.1.2, first paragraph, third sentence (page 29)	13-234
13.8.4.24.60	RG 5.71, Section C.4.1.3, first paragraph, second sentence (page 29)	13-235
13.8.4.24.61	RG 5.71, Section C.4.2, first paragraph, second sentence (page 30)	13-236
13.8.4.24.62	RG 5.71, Section C.4.2.1, first paragraph, third sentence (page 30)	13-236
13.8.4.24.63	RG 5.71, Section C.4.2.1, second paragraph, third sentence (page 30)	13-237
13.8.4.24.64	RG 5.71, Section C.4.3, second paragraph (page 31).....	13-237
13.8.4.24.65	RG 5.71, Section C.5, second paragraph, second and third sentences (page 32)	13-237
13.8.4.24.66	RG 5.71, Glossary (Page 35)	13-238
13.8.4.24.67	RG 5.71, Glossary (Page 35)	13-238
13.8.4.24.68	RG 5.71, Glossary (Page 35)	13-238
13.8.5	Post Combined License Activities.....	13-240
13.8.6	Conclusion	13-240

14.0	INITIAL TEST PROGRAMS	14-1
14.1	Specific Information to be Included in Preliminary/Final Safety Analysis Reports (Related to Regulatory Guide (RG) 1.206, Section C.III.1, Chapter 14, C.I.14.1, "Specific Information To Be Addressed for the Initial Plant Test Program").....	14-1
14.2	Specific Information to be Included in Standard Safety Analysis Reports (Related to RG 1.206, Section C.III.1, Chapter 14, C.I.14.2, "Initial Plant Test Program")	14-2
14.2.1	Summary of Test Program and Objectives.....	14-2
14.2.1.1	Introduction	14-2
14.2.1.2	Summary of Application	14-2
14.2.1.3	Regulatory Basis.....	14-2
14.2.1.4	Technical Evaluation.....	14-3
14.2.1.5	Post Combined License Activities.....	14-5
14.2.1.6	Conclusion	14-5
14.2.2	Organization, Staffing, and Responsibilities (Related to RG 1.206, Section C.III.1, Chapter 14, C.I.14.2.2, "Organization and Staffing")	14-5
14.2.2.1	Introduction	14-5
14.2.2.2	Summary of Application	14-5
14.2.2.3	Regulatory Basis.....	14-5
14.2.2.4	Technical Evaluation.....	14-6
14.2.2.5	Post Combined License Activities.....	14-12
14.2.2.6	Conclusion	14-12
14.2.3	Test Specifications and Test Procedures (Related to RG 1.206, Section C.III.1, Chapter 14, C.I.14.2.3, "Test Procedures," C.I.14.2.4, "Conduct of Test Program," C.I.14.2.5, "Review, Evaluation, and Approval of Test Results," and C.I.14.2.6, "Test Records").....	14-13
14.2.3.1	Introduction	14-13
14.2.3.2	Summary of Application	14-13
14.2.3.3	Regulatory Basis.....	14-15
14.2.3.4	Technical Evaluation.....	14-15
14.2.3.5	Post Combined License Activities.....	14-28
14.2.3.6	Conclusion	14-28
14.2.5	Utilization of Operating Experience (Related to RG 1.206, Section C.III.1, Chapter 14, C.I.14.2.8, "Utilization of Reactor Operating and Testing Experiences in Development of Test Program") ..	14-30
14.2.5.1	Introduction	14-30
14.2.5.2	Summary of Application	14-30
14.2.5.3	Regulatory Basis.....	14-31
14.2.5.4	Technical Evaluation.....	14-Error! Bookmark not defined.
14.2.5.5	Post Combined License Activities.....	14-35
14.2.5.6	Conclusion	14-35

14.2.6	Use of Plant Operating and Emergency Procedures (Related to RG 1.206, Section C.III.1, Chapter 14, C.I.14.2.9, "Trial Use of Plant Operating and Emergency Procedures").....	14-36
14.2.6.1	Introduction	14-36
14.2.6.2	Summary of Application	14-36
14.2.6.3	Regulatory Basis	14-36
14.2.6.4	Technical Evaluation	14-37
14.2.6.5	Post Combined License Activities	14-38
14.2.6.6	Conclusion	14-39
14.2.8	Test Program Schedule (Related to RG 1.206, Section C.III.1, Chapter 14, C.I.14.2.11, "Test Program Schedule").....	14-39
14.2.8.1	Introduction	14-39
14.2.8.2	Summary of Application	14-39
14.2.8.3	Regulatory Basis	14-40
14.2.8.4	Technical Evaluation	14-40
14.2.8.5	Post Combined License Activities	14-45
14.2.8.6	Conclusion	14-47
14.2.9	Preoperational Test Descriptions (Related to RG 1.206, Section C.III.1, Chapter 14, C.I.14.2.12, "Individual Test Descriptions") ..	14-47
14.2.9.1	Introduction	14-47
14.2.9.2	Summary of Application	14-48
14.2.9.3	Regulatory Basis	14-48
14.2.9.4	Technical Evaluation	14-49
14.2.9.5	Post Combined License Activities	14-57
14.2.9.6	Conclusion	14-57
14.2.10	Startup Test Procedures (Related to RG 1.206, Section C.III.1, Chapter 14, C.I.14.2.12, "Individual Test Descriptions")	14-58
14.2.10.1	Introduction	14-58
14.2.10.2	Summary of Application	14-58
14.2.10.3	Regulatory Basis	14-58
14.2.10.4	Technical Evaluation	14-59
14.2.10.5	Post Combined License Activities	14-60
14.2.10.6	Conclusion	14-60
14.3	Certified Design Material (Related to RG 1.206, Section C.III.1, Chapter 14, C.I.14.3, "Inspections, Tests, Analyses, and Acceptance Criteria").....	14-61
14.3.1	Introduction	14-61
14.3.2	Summary of Application	14-61
14.3.3	Regulatory Basis	14-63
14.3.4	Technical Evaluation	14-63
14.3.5	Post Combined License Activities	14-67
14.3.6	Conclusion	14-67

15.0	ACCIDENT ANALYSIS	15-1
15.0	Accident Analysis (Related to Regulatory Guide (RG) 1.206, Section C.III.1, Chapter 15, C.I.15.1, "Transient and Accident Classification," C.I.15.2, "Frequency of Occurrence," C.I.15.3, "Plant Characteristics Considered in the Safety Evaluation," C.I.15.4, "Assumed Protection System Actions," and C.I.15.5, "Evaluation of Individual Initiating Events")	15-1
15.0.1	Introduction	15-1
15.0.2	Summary of Application	15-1
15.0.3	Regulatory Basis.....	15-3
15.0.4	Technical Evaluation.....	15-3
15.0.5	Post Combined License Activities.....	15-10
15.0.6	Conclusion	15-11
15.1	Increase in Heat Removal from the Primary System (Related to RG 1.206, Section C.III.1, Chapter 15, C.I.15.6, "Event Evaluation")	15-11
15.2	Decrease in Heat Removal By the Secondary System	15-12
15.3	Decrease in Reactor Coolant System Flow Rate	15-13
15.4	Reactivity and Power Distribution Anomalies	15-14
15.4.1	Introduction	15-14
15.4.2	Summary of Application	15-14
15.4.3	Regulatory Basis.....	15-15
15.4.4	Technical Evaluation.....	15-15
15.4.5	Post Combined License Activities.....	15-16
15.4.6	Conclusion	15-16
15.5	Increase in Reactor Coolant Inventory	15-17
15.6	Decrease in Reactor Coolant Inventory.....	15-17
15.7	Radioactive Release From a Subsystem or Component.....	15-18
15.7.1	Introduction	15-18
15.7.2	Summary of Application	15-18
15.7.3	Regulatory Basis.....	15-19
15.7.4	Technical Evaluation.....	15-20
15.7.5	Post Combined License Activities.....	15-20
15.7.6	Conclusion	15-20
15.8	Anticipated Transients Without Scram	15-21
Appendix 15A	Evaluation Models and Parameters for Analysis of Radiological Consequences of Accidents	15-21
15A.1	Introduction	15-21
15A.2	Summary of Application	15-21
15A.3	Regulatory Basis.....	15-22
15A.4	Technical Evaluation.....	15-23
15A.5	Post Combined License Activities.....	15-26
15A.6	Conclusion	15-26
Appendix 15B	Removal of Airborne Activity from the Containment Atmosphere Following a LOCA.....	15-26

TURKEY POINT

UNITS 6 AND 7

16.0	TECHNICAL SPECIFICATIONS	16-1
16.1	Technical Specifications	16-1
16.1.1	Introduction	16-1
16.1.2	Summary of Application	16-1
16.1.3	Regulatory Basis	16-3
16.1.4	Technical Evaluation	16-3
16.1.4.1	Use and Application	16-5
16.1.4.2	Safety Limits	16-5
16.1.4.3	Limiting Condition for Operation and Surveillance Requirement Applicability	16-5
16.1.4.3.1	Reactivity Control Systems	16-5
16.1.4.3.2	Power Distribution Limits	16-6
16.1.4.3.3	Instrumentation	16-6
16.1.4.3.4	Reactor Coolant System	16-7
16.1.4.3.5	Emergency Core Cooling Systems	16-7
16.1.4.3.6	Containment Systems	16-8
16.1.4.3.7	Plant Systems	16-8
16.1.4.3.8	Electrical Power Systems	16-8
16.1.4.3.9	Refueling Operations	16-8
16.1.4.4	Design Features	16-9
16.1.4.5	Administrative Controls	16-9
16.1.5	Post Combined License Activities	16-11
16.1.6	Conclusion	16-11
16.2	Design Reliability Assurance Program (Related to RG 1.206, Section C.III.1, Chapter 17, C.I.17.4, "Reliability Assurance Program Guidance")	16-11
16.3	Investment Protection	16-12
16.3.1	Introduction	16-12
16.3.2	Summary of Application	16-12
16.3.3	Regulatory Basis	16-12
16.3.4	Technical Evaluation	16-12
16.3.5	Post Combined License Activities	16-14
16.3.6	Conclusion	16-14
17.0	QUALITY ASSURANCE (RELATED TO RG 1.206, SECTION C.III.1, CHAPTER 17, C.I.17, "QUALITY ASSURANCE AND RELIABILITY ASSURANCE")	17-1
17.1	Quality Assurance During the Design and Construction Phases	17-1
17.1.1	Introduction	17-1
17.1.2	Summary of Application	17-1
17.1.3	Regulatory Basis	17-1
17.1.4	Technical Evaluation	17-2
17.1.5	Post Combined License Activities	17-4
17.1.6	Conclusion	17-4
17.2	Quality Assurance During the Operations Phase	17-5
17.3	Quality Assurance During Design, Procurement, Fabrication, Inspection, and/or Testing of Nuclear Power Plant Items (Related to RG 1.206, Section C.III.1, Chapter 17, C.I.17.3, "Quality Assurance Program Description")	17-5

TURKEY POINT

UNITS 6 AND 7

17.4	Design Reliability Assurance Program (Related to RG 1.206, Section C.III.1, Chapter 17, C.I.17.4, “Reliability Assurance Program Guidance”).....	17-5
17.4.1	Introduction.....	17-5
17.4.2	Summary of Application.....	17-5
17.4.3	Regulatory Basis.....	17-6
17.4.4	Technical Evaluation.....	17-6
17.4.5	Post Combined License Activities.....	17-8
17.4.6	Conclusion.....	17-8
17.5	Quality Assurance Program Description – New License Applicants (Related to RG 1.206, Section C.III.1, Chapter 17, C.I.17.5, “Quality Assurance Program Guidance”).....	17-8
17.5.1	Introduction.....	17-8
17.5.2	Summary of Application.....	17-9
17.5.3	Regulatory Basis.....	17-9
17.5.4	Technical Evaluation.....	17-10
17.5.4.1	Organization.....	17-12
17.5.4.2	Quality Assurance Program.....	17-12
17.5.4.3	Design Control.....	17-16
17.5.4.4	Procurement Document Control.....	17-17
17.5.4.5	Instructions, Procedures, and Drawings.....	17-19
17.5.4.6	Document Control.....	17-19
17.5.4.7	Control of Purchased Material, Equipment, and Services.....	17- Error! Bookmark not defined.
17.5.4.8	Identification and Control of Materials, Parts, and Components.....	Error! Bookmark not defined.
17.5.4.9	Control of Special Processes.....	17-23
17.5.4.10	Inspection.....	17-24
17.5.4.11	Test Control.....	17-25
17.5.4.12	Control of Measuring and Test Equipment.....	17-26
17.5.4.13	Handling, Storage, and Shipping.....	17-26
17.5.4.14	Inspection, Test, and Operating Status.....	17-27
17.5.4.15	Nonconforming Materials, Parts, or Components.....	17-28
17.5.4.16	Corrective Action.....	17-28
17.5.4.17	Quality Assurance Records.....	17-29
17.5.4.18	Quality Assurance Audits.....	17-29
17.5.4.19	Nonsafety-Related SSCs Quality Assurance Control.....	17-30
17.5.4.19.1	Nonsafety-Related SSCs - Significant Contributors to Plant Safety.....	17-30
17.5.4.19.2	Nonsafety-Related SSCs Credited for Regulatory Events.....	17-31
17.5.4.20	Regulatory Commitments.....	17-31
17.5.5	Post Combined License Activities.....	17-33
17.5.6	Conclusion.....	17-33
17.6	Maintenance Rule Program (Related to RG 1.206, Section C.III.1, Chapter 17, C.I.17.6, “Description of the Applicant’s Program for Implementation of 10 CFR 50.65, The Maintenance Rule”).....	17-34
17.6.1	Introduction.....	17-34
17.6.2	Summary of Application.....	17-34

TURKEY POINT

UNITS 6 AND 7

17.6.3	Regulatory Basis.....	17-34
17.6.4	Technical Evaluation.....	17-35
17.6.5	Post Combined License Activities.....	17-37
17.6.6	Conclusion	17-37
18.0	HUMAN FACTORS ENGINEERING.....	18-1
18.1	Overview (No Corresponding Section in Regulatory Guide (RG) 1.206)	18-1
18.2	Human Factors Engineering Program Management (Related to RG 1.206, Section C.I.18.1, "HFE Program Management")	18-1
18.2.1	Introduction	18-1
18.2.2	Summary of Application	18-1
18.2.3	Regulatory Basis.....	18-1
18.2.4	Technical Evaluation.....	18-1
18.2.5	Post Combined License Activities.....	18-6
18.2.6	Conclusion	18-6
18.3	Operating Experience Review (Related to RG 1.206, Section C.I.18.2, "Operating Experience Review")	18-7
18.4	Functional Requirements Analysis and Allocation (Related to RG 1.206, Section C.I.18.3, "Functional Requirements Analysis and Function Allocation").....	18-7
18.5	AP1000 Task Analysis Implementation Plan (Related to RG 1.206, Section C.I.18.4, "Task Analysis")	18-7
18.6	Staffing (Related to RG 1.206, Section C.I.18.5, "Staffing and Qualifications").....	18-8
18.6.1	Introduction	18-8
18.6.2	Summary of Application	18-8
18.6.3	Regulatory Basis.....	18-8
18.6.4	Technical Evaluation.....	18-9
18.6.5	Post Combined License Activities.....	18-13
18.6.6	Conclusion	18-13
18.7	Integration of Human Reliability Analysis with Human Factors Engineering (Related to RG 1.206, Section C.I.18.6, "Human Reliability Analysis")	18-14
18.8	Human-System Interface Design (Related to RG 1.206, Section C.I.18.7, "Human System Interface Design")	18-14
18.8.1	Introduction	18-14
18.8.2	Summary of Application	18-14
18.8.3	Regulatory Basis.....	18-15
18.8.4	Technical Evaluation.....	18-15
18.8.5	Post Combined License Activities.....	18-15
18.8.6	Conclusion	18-16
18.9	Procedure Development (Related to RG 1.206, Section C.I.18.8, "Procedure Development")	18-16
18.10	Training Program Development (Related to RG 1.206, Section C.I.18.9, "Training Program Development")	18-16
18.10.1	Introduction	18-16
18.10.2	Summary of Application	18-17
18.10.3	Regulatory Basis.....	18-17

TURKEY POINT

UNITS 6 AND 7

18.10.4	Technical Evaluation.....	18-17
18.10.5	Post Combined License Activities.....	18-19
18.10.6	Conclusion.....	18-19
18.11	Human Factors Engineering Verification and Validation (Related to RG 1.206, Section C.I.18.10, "Verification and Validation")	18-20
18.12	Inventory (No Corresponding Section in RG 1.206).....	18-20
18.13	Design Implementation (Related to RG 1.206, Section C.I.18.11, "Design Implementation").....	18- Error! Bookmark not defined.
18.14	Human Performance Monitoring (Related to RG 1.206, Section C.I.18.12, "Human Performance Monitoring").....	18-21
18.14.1	Introduction	18-21
18.14.2	Summary of Application	18-21
18.14.3	Regulatory Basis.....	18-21
18.14.4	Technical Evaluation.....	18-22
18.14.5	Post Combined License Activities.....	18-24
18.14.6	Conclusion	18-24
19.0	PROBABILISTIC RISK ASSESSMENT (Related to RG 1.206, Section C.III.1, Chapter 19, C.I.19, "probabilistic risk assessment and severe accident evaluation") ..	19-1
19.1–19.40, 19.42–19.54, 19.56–19.57, and Appendices 19A, 19B, 19C, and 19D,	Probabilistic Risk Assessment	19-1
19.55	Seismic Margin Analysis.....	19-4
19.55.1	Introduction	19-4
19.55.2	Summary of Application	19-4
19.55.3	Regulatory Basis.....	19-4
19.55.4	Technical Evaluation.....	19-6
19.55.5	Post Combined License Activities.....	19-6
19.55.6	Conclusion	19-6
19.58	Winds, Floods, and Other External Events.....	19-7
19.58.1	Introduction	19-7
19.58.2	Summary of Application	19-7
19.58.3	Regulatory Basis.....	19-8
19.58.4	Technical Evaluation.....	19-9
19.58.5	Post Combined License Activities.....	19-15
19.58.6	Conclusion	19-15
19.59	PRA Results and Insights.....	19-15
19.59.1	Introduction	19-15
19.59.2	Summary of Application	19-15
19.59.3	Regulatory Basis.....	19-18
19.59.4	Technical Evaluation.....	19-19
19.59.5	Post Combined License Activities.....	19-26
19.59.6	Conclusion	19-27

APPENDIX 19.A – LOSS OF LARGE AREAS OF THE PLANT DUE TO EXPLOSIONS OR FIRES.....	19.A-1
19.A.1 Introduction.....	19.A-1
19.A.2 Summary of Application.....	19.A-1
19.A.3 Regulatory Basis	19.A-2
19.A.4 Technical Evaluation	19.A-2
19.A.5 Post Combined License Activities	19.A-4
19.A.6 Conclusion.....	19.A-5
20.0 NEAR TERM TASK FORCE RECOMMENDATIONS REQUIREMENTS RESULTING FROM FUKUSHIMA	20-1
20.1 Mitigation Strategies for Beyond-Design-Basis External Events (Based on Recommendation 4.2)	20-4
20.1.1 Introduction	20-4
20.1.2 Summary of Application	20-5
20.1.3 Regulatory Basis.....	20-6
20.1.4 Technical Evaluation.....	20-6
20.1.5 Post Combined License Activities.....	20-10
20.1.6 Conclusion	20-11
20.2 Reliable Spent Fuel Pool Instrumentation (Based on Recommendation 7.1)	20-12
20.2.1 Introduction	20-12
20.2.2 Summary of Application	20-12
20.2.3 Regulatory Basis and Guidance	20-13
20.2.4 Technical Evaluation.....	20-13
20.2.5 Post Combined License Activities.....	20-17
20.2.6 Conclusion	20-18
20.3 Emergency Preparedness (Based on Recommendation 9.3)	20-18
20.3.1 Introduction	20-18
20.3.2 Summary of Application	20-18
20.3.3 Regulatory Basis.....	20-19
20.3.4 Technical Evaluation.....	20-20
20.3.5 Post Combined License Activities.....	20-20
20.3.6 Conclusion	20-20
21.0 DESIGN CHANGES PROPOSED IN ACCORDANCE WITH ISG-11.....	21-2
21.1 Passive Core Cooling System Containment Condensate Return	21-2
21.1.1 Introduction	21-2
21.1.2 Summary of Application	21-3
21.1.3 Regulatory Basis.....	21-4
21.1.4 Technical Evaluation.....	21-5
21.1.5 Post Combined License Activities.....	21-33
21.1.6 Conclusion	21-33
21.2 Main Control Room Dose Departure	21-33
21.2.1 Introduction	21-33
21.2.2 Summary of Application	21-34
21.2.3 Regulatory Basis.....	21-34

21.2.4	Technical Evaluation.....	21-35
21.2.5	Post Combined License Activities.....	21-61
21.2.6	Conclusion	21-61
21.3	Main Control Room Heat Load	21-62
21.3.1	Introduction	21-62
21.3.2	Summary of Application.....	21-63
21.3.3	Regulatory Basis.....	21-63
21.3.4	Technical Evaluation.....	21-65
21.3.5	Post Combined License Activities.....	21-98
21.3.6	Conclusion	21-98
21.4	Hydrogen Vent ITAAC	21-98
21.4.1	Introduction	21-98
21.4.2	Summary of Application.....	21-99
21.4.3	Regulatory Basis.....	21-100
21.4.4	Technical Evaluation.....	21-101
21.4.5	Post Combined License Activities.....	21-112
21.4.6	Conclusion	21-113
21.5	Source Range Neutron Flux Doubling Logic Operating Bypass.....	21-113
21.5.1	Introduction	21-113
21.5.2	Summary of Application.....	21-114
21.5.3	Regulatory Basis.....	21-114
21.5.4	Technical Evaluation.....	21-115
21.5.5	Post Combined License Activities.....	21-125
21.5.6	Conclusion	21-125
22.0	CONCLUSIONS	22-1

LIST OF FIGURES

Figure 2.4.12.4.1 1	Turkey Point Units 6 and 7 power block layout and grading plan. (Source: COL FSAR Figure 2.4.2-202).....	2-85
Figure 2.4.1-2	NOAA Tidal Stations and USGS Stream Gauges in the vicinity of Biscayne Bay (source: Turkey Point Units 6 and 7 COL FSAR Figure 2.4.12-12)	2-87
Figure 2.4.2-1	Units 6 and 7 Local PMP Analysis Subbasin Drainage Areas (Adapted from FSAR Figure 2.4.2 203).....	2-99
Figure 2.4.5-1	Observed high water elevations around Biscayne Bay during Hurricane Andrew	2-117
Figure 02.04.05-2	Biscayne Bay model grid used in applicant's implementation of SLOSH.....	2-123
Figure 02.04.05-3	Surge elevations simulated for different combinations of PMH parameters (Source: Turkey Point Units 6 and 7 COL FSAR Figure 02.04.05-205)	2-124
Figure 02.04.05-4	Applicant's analysis of surge elevation sensitivity to PMH direction and track distance. (Source: Turkey Point Units 6 and 7 COL FSAR Figure 02.04.05-206).....	2-124
Figure 02.04.05-5	Applicant's SLOSH output for the parameter combination producing the PMSS at Units 6 and 7. The black line is the storm track at 258.75 ° from north. (Source: Turkey Point Units 6 and 7 COL FSAR Figure 2.4.5-209)	2-125
Figure 02.04.05-6	Comparison of SLOSH predictions with observed storm surge elevations (Source: Turkey Point Units 6 and 7 COL FSAR Figure 02.04.05-211, modified from Jelesnianski et. al, 1992)	2-126
Figure 02.04.05-6	Storm tracks (blue lines) modeled in ADCIRC analysis for the Turkey Point site (shown with a red circle and x) in Florida.....	2-131
Figure 2.4.6-1	Azores-Gibraltar region showing various faults that make up the oceanic convergence zone boundary (Barkan and others, 2009).....	2-147
Figure 2.4.6-2	The Caribbean Plate Boundary and its Tectonic Elements	2-148
Figure 2.4.9-1	Historical Shoreline Changes at Units 6 & 7 (Modified after Turkey Point Units 6 and 7 COL FSAR Figure 2.4.9-201).....	2-178

LIST OF TABLES

Table 2.1.1-1	NAD83 Coordinates of proposed site provided in Turkey Point Units 6 and 7 COL FSAR	2-15
Table 2.4.2-1	Local Intense Precipitation at the Turkey Point Site (Adapted from FSAR Table 2.4S.2-207)	2-97
Table 2.4.2-2.	Units 6 and 7 Subbasin Local PMP Peak Discharges (Adapted from FSAR Table 2.4.2-211)	2-100
Table 2.4.5.4-1	Assumed PMH Characteristics for Turkey Point Units 6 and 7	2-114
Table 02.04.05.4-2	USACE Turkey Point ADCIRC PMSS.....	2-134
Table 02.04.05.3	FPL SLOSH vs USACE Turkey Point ADCIRC PMSS (880 mb, Rp=30 nm, 10-7 Exceedance Probability).....	2-135

EXECUTIVE SUMMARY

The U.S. Nuclear Regulatory Commission (NRC) regulations in Title 10 of the *Code of Federal Regulations* (10 CFR) Part 52 include requirements for licensing new nuclear power plants.³ These regulations include the NRC's requirements for design certification and combined license (COL) applications. The COL process (10 CFR Part 52, Subpart C, "Combined Licenses") allows an applicant to seek authorization to construct and operate a new nuclear power plant.

This FSER describes the results of a review by the NRC staff of a COL application submitted for two new reactors to be located at the Turkey Point Units 6 and 7 site. The applicant is Florida Power & Light Company (FPL). The staff's review was to determine the applicant's compliance with the requirements of Subpart C of 10 CFR Part 52, as well as the applicable requirements under 10 CFR Parts 30, 40, and 70 governing the possession and use of source, byproduct and special nuclear materials. This FSER identifies the staff's conclusions with respect to the COL safety review.

The NRC regulations in 10 CFR Part 51, "Environmental protection regulations for domestic licensing and related regulatory functions," also require an applicant to submit an environmental report. The NRC reviews the environmental report as part of the Agency's responsibilities under the National Environmental Policy Act of 1969, as amended. The NRC presents the results of that review in a final environmental impact statement (FEIS), which is a report separate from this FSER. The staff's FEIS, NUREG-2176, "Final Environmental Impact Statement for Combined Licenses (COLs) for Turkey Point Nuclear Plant Units 6 and 7," was issued in October 2016, and can be accessed through the Agencywide Documents Access and Management System (ADAMS) at Accession Nos. ML16300A104, ML16300A137, ML16301A018, and ML16300A312.⁴

³ Applicants may also choose to seek a construction permit (CP) and operating license in accordance with 10 CFR Part 50, "Domestic licensing of production and utilization facilities," instead of using the 10 CFR Part 52 process.

⁴ The Agencywide Documents Access and Management System (ADAMS) is the NRC's information system that provides access to all image and text documents that the NRC has made public since November 1, 1999, as well as bibliographic records (some with abstracts and full text) that the NRC made public before November 1999. Documents available to the public may be accessed via the Internet at <http://www.nrc.gov/reading-rm/adams.html#web-based-adams>. Documents may also be viewed by visiting the NRC's Public Document Room at One White Flint North, 11555 Rockville Pike, Rockville, Maryland. Telephone assistance for using web-based ADAMS is available at (800) 397-4209 between 8:30 a.m. and 4:15 p.m., Eastern Time, Monday through Friday, except Federal holidays. The staff is also making this FSER available on the NRC's new reactor licensing public web site at <http://www.nrc.gov/reactors/new-reactors/col/turkey-point/documents.html>.

By letter dated June 30, 2009, the applicant submitted its initial application to the NRC for COLs for two AP1000 advanced passive pressurized-water reactors (PWRs) (ADAMS Accession No. ML091830589) to be located at the Turkey Point Units 6 and 7 site. The Turkey Point Units 6 and 7 site is located in Miami-Dade County, Florida, approximately 25 mi (40 km) south of Miami, 8 mi (13 km) east of Florida City, and 9 mi (14 km) southeast of Homestead, Florida.

The application incorporated by reference 10 CFR Part 52, Appendix D, "Design Certification Rule for the AP1000 Design," including the AP1000 Design Certification Document (DCD) Revision 19. The results of the NRC staff's evaluation of the AP1000 DCD are documented in NUREG-1793, "Final Safety Evaluation Report Related to Certification of the AP1000 Standard Design," and its supplements. The applicant submitted its final update to the COL application, Revision 8, on August 26, 2016.

Appendix A to this FSER identifies certain license conditions, and inspections, tests, analyses and acceptance criteria (ITAAC) that the staff recommends the Commission impose, should COLs be issued to the applicant. In addition to the ITAAC in Appendix A, the ITAAC found in the AP1000 DCD Revision 19 Tier 1 material will also be incorporated into the COLs should COLs be issued to the applicant.

Inspections and audits conducted by the NRC have verified, where appropriate, the conclusions in this FSER. The inspections focused on selected information in the COL application and its references. The FSER identifies applicable inspection reports as reference documents.

The NRC's Advisory Committee on Reactor Safeguards (ACRS) also reviewed the bases for the conclusions in this report. The ACRS independently reviewed those aspects of the application that concern safety, as well as the advanced safety evaluation report without open items (an earlier version of this document), and provided the results of its review to the Commission in reports dated December 14, 2015 and September 16, 2016. Appendix F includes a copy of this report by the ACRS on the COL application, as required by 10 CFR 52.87, "Referral to the Advisory Committee on Reactor Safeguards (ACRS)."

ABBREVIATIONS

χ/Q	atmospheric dispersion
A2LA	American Association for Laboratory Accreditation
AB	annex building
ac	alternating current
ACI	American Concrete Institute
ACP	access control point
ACRS	Advisory Committee on Reactor Safeguards
ADAMS	Agencywide Documents Access and Management System
ADS	automatic depressurization system
AE	architect-engineer
AEA	Atomic Energy Act of 1954
AFFF	aqueous film forming foam
AFUDC	allowance for funds used during construction
AHPS	Advanced Hydrologic Prediction Service
ALARA	as low as is reasonable achievable
ALI	annual limit on intake
ALWR	advanced light-water reactor
AMP	amperes
ANI	American Nuclear Insurers
ANS	Alert and Notification Systems
ANS	American Nuclear Society
ANSI	American National Standards Institute
ANSS	Advanced National Seismic System
AOO	anticipated operational occurrence
AOV	air-operated valve
ASA	Applicable Safety Analyses
ASCE	American Society of Civil Engineers
ASE	advanced safety evaluation
ASHRAE	American Society of Heating, Refrigerating and Air-Conditioning Engineers
ASME	American Society of Mechanical Engineers
ASTM	American Society for Testing and Materials
ATE	advisory to evacuate
ATWS	anticipated transients without scram
AWWA	American Water Works Association
B&PV	Boiler and Pressure Vessel (ASME BPV Code)
BDBE	beyond-design basis event
BE	best estimate

BL	Bulletin
BLN	Bellefonte Nuclear Station
BPV	Boiler & Pressure Vessel
BTP	Branch Technical Position
BWR	boiling-water reactor
C	Celsius
C&C	command & control
CAS	central alarm station
CAV	cumulative absolute velocity
CCS	component cooling water system
CDF	core damage frequency
CDI	conceptual design information
CDM	certified design material
CDRS	control rod drive system
CEM	Coastal Engineering Manual
CFBC	Cross Florida Barge Canal
CFD	computational fluid dynamics
cfm	cubic feet per minute
CFR	<i>Code of Federal Regulations</i>
cfs	cubic feet per second
cGy	centiGray
CLSM	controlled low strength material
cm	centimeters
CMT	core makeup tank
COL	combined license
CP	construction permit
CR	control room
CR3	Crystal River Unit 3
CRD	control rod drive
CRDM	control rod drive mechanism
CRDS	control rod drive system
CREC	Crystal River Energy Complex
CRNP	Crystal River Nuclear Plant
CRR	cyclic resistance ratio
CS	containment system
CS	core supports
CS	critical system
CSA	control support area
CSC	Coastal Services Center

CSDRS	certified seismic design response spectra
CTA	critical target area
CVCS	chemical and volume control system
CVS	chemical and volume control system
CWS	circulating water system
DAC	derived air concentration
DAS	Diverse Actuation System
DBA	design-basis accident
DBE	design-basis event
DBT	design-basis threat
dc	direct current
DC	design certification
DCA	design certification amendment
DCD	design control document
DCP	Design Change Package
DCRA	design-centered review approach
DE	deaggregation earthquakes
DEI	dose equivalent iodine
DEM	digital elevation model
DEM	Division of Emergency Management
DEP	Departure
DF	design factor
DG	diesel generator
DHBRC	Department of Health, Bureau of Radiation Control
DHEC	Department of Health and Environmental Control
DHS	Department of Homeland Security
DNBR	departure from nucleate boiling ratio
DOE	Department of Energy
DOT	Department of Transportation
D-RAP	Design Reliability Assurance Program
DTS	demineralized water treatment system
DVI	direct vessel injection
DWS	demineralized water system
EAB	exclusion area boundary
EAL	emergency action level
EAS	Emergency Alert System
EC	Emergency Coordinator
ECC-GC	extended continental crust Gulf Coast

ECCS	emergency core cooling system
ECL	effective concentration limit
ED	Emergency Director
EDMG	Extensive Damage Mitigation Guidelines
EIA	Energy Information Agency
EIS	Environmental Impact Statement
ENC	Emergency News Center
ENS	Emergency Notification System
EOC	emergency operation center
EOF	emergency operations facility
EOP	emergency operating procedure
EP	Emergency Plan
EP	emergency planning
EPA	Environmental Protection Agency
EPAct	Energy Policy Act of 2005
EPC	engineering, procurement, and construction
EPDM	ethylene propylene diene monomer
EPIP	emergency plan implementing procedure
EP-ITAAC	emergency planning-inspections, tests, analyses, and acceptance criteria
EPRI	Electric Power Research Institute
EPZ	emergency planning zone
EQ	environmental qualification
EQL	equivalent linear
EQMEL	Environmental Qualification Master Equipment List
ERDS	emergency response data system
ERF	emergency response facility
ERM	Eastern rift margin
ERO	emergency response officer
ERO	Emergency Response Organization
ERT	emergency response team
ESATCOM	Emergency Satellite Communications System
ESF	engineered safety feature
ESFAS	engineered safety features actuation system
ESP	Early Site Permit
ETE	evacuation time estimate
ETS	Emergency Telephone System
F	Fahrenheit
FAC	flow-accelerated corrosion
FBI	Federal Bureau of Investigation

FDLE	Department of Law Enforcement
FEIS	final environmental impact statement
FEM	Finite Element Model
FEMA	Federal Emergency Management Agency
FERC	Federal Energy Regulatory Commission
FFD	fitness for duty
FHA	Fuel Handling Accident
FIRS	foundation input response spectra
FIV	flow induced vibration
FMCRD	fine motion control rod drive
FMEA	failure mode and effects analysis
fps	feet per second
FPS	fire protection system
FPSC	Florida Public Service Commission
FR	<i>Federal Register</i>
FRCC	Florida Reliability Coordinating Council
FRS	floor response spectra
FS	factor of safety
FSAR	final safety analysis report
FSER	final safety evaluation report
ft	feet
GALL	Generic Aging Lessons Learned
GCSZ	Gulf Coastal Source Zones
GDC	General Design Criteria (Criterion)
GE	General Emergency
GG&S	Geotechnical, Geological, and Seismological
GL	Generic Letter
GMRS	ground motion response spectra
gpm	gallons per minute
GSI	Generic Safety Issue
GSI	geologic strength index
GSU	generator step-up
GTS	generic technical specification
GWMS	gaseous waste management system
HCM	Highway Capacity Manual
HCLPF	high confidence in low probability of failure
HEPA	high efficiency particulate air
HFE	human factors engineering

HP	health physics
HPN	Health Physics Network
HPS	Health Physics Society
hr	hour
HRA	human reliability analysis
HRHF	hard rock high frequency
HRTS	Hot Ringdown Telephone System
HSI	human-system interface
HV	high voltage
HVAC	heating, ventilation, and air conditioning
HX	heat exchanger
Hz	Hertz
HZP	Hot Zero Power
I&C	instrumentation and control
IBC	International Building Code
ICMO	interim compensatory order
IDLH	immediate danger to life and health
IDS	1E dc and uninterruptible power supply system
IEEE	Institute of Electrical and Electronic Engineers
IFR	Interim Findings Report
IGSCC	intergranular stress corrosion cracking
IHP	integrated head package
IIS	incore instrumentation system
ILAC	International Laboratory Accreditation Cooperation
in	inch
INPO	Institute of Nuclear Power Operations
IRWST	in-containment refueling water storage tank
ISA	independent safety assessment
ISC	International Seismological Centre
ISG	Interim Staff Guidance
ISI	inservice inspection
ISL	Information Systems Laboratory, Inc.
IST	inservice testing
ITAAC	inspections, tests, analyses, and acceptance criteria
ITP	Initial Test Program
JOG	Joint Owners Group
JTWG	Joint Test Working Group

kg/m ³	kilogram per cubic meter
kg/yr	kilograms per year
km	kilometers
kPa	kilopascal
kV	kilovolt
kWe	kilowatt electric
LAN	Local Area Network
lb/ft ²	pounds per square foot
LB	lower bound
LBB	leak-before-break
LCCWS	low capacity chilled water subsystem
LCD	Local Climatological Data
LCO	limiting condition for operation
LEFM	Leading Flow Edge Meter
LLB	Lower LB case
LLEA	local law enforcement agency
LLHS	light load handling system
LLNL	Lawrence Livermore National Laboratory
LLRW	low-level radioactive waste
LMA	left margin annotation
LNP	Levy Nuclear Plant
LOA	letter of agreement
LOAC	Loss of AC Power to Plant Auxiliaries
LOCA	loss-of-coolant accident
LOLA	loss of large area
LOOP	loss of offsite power
LPZ	low population zone
LRF	large release frequency
LSS	low strategic significance
LRA	locked rotor accident
LTOP	low-temperature overpressure protection
LWA	Limited Work Authorization
LWMS	liquid waste management system
LWR	light-water reactor
M	magnitude
m	meter
m/s	meters per second
m ³ /s	cubic meters per second

Ma	million years ago
MAAP	Modular Accident Analysis Program
m_b	body-wave magnitude
Mbtu/hr	one million British thermal units/hour
MC&A	material control and accounting
MCL	Management Counterpart Link
MCR	main control room
MCRE	main control room envelope
M_d	duration magnitude
MEI	maximally exposed individual
MERL	Mobile Emergency Radiological Laboratory
MESE	Mesozoic and younger extended prior
mgd	million gallons per day
mGy	milliGray
mi	miles
MIDC-A	Midcontinent A
MIT	Massachusetts Institute of Technology
M_L	local magnitude
mld	million liters per day
MLU	Multi-Layer Unsteady
mm	millimeters
Mmax	maximum magnitude
MOA	Memorandum of Agreement
MOM	maximum envelope of water
MOU	Memorandum of Understanding
MOV	motor-operated valve
MOX	mixed-oxide
mph	miles per hour
MR	Maintenance Rule
MRA	Mutual Recognition Arrangement
mrad	millirad
mrem	millirem
MSD	Mitigative Strategies Description
MSLB	Main Steam Line Break
MSSS	main steam supply system
MST	Mitigative Strategies Table
mSv	milliSievert
MT	magnetic particle
MW	megawatts
MWe	megawatts electric

MWt	megawatts thermal
N	North
NCDC	National Climatic Data Center
NDQAM	Nuclear Development Quality Assurance Manual
NEI	Nuclear Energy Institute
NFPA	National Fire Protection Association
NGS	National Geodetic Survey
NI	nuclear island
NIRMA	Nuclear Information and Records Management Association
NIST	National Institute of Standards and Technology
NMFS	New Madrid Fault System
NNS	non-nuclear safety
NOAA	National Oceanic and Atmospheric Administration
NOUE	Notification of Unusual Event
NOV	Notice of Violation
NPSH	net positive suction head
NRC	U.S. Nuclear Regulatory Commission
NRCOC	NRC Headquarters Operations Center
NRF	National Response Framework
NRO	Office of New Reactors
NS	nonseismic
NSM	Nuclear Shift Manager
NSSS	nuclear steam system supplier
NSW	nonlinear shallow-water
NTTF	Near-Term Task Force
NUMARC	Nuclear Management and Resources Council
NVLAP	National Voluntary Laboratory Accreditation Program
NW	northwest
NWS	National Weather Service
OBE	operating basis earthquake
ODCM	Offsite Dose Calculation Manual
OE	operating experience
OER	operating experience review
OHLHS	overhead heavy load handling system
OM	Operation and Maintenance (ASME OM Code)
OPRAA	operational phase reliability assurance activity
ORE	occupational radiation exposure
ORO	Offsite-Response Organizations

OSC	Operational Support Center
OSHA	Occupational Safety and Health Administration
PA	protected area
PABS	private automatic branch system
PAM	Postaccident Monitoring
PAP	primary access point
PAR	protective action recommendation
PBSRS	performance based surface horizontal and vertical response spectra
PCCAWST	passive containment cooling ancillary water storage tank
PCCWST	passive containment cooling water storage tank
pcf	pounds per cubic foot
pcf	per cubic foot
PCP	Process Control Program
PCS	passive containment cooling system
PDP	procedure development program
PE	Polyethylene
PEC	Progress Energy Carolinas, Inc.
PEF	Progress Energy Florida
PF	performance goal
PGA	peak ground acceleration
PGM	Plant General Manager
PGP	procedures generation package
PID	Public Information Director
P&IDs	pipng and instrumentation diagrams
PLT	point load test
PM	preventive maintenance
PMCL	Protective Measures Counterpart Link
PMP	probable maximum precipitation
PMS	protection and safety monitoring
PMSS	probable maximum storm surge
PMT	pressuremeter tests
PORV	power-operated relief valve
POV	power-operated valve
ppm	parts per million
PRA	probabilistic risk assessment
PRHR	passive residual heat removal
PRP	Peer Review Panel
psf	pounds per square foot
PSHA	probabilistic seismic hazard analysis

PSI	preservice inspection
psi	pounds per square inch
psig	pounds per square inch gauge
PS-ITAAC	physical security inspections, tests, analyses, and acceptance criteria
PSP	Physical Security Plan
P-T	pressure temperature
PT	liquid penetrant
PT&O	plant test and operations
PTAC	Plant Transmission Activities Coordinator
PTS	plant-specific technical specifications
Pu	per unit
PWR	pressurized-water reactor
PWS	potable water system
PWSCC	primary water stress corrosion cracking
PXS	passive core cooling system
QA	quality assurance
QDPS	Qualified Data Processing System
QAPD	Quality Assurance Program description
QC	quality control
RAI	request for additional information
RAP	reliability assurance program
RAT	reserve auxiliary transformer
RB	radwaste building
RCA	radiation controlled area
RCCA	rod cluster control assembly
RCL	reactor coolant loop
RCOL	reference combined license
RCP	reactor coolant pump
RCPB	reactor coolant pressure boundary
RCS	reactor coolant system
REA	Rod Ejection Accident
REAC/TS	Radiation Emergency Assistance Center/Training Site
rem	roentgen equivalent man
REMP	Radiological Emergency Management Plan
REP	radiological emergency preparedness
RG	regulatory guide
RH	relative humidity
RIS	Regulatory Issue Summary

RLME	repeated large magnitude earthquake
RMS	rock mass rating
RMS	radiation monitoring system
RMS	root-mean-square
RNS	residual heat removal system
RO	reactor operator
RPP	Radiation Protection Program
RPV	reactor pressure vessel
RSCL	Reactor Safety Counterpart Link
RSW	Remote Shutdown Workstation
RTDP	revised thermal design procedure
RT _{NDT}	nil-ductility reference transition temperature
RTNSS	regulatory treatment of nonsafety systems
RTP	rated thermal power
RT _{PTS}	pressurized thermal shock reference temperature
RV	reactor vessel
RVSP	reactor vessel surveillance capsule program
RWS	raw water system
RXS	reactor system
S&PC	steam and power conversion
SAE	Site Area Emergency
SAMSON	Solar and Meteorological Surface Observation Network
SAR	safety analysis report
SAT	systematic approach to training
SBO	station blackout
SC	steel concrete composite
SCBA	self-contained breathing apparatus
SCOR	soil column outcrop response
SCE&G	South Carolina Electric and Gas Company
SCOL	subsequent combined license
SCDOT	South Carolina Department of Transportation
SCP	Safeguards Contingency Plan
SCPSC	South Carolina Public Service Commission
SCR	stable continental region
SE	safety evaluation
SEC	Securities and Exchange Commission
SER	safety evaluation report
SFP	spent fuel pool
SFS	spent fuel pool cooling system

SG	steam generator
SGI	safeguards information
SGTR	steam generator tube rupture
SLOSH	Sea, Lake, and Overland Surge from Hurricanes
s/m	seconds per cubic meter
SNC	Southern Nuclear Operating Company
SNM	special nuclear material
SMA	seismic margins analysis
SNMPPP	Special Nuclear Material Physical Protection Program
SP	Setpoint Program
SPDS	safety parameter display system
SPT	standard penetration test
sq	square
sq mi	square mile
SR	surveillance requirement
SRM	Staff Requirements Memorandum
SRO	senior reactor operator
SRP	standard review plan
SSAR	Site Safety Analysis Report
SSC	seismic source characterization
SSCs	structures, systems, and components
SSE	safe shutdown earthquake
SSI	soil-structure interaction
SS-ITAAC	site-specific inspections, tests, analyses and acceptance criteria
SSHAC	Senior Seismic Hazard Analysis Committee
STA	Shift Technical Advisor
STD	Standard
STS	standard technical specification
SUNSI	Sensitive Unclassified Non-Safeguards Information
SUP	Supplement
Sv	Sievert
SWFWMD	Southwest Florida Water Management District
SWMS	solid waste management system
SWPT	State Warning Point-Tallahassee
SWS	service water system
SWFWMD	South West Florida Water Management District
T&QP	Training and Qualification Plan
TAC	total annual cost
TB	turbine building

TCP	traffic control point
TCS	turbine building closed cooling water system
TEDE	total effective dose equivalent
TG	turbine-generator
TGS	turbine generator system
TLD	thermoluminescent dosimeter
TMI	Three Mile Island
TR	technical report
TS	technical specification
TSC	Technical Support Center
TSCSR	Truncated Soil Column Surface Response
TSO	transmission system operator
TSP	trisodium phosphate
TSTF	Technical Specification Task Force Traveler
TVA	Tennessee Valley Authority
U	unconfined compressive strength
UAT	unit auxiliary transformer
UB	upper bound
UCS	unconfined compressive strength
UCSS	updated Charleston seismic source
UF ₆)	uranium hexafluoride
UFM	ultrasonic flow meter
UFSAR	Updated Final Safety Analysis Report
UHF	ultra high frequency
UHRS	uniform hazard response spectra
UPS	uninterruptible power supply
USACE	United States Army Corps of Engineers
USE	upper shelf energy
USGCRP	United States Global Change Research Program
URD	Utility Requirements Document
USGS	United States Geological Survey
UT	ultrasonic
V&V	verification and validation
VAC	volts alternating current
VBS	nonradioactive ventilation system
VCSNS	V.C. Summer Nuclear Station
Vdc	volts direct current
VEGP	Vogtle Electric Generating Plant

VES	main control room emergency habitability system
VFS	containment air filtration system
V/H	vertical to horizontal
VHRA	very high radiation area
WAC	waste acceptance criteria
WCAP	Westinghouse Commercial Atomic Power
WEC	Westinghouse Electric Company
WSW	worst meteorological sector
WUS	Western United States
WWRB	waste water retention basin
WWS	waste water system
YFS	yard fire system