

**From:** [Sean M. McDeavitt](#)  
**To:** [Boyle, Patrick](#); [Newhouse, Jerry E](#)  
**Subject:** [External\_Sender] Fwd: FW: Proposed TS 4.0 Surveillance Requirements Response  
**Date:** Friday, October 14, 2016 4:22:01 PM

---

FYI . . . I am only marginally available today but I do affirm and accept the text that was provided.

Sent from my Verizon Wireless 4G LTE smartphone

----- Original message -----

From: "Newhouse, Jerry E"  
Date: 10/14/2016 3:06 PM (GMT-06:00)  
To: "Sean M. McDeavitt"  
Subject: RE: FW: Proposed TS 4.0 Surveillance Requirements Response

Patrick,

I have reviewed your comments from your email today concerning the AGN-201M Technical Specification (TS) Section 4.0. I have discussed it with my staff and I propose the following update:

Proposed TS 4.0 for license amendment 15:

#### 4.0 SURVEILLANCE REQUIREMENTS

Actions specified in this section, with the exception of Section 4.5, are not required to be performed if during the specified surveillance period the reactor has not been brought critical or is maintained in a shutdown condition extending beyond the specified surveillance period. However, the surveillance requirements must be fulfilled prior to subsequent startup of the reactor unless reactor operation is required for performance of the surveillance. [Any surveillance that can only be performed during reactor operation may be postponed until the reactor is operable.](#)

#### Oath of Affirmation

I declare under penalty of perjury that the foregoing is true and correct to the best of my knowledge.

Sean M. McDeavitt  
Director, Nuclear Science Center  
Principal Investigator, Fuel Cycle & Materials Laboratory  
Department of Nuclear Engineering  
Texas A&M University  
[mcdeavitt@tamu.edu](mailto:mcdeavitt@tamu.edu)

3403 TAMU| College Station, TX 77843  
Tel.: 979-862-1745 (Houston/ANIN) | 979-845-5909 (NSC) | Cell: 979-595-8142  
Fax: 979-845-6443  
<http://nsc.tamu.edu/>  
<http://fcml.tamu.edu/>  
<http://nuclear.tamu.edu/index.php>