

TVA


WALL THICKNESS
PROFILE SHEET

REPORT NO:

R-P0149

PROJECT: WBNWELD NO: ECF-C3-2UNIT: 2SYSTEM: RCSRecord Thickness Measurements As
Indicated, Including Weld Width,
Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	N/A	N/A	N/A	N/A
2	3.97	N/A	3.72	3.62
3	3.58	2.29	3.48	3.31
4	3.21	3.17	3.24	3.20
5	2.93	2.99	2.93	2.94

CROWN HEIGHT: FlushDIAMETER: 310CROWN WIDTH: 2.75WELD LENGTH: 105.5

FLOW

0°

a

90°

a

180°

a

270°

a

Pump

Pipe

EXAMINER: Marcie KalkbrennerLEVEL: IIDATE: 2/4/2009REVIEWED BY: Darlene DureyLEVEL: IIIDATE: 2-17-09ANII: DEDATE: 3/9/09PAGE 4 OF 5

TVA

Office of Nuclear Power

PROJECT: WBN


SYSTEM: RCS

REPORT NO.:

UNIT: 2

WELD NO: RCE-C3-2

R-80149



BY: Marcie Kalkbrenner / Marcie Kalkbrenner

LEVEL: II

DATE: 2/4/2009

PAGE 5 OF 5