

TVA

WALL THICKNESS  
PROFILE SHEET

REPORT NO:

R-P0152

PROJECT: WBNUNIT: 2

SYSTEM

WELD NO:



RCS

WELD NO:

SYSTEM:

RCF-G1-4Record Thickness Measurements As  
Indicated, Including Weld Width,  
Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	3.16	3.06	2.66	3.37
2	3.23	3.37	3.23	3.13
3	3.30	3.36	3.30	3.39
4	3.95	3.89	3.81	3.69
5	N/A	N/A	N/A	N/A

CROWN HEIGHT: FlushDIAMETER: 31.0CROWN WIDTH: 3"WELD LENGTH: 119.5"EXAMINER: Jose Alejandro [Signature]  
LEVEL: II  
DATE: 02-17-09REVIEWED BY: [Signature]  
LEVEL: III DATE: 02-24-09ANII: [Signature]  
DATE: 3/9/09  
PAGE 4 OF 5

TVA

Office of Nuclear Power

PROJECT: WBN


SYSTEM: RCS

REPORT NO.:

UNIT: 2

WELD NO: RCF-G1-4

R. P0152



BY: Jose Alejandro Jose Alejandro LEVEL: II DATE: 2-17-09 PAGE 5 OF 5