

TVA


WALL THICKNESS
PROFILE SHEET

REPORT NO:

R. P. 1161

PROJECT: WBNWELD NO: SIF-D119-03UNIT: 2SYSTEM: SISRecord Thickness Measurements As
Indicated, Including Weld Width,
Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	N/A	N/A	N/A	N/A
2	.390	.313	.322	.312
3	.325	.310	.309	.303
4	.343	.303	.354	.359
5	.392	.367	.393	.372

CROWN HEIGHT: .1DIAMETER: 4CROWN WIDTH: .4WELD LENGTH: 14.25"

Valve

0°

Flow

Pipe

90°

180°

270°

EXAMINER:

Brad Langston

REVIEWED BY:

Doreen Dwyer

ANII:

TMM

LEVEL:

II

LEVEL:

II

DATE:

6-25-10

DATE:

7-20-10

DATE:

6-17-10

PAGE

6

OF

67

TVA

Office of Nuclear Power

PROJECT: WBN

SYSTEM: SIS


REPORT NO.:

UNIT: 2

WELD NO: SIF-D119-03

VAIVE

P:PE



BY: Brad Langston

LEVEL: II

DATE: 6-17-10

PAGE 7 OF 7