

**TVA**

Office of Nuclear Power

PROJECT: WBN SYSTEM: SIS (063)

UNIT: 2 WELD NO: SIF-B-T097-12


REPORT NO.:

R.P2473

PIPE

← FLOW

FLANGE



50% one sided examination  
code credit coverage achieved.

BY: (Signature) LEVEL: 1 DATE: 03-18-15 PAGE 6 OF ( 7 )

<h1>TVA</h1>	<h2>WALL THICKNESS PROFILE SHEET</h2>	REPORT NO: <u>R-P2473</u>
PROJECT: <u>WBN</u>		WELD NO: <u>SIF-B-T097-12</u>
UNIT: <u>2</u>		SYSTEM: <u>SIS (063)</u>

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
<u>1</u>	<u>*</u>			
<u>2</u>	<u>.327</u>	<u>N</u>		
<u>3</u>	<u>.310</u>			
<u>4</u>	<u>.299</u>		<u>A</u>	
<u>5</u>	<u>.321</u>			

CROWN HEIGHT: <u>FLUSH</u>	DIAMETER: <u>1.50</u>
CROWN WIDTH: <u>.4</u>	WELD LENGTH: <u>6.25</u>

PIPE ← FLOW FLANGE

\* No thickness readings taken due to configuration.

EXAMINER: <u>[Signature]</u>	REVIEWED BY: _____	ANII: <u>[Signature]</u>
LEVEL: <u>II</u>	LEVEL: _____	DATE: <u>7/14/15</u>
DATE: <u>03-18-15</u>	DATE: _____	PAGE: <u>7</u> OF <u>7</u>