



Sean O'Connor
General Manager Engineering
Harris Nuclear Plant
5413 Shearon Harris Rd
New Hill NC 27562-9300

919.362.3140

OCT 21 2016

10 CFR 50, Appendix E.VI.3.a

Serial: HNP-16-093

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Shearon Harris Nuclear Power Plant, Unit 1
Docket No. 50-400/Renewed License No. NPF-63

Subject: 30-Day Notice of Software Changes to the Emergency Response Data System (ERDS)

In accordance with 10 CFR 50, Appendix E.VI.3.a, Duke Energy, LLC, is submitting this 30-day post-implementation notice for software changes made to transmitted data points in the Shearon Harris Nuclear Power Plant (HNP), Unit 1 Emergency Response Data System (ERDS) Data Point Library.


HNP implemented License Amendment No. 151 on September 22, 2016. The Amendment revised Technical Specification Table 2.2-1, Reactor Trip System Instrumentation Trip Setpoints, to reduce the Pressurizer Water Level - High Trip Setpoint from $\geq 92\%$ to $\geq 87\%$. This change has been applied to the corresponding ERDS point LRC9459 Average Pressurizer Level.

Specific changes to point LRC9459 in the ERDS Data Point Library include:

1. The Alarm/Trip High Setpoint changed to 87% from the previous 92%.
2. The ERDS Quality Code 6 (High Alarm) is now applied for values $\geq 87\%$, rather than $\geq 92\%$.

This submittal contains no regulatory commitments. Please refer any questions regarding this submittal to John Caves, Manager, Regulatory Affairs, at (919) 362-2406.

Sincerely,



Sean O'Connor

cc: M. Riches, NRC Resident Inspector, HNP
M. Barillas, NRC Project Manager, HNP
C. Haney, NRC Regional Administrator, Region II



Sean O'Connor
General Manager Engineering
Harris Nuclear Plant
5413 Shearon Harris Rd
New Hill NC 27562-9300

919.362.3140

10 CFR 50, Appendix E.VI.3.a

Serial: HNP-16-093

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Shearon Harris Nuclear Power Plant, Unit 1
Docket No. 50-400/Renewed License No. NPF-63

Subject: 30-Day Notice of Software Changes to the Emergency Response Data System (ERDS)

In accordance with 10 CFR 50, Appendix E.VI.3.a, Duke Energy, LLC, is submitting this 30-day post-implementation notice for software changes made to transmitted data points in the Shearon Harris Nuclear Power Plant (HNP), Unit 1 Emergency Response Data System (ERDS) Data Point Library.

HNP implemented License Amendment No. 151 on September 22, 2016. The Amendment revised Technical Specification Table 2.2-1, Reactor Trip System Instrumentation Trip Setpoints, to reduce the Pressurizer Water Level - High Trip Setpoint from $\geq 92\%$ to $\geq 87\%$. This change has been applied to the corresponding ERDS point LRC9459 Average Pressurizer Level.

Specific changes to point LRC9459 in the ERDS Data Point Library include:

1. The Alarm/Trip High Setpoint changed to 87% from the previous 92%.
2. The ERDS Quality Code 6 (High Alarm) is now applied for values $\geq 87\%$, rather than $\geq 92\%$.

This submittal contains no regulatory commitments. Please refer any questions regarding this submittal to John Caves, Manager, Regulatory Affairs, at (919) 362-2406.

Sincerely,

Sean O'Connor

cc: M. Riches, NRC Resident Inspector, HNP
M. Barillas, NRC Project Manager, HNP
C. Haney, NRC Regional Administrator, Region II