



November 4, 2016
NND-16-0462
10 CFR 52.99(c)(1)

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Subject: Virgil C. Summer Nuclear Station (VCSNS) Unit 2
Combined License No. NPF-93
Docket Number 52-027
ITAAC Closure Notification on Completion of ITAAC 2.2.03.12a.i [Index
No. 214]

Attachments: 1. References
2. Equipment Qualification ITAAC Compliance Table

The purpose of this letter is to notify the Nuclear Regulatory Commission (NRC) in accordance with 10 CFR 52.99(c)(1) of the completion of Virgil C. Summer Nuclear Station (VCSNS) Unit 2 Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) Item 2.2.03.12a.i for verifying that each squib valve changes position as indicated in Table 2.2.3-1 under design conditions. The References supporting ITAAC completion are identified in Attachment 1. The closure process for this ITAAC is based on the guidance described in NEI 08-01 (Reference 1), which was endorsed by the NRC in Regulatory Guide 1.215.

ITAAC Statement

Design Commitment:

12.a) The squib valves and check valves identified in Table 2.2.3-1 perform an active safety-related function to change position as indicated in the table.

Inspections, Tests, Analyses:

i) Tests or type tests of squib valves will be performed that demonstrate the capability of the valve to operate under its design condition.

Acceptance Criteria:

i) A test report exists and concludes that each squib valve changes position as indicated in Table 2.2.3-1 under design conditions.

ITAAC Determination Basis

Multiple ITAAC are performed to demonstrate that the squib valves and check valves identified in Table 2.2.3-1 (see Attachment 2) perform an active safety-related function to change position as indicated in the table. The subject ITAAC requires tests or type tests of squib valves to be performed to demonstrate the capability of the valve to operate under its design conditions.

The functional qualification program for the AP1000 squib valves was developed based on American Society of Mechanical Engineers (ASME) QME-1-2007, "Qualification of Active Mechanical Equipment Used in Nuclear Power Plants" (Reference 2). The qualification was based on the ASME QME-1-2007 requirements for power operated valve assemblies.

Functional qualification was performed under the design conditions identified in the design specification for the squib valves (Reference 3) to demonstrate that each squib valve is qualified to perform its designated function when used in its intended service. In accordance with ASME QME-1-2007, qualification is substantiated by demonstrating the relationship between the service requirements and the type-testing and analysis that was conducted as part of this qualification program.

Type-testing was performed, including natural frequency determination, sealing capability testing, submergence, functional operation, and flow characteristics, for the ranges of pressure, temperature and flow for each valve. In accordance with ASME QME-1-2007, the functional qualification process for these valves also included valve internal inspections, actuator inspection and testing, orientation requirements, leakage limitations, diagnostic data collection and analysis methods, static and dynamic flow diagnostic testing, and thermal binding evaluations.

The results of the qualification are documented in the Equipment Qualification Data Package (Reference 4) and Equipment Qualification Summary Report (Reference 5). These reports summarize the test methodology and ASME QME-1-2007 functional qualification that demonstrate that each squib valve changes position as indicated in Table 2.2.3-1 under design conditions.

ITAAC Finding Review

In accordance with plant procedures for ITAAC completion, SCE&G performed a review of all findings pertaining to the subject ITAAC and associated corrective actions. This review found three (3) closed notice of nonconformances (NONs) associated with this ITAAC:

1. 99900404/2012-201-01
2. 99900080/2012-201-01
3. 99900080/2013-201-01

The corrective actions for the findings have been completed and the findings are closed. This review is documented in the completion package for ITAAC 2.2.03.12a.i (Reference 6), which is available for NRC inspection.

ITAAC Completion Statement

Based on the above information, SCE&G hereby notifies the NRC that ITAAC 2.2.03.12a.i was performed for VCSNS Unit 2 and that the prescribed acceptance criteria are met.

Systems, structures, and components verified as part of this ITAAC are being maintained in their as-designed, ITAAC compliant condition in accordance with approved plant programs and procedures.

We request NRC staff confirmation of this determination and publication of the required notice in the Federal Register per 10 CFR 52.99(e)(1).

If there are any questions, please contact Ryder Thompson at (803) 941-9812.

Sincerely,



April R. Rice
Manager
Nuclear Licensing
New Nuclear Deployment

- c. Document Control Desk
Catharine Haney – Region II Regional Administrator
Tomy Nazario – Senior Resident
Patrick Heher - NRC
Thomas R. Fredette – NRC
Billy Gleaves – NRC
James Reece – NRC
Marion Cherry – Santee Cooper
Stephen A. Byrne – SCE&G
Jeffrey B. Archie – SCE&G
Ronald A. Jones – SCE&G
Alan Torres – SCE&G
Ryder Thompson – SCE&G
Nick Kellenberger – SCE&G
April Rice – SCE&G
Justin Bouknight – SCE&G
Alvis J. Bynum – SCE&G
Kyle Young – SCE&G
Cynthia Lanier – SCE&G
Kathryn M. Sutton – Morgan Lewis
Carl Churchman – Westinghouse
William Macecevic – Westinghouse
Brian McIntyre – Westinghouse
Brian J. Bedford – Westinghouse
Curtis Castell – WECTEC
Chuck Baucom – WECTEC
Peter Leroy – WECTEC
Jeff Hawkins - Fluor
vcsummeremail@westinghouse.com
vcsummer2&3project@westinghouse.com
DCRM-EDMS@SCANA.COM

References (available for NRC inspection):

1. NEI 08-01, Industry Guideline for the ITAAC Closure Process Under 10 CFR Part 52.
2. American Society of Mechanical Engineers (ASME) QME-1-2007, "Qualification of Active Mechanical Equipment Used in Nuclear Power Plants"
3. APP-PV70-Z0-001, Squib (Pyrotechnic Actuated) Valves, ASME Boiler and Pressure Vessel Code, Section III Class 1
4. APP-PV70-VBR-003, Equipment Qualification Data Package for 8" Squib Valves for Use in the AP1000 Plant
5. APP-PV70-VBR-002, Equipment Qualification Summary Report for 8" Squib Valves for Use in the AP1000 Plant
6. ITAAC 2.2.03.12a.i Completion Package

Attachment 2

EQUIPMENT QUALIFICATION ITAAC COMPLIANCE MATRIX FOR SQUIB VALVES IN TABLE 2.2.3-1

SYSTEM: PASSIVE CORE COOLING SYSTEM

Equipment Name	Tag No.	Active Function	EQ Summary Report Number	EQ Data Package Number
Containment Recirculation A Squib Valve	PXS-PL-V118A	Transfer Open	APP-PV70-VBR-002	APP-PV70-VBR-003
Containment Recirculation B Squib Valve	PXS-PL-V118B	Transfer Open	APP-PV70-VBR-002	APP-PV70-VBR-003
Containment Recirculation A Squib Valve	PXS-PL-V120A	Transfer Open	APP-PV70-VBR-002	APP-PV70-VBR-003
Containment Recirculation B Squib Valve	PXS-PL-V120B	Transfer Open	APP-PV70-VBR-002	APP-PV70-VBR-003
IRWST Injection A Squib Valve	PXS-PL-V123A	Transfer Open	APP-PV70-VBR-002	APP-PV70-VBR-003
IRWST Injection B Squib Valve	PXS-PL-V123B	Transfer Open	APP-PV70-VBR-002	APP-PV70-VBR-003
IRWST Injection A Squib Valve	PXS-PL-V125A	Transfer Open	APP-PV70-VBR-002	APP-PV70-VBR-003
IRWST Injection B Squib Valve	PXS-PL-V125B	Transfer Open	APP-PV70-VBR-002	APP-PV70-VBR-003