

M. J. Yox  
Regulatory Affairs Director  
Vogtle 3&4  
Nuclear Development

Southern Nuclear  
Operating Company, Inc.  
7825 River Road  
Waynesboro, GA 30830  
  
Tel 706.848.6459



Docket No.: 52-025

**OCT 3 1 2016**

ND-16-2193  
10 CFR 52.99(c)(3)

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555-0001

Southern Nuclear Operating Company  
Vogtle Electric Generating Plant Unit 3  
Notice of Uncompleted ITAAC 225-days Prior to Initial Fuel Load  
Item 2.1.02.12a.ii [Index Number 54]

Ladies and Gentlemen:

Pursuant to 10 CFR 52.99(c)(3), Southern Nuclear Operating Company hereby notifies the NRC that as of October 14, 2016, Vogtle Electric Generating Plant (VEGP) Unit 3 Uncompleted Inspection, Test, Analysis, and Acceptance Criteria (ITAAC) Item 2.1.02.12a.ii [Index Number 54] has not been completed greater than 225-days prior to initial fuel load. The Enclosure describes the plan for completing ITAAC 2.1.02.12a.ii [Index Number 54]. Southern Nuclear Operating Company will at a later date provide additional notifications for ITAAC that have not been completed 225-days prior to initial fuel load.

This notification is informed by the guidance described in NEI-08-01, *Industry Guideline for the ITAAC Closure Process Under 10 CFR Part 52*, which was endorsed by the NRC in Regulatory Guide 1.215. In accordance with NEI 08-01, this notification includes ITAAC for which required inspections, tests, or analyses have not been performed or have been only partially completed. All ITAAC will be fully completed and all Section 52.99(c)(1) ITAAC Closure Notifications will be submitted to NRC to support the Commission finding that all acceptance criteria are met prior to plant operation, as required by 10 CFR 52.103(g).

This letter contains no new NRC regulatory commitments.

If there are any questions, please contact David Woods at 706-848-6903.

Respectfully submitted,

  
Michael J. Yox  
Regulatory Affairs Director Vogtle 3&4

U.S. Nuclear Regulatory Commission  
ND-16-2193  
Page 2 of 4

Enclosure: Vogtle Electric Generating Plant (VEGP) Unit 3  
Completion Plan for Uncompleted ITAAC 2.1.02.12a.ii [Index Number 54]

MJY/kms/amm

**To:**

**Southern Nuclear Operating Company/Georgia Power Company**

Mr. S. E. Kuczynski (w/o enclosures)  
Mr. D. A. Bost (w/o enclosures)  
Mr. M. D. Meier  
Mr. M. D. Rauckhorst (w/o enclosures)  
Mr. D. H. Jones (w/o enclosures)  
Ms. K. D. Fili  
Mr. D. L. McKinney  
Mr. B. H. Whitley  
Mr. D. L. Fulton  
Mr. C. E. Morrow  
Mr. M. J. Yox  
Mr. D. Woods  
Ms. A. L. Pugh  
Ms. K. M. Stacy  
Mr. A. S. Parton  
Mr. W. A. Sparkman  
Mr. J. P. Redd  
Mr. D. R. Culver  
Mr. F. H. Willis  
Document Services RTYPE: VND.LI.L06  
File AR.01.02.06

cc:

**Nuclear Regulatory Commission**

Ms. C. Haney (w/o enclosures)  
Ms. A. Bradford (w/o enclosures)  
Ms. J. L. Dixon-Herrity (w/o enclosures)  
Ms. J. M. Heisserer  
Mr. C. J. Even  
Mr. C. P. Patel  
Mr. B. M. Baval  
Ms. R. C. Reyes  
Ms. M. A. Sutton  
Mr. M. E. Ernstes  
Mr. G. J. Khouri  
Mr. J. D. Fuller  
Mr. T. E. Chandler  
Ms. S. E. Temple  
Ms. P. Braxton  
Mr. T. C. Brimfield  
Mr. A. J. Lerch

**Oglethorpe Power Corporation**

Mr. M. W. Price  
Ms. K. T. Haynes  
Ms. A. Whaley

**Municipal Electric Authority of Georgia**

Mr. J. E. Fuller

Mr. S. M. Jackson

**Dalton Utilities**

Mr. D. Cope

**WECTEC**

Mr. C. A. Castell

**Westinghouse Electric Company, LLC**

Mr. R. Easterling (w/o enclosures)

Mr. J. W. Crenshaw (w/o enclosures)

Mr. L. Woodcock (w/o enclosures)

Mr. C. F. Landon

Mr. A. F. Dohse

Mr. M. Y. Shaqqo

Ms. S. DiTommaso

**Other**

Mr. J. E. Hesler, *Bechtel Power Corporation*

Ms. L. Matis, *Tetra Tech NUS, Inc.*

Dr. W. R. Jacobs, Jr., *Ph.D., GDS Associates, Inc.*

Mr. S. Roetger, *Georgia Public Service Commission*

Ms. S. W. Kernizan, *Georgia Public Service Commission*

Mr. K. C. Greene, *Troutman Sanders*

Mr. S. Blanton, *Balch Bingham*

U.S. Nuclear Regulatory Commission  
ND-16-2193 Enclosure  
Page 1 of 4

**Southern Nuclear Operating Company  
ND-16-2193  
Enclosure**

**Vogtle Electric Generating Plant (VEGP) Unit 3  
Completion Plan for Uncompleted ITAAC 2.1.02.12a.ii [Index Number 54]**

**Subject: Uncompleted ITAAC 2.1.02.12a.ii [Index No. 54]**

## **ITAAC Statement**

### **Design Commitment**

*12.a) The automatic depressurization valves identified in Table 2.1.2-1 perform an active safety-related function to change position as indicated in the table.*

### **Inspections/Tests/Analyses**

*ii) Inspection will be performed for the existence of a report verifying that the as-built motor-operated valves are bounded by the tests or type tests.*

### **Acceptance Criteria**

*ii) A report exists and concludes that the as-built motor-operated valves are bounded by the tests or type tests.*

## **ITAAC Completion Description**

Multiple ITAAC are performed to demonstrate that the automatic depressurization valves identified in VEGP Unit 3 Combined License (COL) Appendix C Table 2.1.2-1 (Attachment A) perform an active safety-related function to change position as indicated in the table. The subject ITAAC requires that an inspection is performed for the existence of a report verifying that the as-built motor-operated valves are bounded by the tests or type tests.

The motor-operated valves in VEGP Unit 3 COL Appendix C Table 2.1.2-1 are verified by the tests or type tests in accordance with ITAAC 2.1.02.12a.i (Reference 1) to demonstrate the capability of the valves to operate under their design conditions. Equipment Qualification Data Packages (EQDP) and Equipment Qualification Summary Reports (EQSR) identify the equipment mounting employed for the testing and the specific conditions tested.

In accordance with Equipment Qualification (EQ) Walkdown Inspection Procedure XYZ (Reference 2) an inspection is conducted of the Reactor Coolant System (RCS) to confirm the satisfactory installation of the motor-operated valves. The inspection includes verification of equipment make/model/serial number, verification of equipment mounting and location, and verification that the mechanical and electrical connections are bounded by the tested conditions.

The documentation of installed configuration of the motor-operated valves includes photographs and/or sketches of equipment mounting and connections. The verification of installed component configuration is documented in the EQ As-Built Reconciliation Report(s) (Reference 3).

Attachment A identifies the EQ As-Built Reconciliation Report(s) which verify that the installed configuration of the motor-operated valves identified in VEGP Unit 3 COL Appendix C Table

2.1.2-1 is bounded by the tests or type tests. The EQ As-Built Reconciliation Report(s) are available for NRC inspection as part of the ITAAC Completion Package (Reference 4).

### **List of ITAAC Findings**

In accordance with plant procedures for ITAAC completion, Southern Nuclear Operating Company (SNC) performed a review of all findings pertaining to the subject ITAAC and associated corrective actions. This review found there are no relevant ITAAC findings associated with this ITAAC.

### **References (available for NRC inspection)**

1. ND-XX-XXXX ITAAC Closure Notification on Completion of ITAAC 2.1.02.12a.i [Index No. 53]
2. EQ Walkdown Inspection Procedure XYZ
3. EQ As-Built Reconciliation Report(s) identified in Attachment A
4. ITAAC 2.1.02.12a.ii Completion Package
5. NEI 08-01, "Industry Guideline for the ITAAC Closure Process Under 10 CFR Part 52"

**Attachment A: Excerpt from COL Appendix C Table 2.1.2-1**

**MOTOR-OPERATED VALVES  
(REACTOR COOLANT SYSTEM)**

<b>Equipment Name</b>	<b>Tag No.</b>	<b>Active Function</b>	<b>EQ As-Built Reconciliation Report</b>
First-stage ADS Motor-operated Valve (MOV)	RCS-PL-V001A	Transfer Open	XXX
First-stage ADS MOV	RCS-PL-V001B	Transfer Open	XXX
Second-stage ADS MOV	RCS-PL-V002A	Transfer Open	XXX
Second-stage ADS MOV	RCS-PL-V002B	Transfer Open	XXX
Third-stage ADS MOV	RCS-PL-V003A	Transfer Open	XXX
Third-stage ADS MOV	RCS-PL-V003B	Transfer Open	XXX
First-stage ADS Isolation MOV	RCS-PL-V011A	Transfer Open	XXX
First-stage ADS Isolation MOV	RCS-PL-V011B	Transfer Open	XXX
Second-stage ADS Isolation MOV	RCS-PL-V012A	Transfer Open	XXX
Second-stage ADS Isolation MOV	RCS-PL-V012B	Transfer Open	XXX
Third-stage ADS Isolation MOV	RCS-PL-V013A	Transfer Open	XXX
Third-stage ADS Isolation MOV	RCS-PL-V013B	Transfer Open	XXX