

NRR-PMDAPem Resource

From: Hon, Andrew
Sent: Monday, November 14, 2016 11:22 AM
To: Turkal, Mark A
Cc: Murray, William R. (Bill) (Bill.Murray@duke-energy.com) (Bill.Murray@duke-energy.com)
Subject: Brunswick Unit 1 and Unit Request for Additional Information related to LAR to Relocate of Specific Surveillance Frequency Requirements to Licensee Controlled Program (CAC NOS. MF7206 and MF7207)

In a letter dated December 21, 2015, (Agencywide Documents Access and Management System (ADAMS) Accession Nos. ML16004A249), Duke Energy Progress (the licensee) requested the subject amendment to Operating Licenses OLs DPR-71 and DPR-62.

The U.S. Nuclear Regulatory Commission (NRC) staff is reviewing your submittal and has determined that additional information is required to complete the review. The specific information requested is addressed below:

SR 3.3.1.2.4 contains a two part frequency, "12 hours during CORE ALTERATIONS AND 24 hours" marked for replacement in its entirety with "In accordance with the Surveillance Frequency Control Program." The first part of the frequency, "12 hours during CORE ALTERATIONS," appears to meet one of the four exclusion criteria of part 2.0 of the approved TSTF-425, Revision 3 traveler as a "frequency that is related to a specific condition..." Please clearly explain why the exclusion does not apply and how the complete frequency will be addressed in the Surveillance Frequency Control Program.

The proposed questions were discussed by telephone with you on November 9, 2016. Your staff confirmed that request for additional information (RAI) was understood and did not include proprietary or security-related information, and agreed to provide a response in 10 business days of this request. The NRC staff considers that timely responses to RAIs help ensure sufficient time is available for staff review and contribute toward the NRC's goal of efficient and effective use of staff resources. Please note that if you do not respond to this request by the agreed-upon date or provide an acceptable alternate date, we may deny your application for amendment under the provisions of Title 10 of the *Code of Federal Regulations*, Section 2.108. If circumstances result in the need to revise the agreed upon response date, please contact me.

Docket Nos. 50-324 and 50-325

Distribution: Listserv, Brunswick Unit No.1 and 2

Andy Hon, PE

Project Manager (Brunswick Nuclear Plant 1 & 2, Sequoyah Nuclear Plant 1 & 2)

Plant Licensing Branch II-2

Division of Operating Reactor Licensing

Office of Nuclear Reactor Regulation

301-415-8480

OWFN O8H19

Mail Stop O8G-9a

andrew.hon@nrc.gov

Hearing Identifier: NRR_PMDA
Email Number: 3157

Mail Envelope Properties (Andrew.Hon@nrc.gov20161114112200)

Subject: Brunswick Unit 1 and Unit Request for Additional Information related to LAR to Relocate of Specific Surveillance Frequency Requirements to Licensee Controlled Program (CAC NOS. MF7206 and MF7207)

Sent Date: 11/14/2016 11:22:15 AM

Received Date: 11/14/2016 11:22:00 AM

From: Hon, Andrew

Created By: Andrew.Hon@nrc.gov

Recipients:

"Murray, William R. (Bill) (Bill.Murray@duke-energy.com) (Bill.Murray@duke-energy.com)"
<Bill.Murray@duke-energy.com>

Tracking Status: None

"Turkal, Mark A" <Mark.Turkal@duke-energy.com>

Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	2444	11/14/2016 11:22:00 AM

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received: