



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 2, 2016

Vice President, Operations
Arkansas Nuclear One
Entergy Operations, Inc.
1448 S.R. 333
Russellville, AR 72802

SUBJECT: ARKANSAS NUCLEAR ONE, UNITS 1 AND 2 – INTERIM STAFF RESPONSE
TO REEVALUATED FLOOD HAZARDS SUBMITTED IN RESPONSE TO
10 CFR 50.54(f) INFORMATION REQUEST – FLOOD-CAUSING MECHANISM
REEVALUATION (CAC NOS. MF8379 AND MF8380)

Dear Sir or Madam:

The purpose of this letter is to provide a summary of the U.S. Nuclear Regulatory Commission (NRC) staff's assessment of the reevaluated flood-causing mechanisms described in the September 14, 2016, flood hazard reevaluation report (FHRR) submitted by Entergy Operations, Inc. (Entergy, the licensee) for Arkansas Nuclear One, Units 1 and 2 (ANO) (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16260A060).

By letter dated March 12, 2012, the NRC issued a request for information pursuant to Title 10 of the *Code of Federal Regulations*, Section 50.54(f) (hereafter referred to as the 50.54(f) letter) (ADAMS Accession No. ML12053A340). The request was issued as part of implementing lessons learned from the accident at the Fukushima Dai-ichi nuclear power plant. Enclosure 2 to the 50.54(f) letter requested that licensees reevaluate flood-causing mechanisms using present-day methodologies and guidance. Concurrent with the reevaluation of flooding hazards, licensees were required to develop and implement mitigating strategies in accordance with NRC Order EA-12-049, "Requirements for Mitigation Strategies for Beyond-Design-Basis External Events" (ADAMS Accession No. ML12054A735). On March 30, 2015, the Commission provided staff requirements memorandum (SRM) (ADAMS Accession No. ML15089A236) to COMSECY-14-0037, "Integration of Mitigating Strategies for Beyond-Design-Basis External Events and the Reevaluation of Flooding Hazards," dated November 21, 2014 (ADAMS Accession No. ML14309A256), affirming that licensees need to address the reevaluated flooding hazards within their mitigating strategies for beyond-design-basis external events.

Enclosure 2 transmitted herewith contains Security-Related Information. When separated from the Enclosure, this document is decontrolled.

The NRC staff has reviewed the information submitted by the licensee and has summarized the results of the review in the tables provided as an enclosure to this letter. Table 1 provides the current design-basis flood hazard mechanisms. Table 2 provides the reevaluated flood hazard mechanisms; however, the reevaluated flood hazard mechanisms bounded by the current design-basis (Table 1) are not included. Because Table 1 includes security-related information, Enclosure 1 contains the redacted version of Table 1. Enclosure 2 is withheld from public disclosure and restores the security-related information to Table 1.

The NRC staff has concluded that the licensee's reevaluated flood hazard information, as summarized in the enclosure, is suitable for the assessment of mitigating strategies developed in response to Order EA-12-049 (i.e., defines the mitigating strategies flood hazard information described in Nuclear Energy Institute (NEI) guidance document NEI 12-06, "Diverse and Flexible Coping Strategies (FLEX) Implementation Guide") for ANO. Further, the NRC staff has concluded that the licensee's reevaluated flood hazard information is a suitable input for other assessments associated with Near-Term Task Force Recommendation 2.1, "Flooding." The NRC staff plans to issue a staff assessment documenting the basis for these conclusions at a later time.

Revision 2 of NEI 12-06 includes a methodology to perform a mitigating strategies assessment (MSA) with respect to the reevaluated flood hazards. On February 29, 2016, the NRC staff published Japan Lessons-Learned Division (JLD) Interim Staff Guidance (ISG) JLD-ISG-2012-01, Revision 1, "Compliance with Order EA-12-049, Order Modifying Licenses with Regard to Requirements for Mitigation Strategies for Beyond-Design-Basis External Events" (ADAMS Accession No. ML15357A142) in the *Federal Register* (81 FR 10283). This ISG endorses Revision 2 of NEI 12-06 (ADAMS Accession No. ML16005A625), dated December 2015. Based on the guidance provided in Revision 2 of NEI 12-06, flood event duration parameters and applicable flood associated effects should be considered as part of the ANO MSA. The NRC staff will evaluate the flood event duration parameters (including warning time and period of inundation) and flood-related associated effects developed by the licensee during the NRC staff's review of the MSA.

As stated above, Table 2 of the enclosure to this letter describes the reevaluated flood hazards that exceed the current design basis. In order to complete its response to the information requested by Enclosure 2 to the 50.54(f) letter, the licensee is expected to submit an integrated assessment or a focused evaluation, as appropriate, to address these reevaluated flood hazards, as described in the NRC letter, "Coordination of Request for Information Regarding Flooding Hazard Reevaluation and Mitigating Strategies for Beyond-Design-Basis External Events" (ADAMS Accession No. ML15174A257). This letter describes the changes in the NRC's approach to the flood hazard reevaluations that were approved by the Commission in its SRM to COMSECY-15-0019, "Closure Plan for the Reevaluation of Flooding Hazards for Operating Nuclear Power Plants" (ADAMS Accession No. ML15209A682).

- 3 -

If you have any questions, please contact me at (301) 415-22621 or e-mail at Robert.Bernardo@nrc.gov.

Sincerely,



Robert Bernardo, Project Manager
Hazards Management Branch
Japan Lessons-Learned Division
Office of Nuclear Reactor Regulation

Docket Nos. 50-313 and 50-368

Enclosures:

- 1) Summary of Results of Flooding
Hazard Re-Evaluation Report (Redacted Version)
- 2) Summary of Results of Flooding
Hazard Re-Evaluation Report (Non-Public Version)

cc w/encl: Distribution via Listserv

ENCLOSURE 1:

SUMMARY TABLES OF
REEVALUATED FLOOD HAZARD LEVELS-REDACTED VERSION

Table 1. Current Design Basis Flood Hazards for Use in the MSA

Mechanism	Stillwater Elevation	Waves/ Runup	Design Basis Hazard Elevation	Reference
Local Intense Precipitation	Not included in DB	Not included in DB	Not included in DB	FHRR Table 4-1
Streams and Rivers				
PMF on Arkansas River	358.0 ft, NGVD29	10.0 ft	368.0 ft, NGVD29	FHRR Table 4-1
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]
Failure of Dams and Onsite Water Control/Storage Structures	Not included in DB	Not included in DB	Not included in DB	FHRR Table 4-1
Storm Surge	Not included in DB	Not included in DB	Not included in DB	FHRR Table 4-1
Seiche	Not included in DB	Not included in DB	Not included in DB	FHRR Table 4-1
Tsunami	Not included in DB	Not included in DB	Not included in DB	FHRR Table 4-1
Ice-Induced Flooding	Not included in DB	Not included in DB	Not included in DB	FHRR Table 4-1

Table 1. Current Design Basis Flood Hazards for Use in the MSA

Mechanism	Stillwater Elevation	Waves/ Runup	Design Basis Hazard Elevation	Reference
Channel Migrations/Diversions	Not included in DB	Not included in DB	Not included in DB	FHRR Table 4-1

Note 1: Reported values are rounded to the nearest one-tenth of a foot.

Table 2. Reevaluated Flood Hazards for Flood-Causing Mechanisms for Use in the MSA

Mechanism	Stillwater Elevation	Waves/ Runup	Reevaluated Hazard Elevation	Reference
Local Intense Precipitation				
North Train Bay Door	354.4 ft, NGVD29	Minimal	354.4 ft, NGVD29	FHRR Table 4-2
South Train Bay Door	354.4 ft, NGVD29	Minimal	354.4 ft, NGVD29	FHRR Table 4-2
Between Warehouse and Reactor Building Unit 2	355.0 ft, NGVD29	Minimal	355.0 ft, NGVD29	FHRR Table 4-2
West of Maintenance Building	353.7 ft, NGVD29	Minimal	353.7 ft, NGVD29	FHRR Table 4-2
North of Turbine Building Unit 2	353.7 ft, NGVD29	Minimal	353.7 ft, NGVD29	FHRR Table 4-2
South of Turbine Building Unit 2	355.1 ft, NGVD29	Minimal	355.1 ft, NGVD29	FHRR Table 4-2
South of Central Support Building	354.0 ft, NGVD29	Minimal	354.0 ft, NGVD29	FHRR Table 4-2
North of Central Support Building	357.7 ft, NGVD29	Minimal	357.7 ft, NGVD29	FHRR Table 4-2
Northeast of Turbine Building Unit 2	354.4 ft, NGVD29	Minimal	354.4 ft, NGVD29	FHRR Table 4-2
Transformer Yard	354.4 ft, NGVD29	Minimal	354.4 ft, NGVD29	FHRR Table 4-2
East of Turbine Building Unit 1	354.3 ft, NGVD29	Minimal	354.3 ft, NGVD29	FHRR Table 4-2

Table 2. Reevaluated Flood Hazards for Flood-Causing Mechanisms for Use in the MSA

Mechanism	Stillwater Elevation	Waves/ Runup	Reevaluated Hazard Elevation	Reference
Northwest of Intake Structure	354.1 ft, NGVD29	Minimal	354.1 ft, NGVD29	FHRR Table 4-2
North of Intake Structure	354.2 ft, NGVD29	Minimal	354.2 ft, NGVD29	FHRR Table 4-2
North of ISFSI	356.3 ft, NGVD29	Minimal	356.3 ft, NGVD29	FHRR Table 4-2
South of ISFSI	355.6 ft, NGVD29	Minimal	355.6 ft, NGVD29	FHRR Table 4-2
East of Cooling Tower	351.4 ft, NGVD29	Minimal	351.4 ft, NGVD29	FHRR Table 4-2
West of Warehouse	351.2 ft, NGVD29	Minimal	351.2 ft, NGVD29	FHRR Table 4-2
South of Warehouse	351.4 ft, NGVD29	Minimal	351.4 ft, NGVD29	FHRR Table 4-2
West of Diesel Oil Storage Tank	354.5 ft, NGVD29	Minimal	354.5 ft, NGVD29	FHRR Table 4-2
West of Engineering/Modification Building	352.2 ft, NGVD29	Minimal	352.2 ft, NGVD29	FHRR Table 4-2
Between Engineering/Modification Building and Reactor Building 1	352.7 ft, NGVD29	Minimal	352.7 ft, NGVD29	FHRR Table 4-2
East of Diesel Fuel Storage Vault	353.7 ft, NGVD29	Minimal	353.7 ft, NGVD29	FHRR Table 4-2

Note 1: Reevaluated hazard mechanisms bounded by the current design basis (see Table 1) are not included in this table

Note 2: Reported values are rounded to the nearest one-tenth of a foot.

OFFICIAL USE ONLY – SECURITY RELATED INFORMATION

If you have any questions, please contact me at (301) 415-22621 or e-mail at Robert.Bernardo@nrc.gov.

Sincerely,

/RA/

Robert Bernardo, Project Manager
Hazards Management Branch
Japan Lessons-Learned Division
Office of Nuclear Reactor Regulation

Docket Nos. 50-313 and 50-368

Enclosures:

- 1) Summary of Results of Flooding
Hazard Re-Evaluation Report (Redacted Version)
- 2) Summary of Results of Flooding
Hazard Re-Evaluation Report (Non-Public Version)

cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC	JLD R/F	RidsNRRJLD Resource
RBernardo, NRR	LQuinn-Willingham, NRO	RidsNroDsea Resource
RidsNrrDorLpl4-2 Resource	RidsNrrDorL Resource	RidsNrrPMANO Resource
RidsRgn4MailCenter Resource	RidsNrrLASLent	RidsOgcMailCenter Resource
RidsOpaMail Resource	RidsAcraAcnw_MailCtr Resource	CCook, NRO
MBensi, NRO	KErwin, NRO	ACampbell, NRO
MWillingham, NRO	KSee, NRO	BHarvey, NRO
MShams, NRR	GBowman, NR	

**ADAMS Accession Nos.: PKG ML16327A482 LTR: ML16327A494 ENCL 1: ML16327A530 (PUBLIC)
ENCL 2 ML16327A503 (NON-PUBLIC)**

***via email**

OFFICE	NRR/JLD/JHMB/PM	NRR/JLD/LA	NRO/DSEA/RHM1/TR*
NAME	RBernardo	SLent	KSee*
DATE	11/22/2016	11/28/2016	11/15/2016
OFFICE	NRO/DSEA/RHM1/BC*	NRR/JLD/JHMB/BC	NRR/JLD/JHMB/PM
NAME	CCook	GBowman	RBernardo
DATE	11/15/2016	11/29/2016	12/2/2016

OFFICIAL AGENCY RECORD

~~OFFICIAL USE ONLY – SECURITY RELATED INFORMATION~~