



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
REGION III
2443 WARRENVILLE RD. SUITE 210
LISLE, IL 60532-4352

December 2, 2016

Mr. Charles Arnone
Vice President, Operations
Entergy Nuclear Operations, Inc.
Palisades Nuclear Plant
27780 Blue Star Memorial Highway
Covert, MI 49043-9530

**SUBJECT: PALISADES NUCLEAR PLANT—NRC TEMPORARY INSTRUCTION 2515/191,
MITIGATION STRATEGIES, SPENT FUEL POOL INSTRUMENTATION AND
EMERGENCY PREPAREDNESS INSPECTION REPORT 05000255/2016008**

Dear Mr. Arnone:

On November 16, 2016, the U.S. Nuclear Regulatory Commission (NRC) completed Temporary Instruction (TI) 2515/191, "Inspection of the Implementation of Mitigation Strategies and Spent Fuel Pool Instrumentation Orders and Emergency Preparedness Communication/Staffing/Multi-Unit Dose Assessment Plans" inspection at your Palisades Nuclear Plant. The NRC inspection team discussed the results of this inspection with Mr. M. Lee and other members of your staff. The enclosed report represents the results of this inspection.

The inspection examined activities conducted under your license as they relate to the implementation of mitigation strategies and spent fuel pool instrumentation orders (EA-12-049 and EA-12-051) and Emergency Preparedness Communication/Staffing/Multi-Unit Dose Assessment Plans, your compliance with the Commission's rules and regulations, and with the conditions of your operating license. Within these areas, the inspection involved examination of selected procedures and records, observation of activities, and interviews with station personnel.

The NRC inspectors did not identify any findings or violations of more than minor significance.

C. Arnone

-2-

In accordance with Title 10 of the *Code of Federal Regulations* (10 CFR) 2.390, "Public Inspections, Exemptions, Requests for Withholding," of the NRC's "Rules of Practice," a copy of this letter, its enclosure, and your response (if any) will be available electronically for public inspection in the NRC's Public Document Room or from the Publicly Available Records System (PARS) component of the NRC's Agencywide Documents Access and Management System (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA/

Ann Marie Stone, Team Leader
Technical Support Staff
Division of Reactor Projects

Docket No. 50-255
License No. DPR-20

Enclosure:
Inspection Report 05000255/2016008

cc: Distribution via LISTSERV®

U.S. NUCLEAR REGULATORY COMMISSION

REGION III

Docket No: 50-255
License No: DPR-20

Report No: 05000255/2016008

Licensee: Entergy Nuclear Operations, Inc.

Facility: Palisades Nuclear Plant

Location: Covert, MI

Dates: September 26 through November 16, 2016

Inspectors: J. Boettcher, Resident Inspector (Team Lead)
B. Bartlett, Project Engineer
J. Benjamin, Senior Reactor Inspector
S. Sheldon, Project Engineer

Approved by: A. Stone, Team Leader
Technical Support Staff
Division of Reactor Projects

Enclosure

SUMMARY

Inspection Report 05000255/2016008, 09/26/2016 – 09/30/2016, Palisades Nuclear Plant; Temporary Instruction 2515/191 Implementation of Mitigation Strategies and Spent Fuel Pool Instrumentation Orders and Emergency Preparedness Communication/Staffing/Multi-Unit Dose Assessment Plans.

This inspection was performed by a resident inspector and three U.S. Nuclear Regulatory Commission (NRC) regional inspectors. No findings of significance or violations of NRC requirements were identified during this inspection. The significance of inspection findings is indicated by their color (i.e., greater than Green, or Green, White, Yellow, Red) and determined using Inspection Manual Chapter 0609, "Significance Determination Process," dated April 29, 2015. Cross-cutting aspects are determined using Inspection Manual Chapter (IMC) 0310, "Aspects Within the Cross-Cutting Areas," dated December 4, 2014. The NRC's program for overseeing the safe operation of commercial nuclear power reactors is described in NUREG-1649, "Reactor Oversight Process," dated July 2016.

NRC-Identified and Self-Revealing Findings

None

REPORT DETAILS

4. OTHER ACTIVITIES

4OA5 Other Activities (Temporary Instruction 2515/191)

The objective of Temporary Instruction (TI) 2515/191, "Inspection of the Implementation of Mitigation Strategies and Spent Fuel Pool Instrumentation Orders and Emergency Preparedness Communication/Staffing/Multi-Unit Dose Assessment Plans," is to verify the licensee has adequately implemented the mitigation strategies as described in the licensee's Final Integrated Plan (Agencywide Documents Access Management System (ADAMS) Accession No. ML15351A351), the licensee's supplement to the notification of full compliance (ADAMS Accession No. ML16083A285), and the U.S. Nuclear Regulatory Commission's (NRC's) safety evaluation (ADAMS Accession No. ML16014A318) and to verify the licensee installed reliable water-level measurement instrumentation in their spent fuel pool (SFP). The purpose of this TI was also to verify the licensee had implemented Emergency Preparedness (EP) enhancements as described in their site-specific submittals and NRC safety assessments, including multi-unit dose assessment capability and enhancements to ensure staffing is sufficient and communications can be maintained during such an event.

The inspection also verifies plans for complying with NRC Orders EA-12-049, "Order Modifying Licenses with Regard to Requirements for Mitigation Strategies for Beyond-Design-Basis External Events" (ADAMS Accession No. ML12054A736) and EA-12-051, "Order Modifying Licenses With Regard to Reliable Spent Fuel Pool Instrumentation" (ADAMS Accession No. ML12054A679) are in place and are being implemented by the licensee. Additionally, the inspection verified implementation of staffing and communications information provided in response to the March 12, 2012, request for information letter and multiunit dose assessment information provided per COMSECY-13-0010, "Schedule and Plans for Tier 2 Order on Emergency Preparedness for Japan Lessons Learned," dated March 27, 2013, (ADAMS Accession No. ML12339A262).

The inspectors discussed the plans and strategies with plant staff, reviewed documentation, and where appropriate, performed plant walk downs to verify the strategies could be implemented as stated in the licensee's submittals and the NRC staff prepared safety evaluation. For most strategies, this included verification that the strategy was feasible, procedures and/or guidance had been developed, training had been provided to plant staff, and required equipment had been identified and staged. Specific details of the team's inspection activities are described in the following sections.

.1 Mitigation Strategies for Beyond-Design Basis External Events

a. Inspection Scope

The inspectors examined the licensee's established guidelines and implementing procedures for the beyond-design basis mitigation strategies. The inspectors assessed how the licensee coordinated and documented the interface/transition between existing off-normal and emergency operating procedures with the newly developed mitigation strategies. The inspectors selected a number of mitigation strategies and conducted plant walk downs with licensed operators and responsible plant staff to assess: the adequacy and completeness of the procedures; familiarity of operators with the

procedure objectives and specific guidance; staging and compatibility of equipment; and the practicality of the operator actions prescribed by the procedures, consistent with the postulated scenarios.

The inspectors verified a preventive maintenance program had been established for the Diverse and Flexible Coping Strategies (FLEX) portable equipment and periodic equipment inventories were in place and being conducted. Additionally, the inspectors examined the introductory and planned periodic/refreshers training provided to the Operations staff most likely to be tasked with implementation of the FLEX mitigation strategies. The inspectors also reviewed the introductory and planned periodic training provided to the Emergency Response Organization personnel. Documents reviewed are listed in the attachment.

b. Assessment

Based on samples selected for review, the inspectors verified the licensee satisfactorily implemented appropriate elements of the FLEX strategy as described in the plant specific submittal(s) and the associated safety evaluation and determined the licensee is generally in compliance with NRC Order EA-12-049. The inspectors verified the licensee satisfactorily:

- developed and issued FLEX Support Guidelines (FSG) to implement the FLEX strategies for postulated external events;
- integrated their FSGs into their existing plant procedures such that entry into and departure from the FSGs were clear when using existing plant procedures;
- protected FLEX equipment from site-specific hazards;
- developed and implemented adequate testing and maintenance of FLEX equipment to ensure their availability and capability;
- trained their staff to assure personnel proficiency in the mitigation of beyond-design basis events; and
- developed the means to ensure the necessary off-site FLEX equipment would be available from off-site locations.

The inspectors verified non-compliances with current licensing requirements, and other issues identified during the inspection were entered into the licensee's corrective action program as appropriate.

c. Findings

No findings were identified.

.2 Spent Fuel Pool Instrumentation

a. Inspection Scope

The inspectors examined the licensee's newly installed SFP instrumentation. Specifically, the inspectors verified the sensors were installed as described in the plant specific submittals and the associated safety evaluation and that the cabling for the power supplies and the indications for each channel were physically and electrically separated. Additionally, environmental conditions and accessibility of the instruments were evaluated. Documents reviewed are listed in the attachment.

b. Assessment

Based on samples selected for review, the inspectors determined the licensee satisfactorily installed and established control of the SFP instrumentation as described in the plant specific submittal(s) and the associated safety evaluation and determined the licensee is generally in compliance with NRC Order EA-12-051. The inspectors verified the licensee satisfactorily:

- installed the SFP instrumentation sensors, cabling and power supplies to provide physical and electrical separation as described in the plant specific submittal(s) and safety evaluation;
- installed the SFP instrumentation display in the location, environmental conditions and accessibility as described in the plant specific submittal(s); and
- trained their staff to assure personnel proficiency with the maintenance, testing, and use of the SFP instrumentation.

The inspectors verified non-compliances with current licensing requirements, and other issues identified during the inspection were entered into the licensee's corrective action program.

c. Findings

No findings were identified.

.3 Staffing and Communication Request for Information

a. Inspection Scope

Through discussions with plant staff, review of documentation and plant walk downs, the inspectors verified the licensee has implemented required changes to staffing, communications equipment and facilities to support a multi-unit extended loss of alternating current power (ELAP) scenario as described in the licensee's staffing assessment and the NRC safety assessment. The inspectors also verified the licensee has implemented multi-unit dose assessment (including releases from SFPs) capability using the licensee's site-specific dose assessment software and approach as described in the licensee's multi-unit dose assessment submittal. Documents reviewed are listed in the attachment.

b. Assessment

The inspectors reviewed information provided in the licensee's multi-unit dose submittal and in response to the NRC's March 12, 2012, request for information letter and verified that the licensee satisfactorily implemented enhancements pertaining to Near-Term Task Force Recommendation 9.3 response to a large scale natural emergency event that results in an extended loss of all alternating current power to all site units and impedes access to the site. The inspectors verified the following:

- the licensee satisfactorily implemented required staffing change(s) to support a multi-unit ELAP scenario;
- EP communications equipment and facilities are sufficient for dealing with a multi-unit ELAP scenario; and

- the licensee implemented multi-unit dose assessment capabilities (including releases from SFPs) using the licensee's site-specific dose assessment software and approach.

The inspectors verified non-compliances with current licensing requirements, and other issues identified during the inspection were entered into the licensee's corrective action program.

c. Findings

No findings were identified.

4OA6 Management Meeting

Exit Meeting Summary

On November 16, 2016, the inspectors presented the inspection results to Mr. M. Lee and other members of the licensee's staff. The licensee acknowledged the issues presented. The inspectors confirmed none of the potential report input discussed was considered proprietary.

ATTACHMENT: SUPPLEMENTAL INFORMATION

SUPPLEMENTAL INFORMATION

KEY POINTS OF CONTACT

Licensee

C. Arnone, Site Vice President
A. Williams, General Manager Plant Operations
T. Mulford, Operations Manager
B. Baker, Operations Manager – Shift
J. Borah, Engineering Manager, Systems and Components
T. Davis, Regulatory Assurance
B. Dotson, Regulatory Assurance
J. Erickson, Regulatory Assurance
O. Gustafson, Director of Regulatory and Performance Improvement
J. Hardy, Regulatory Assurance Manager
J. Haumersen, Site Projects and Maintenance Services Manager
G. Heisterman, Maintenance Manager
M. Lee, Operations Manager – Support
D. Lucy, Outage Manager
D. Malone, Emergency Planning Manager
W. Nelson, Training Manager
D. Nestle, Radiation Protection Manager
K. O'Connor, Engineering Manager, Design and Programs
C. Plachta, Nuclear Independent Oversight Manager
P. Russell, Site Engineering Director
M. Schultheis, Performance Improvement Manager
M. Soja, Chemistry Manager
J. Tharp, Security Manager

U.S. Nuclear Regulatory Commission

A. Stone, Team Leader, Technical Support Staff

LIST OF ITEMS OPENED, CLOSED, AND DISCUSSED

Opened

None

Closed

None

Discussed

None

LIST OF DOCUMENTS REVIEWED

The following is a partial list of documents reviewed during the inspection. Inclusion on this list does not imply the NRC inspector reviewed the documents in their entirety, but rather that selected sections or portions of the documents were evaluated as part of the overall inspection effort. Inclusion of a document on this list does not imply NRC acceptance of the document or any part of it, unless this is stated in the body of the inspection report.

Condition Reports Initiated as a Result of the Inspection

- CR-HQN-2016-01215, It Was Discovered that Two Copies of the Palisades FLEX FIP Exist, September 27, 2016
- CR-PLP-2016-04603, It Was Discovered that the Labels on Both the FLEX Diesel Generators are Incorrect, September 28, 2016
- CR-PLP-2016-04610, Walkdown Discovered that the Labels on the FLEX Diesel Generators are Incorrect, September 28, 2016
- CR-PLP-2016-04638, Flooding Level in A Flex Building Question, September 29, 2016
- CR-PLP-2016-04641, A Later Version of Staffing Assessment, Revision 2, was Discovered, September 29, 2016
- CR-PLP-2016-04643, NRC Identified, Incorrect Value to Fill Tank T-81, September 29, 2016
- CR-PLP-2016-04650, No Specific Operator Guidance for Flex Hose Minimum Bend Radius, September 29, 2016

Condition Reports Reviewed

- CR-HQN-2015-00345, Potential Concern with the Instrumentation for Spent Fuel Pool Level Monitoring, April 9, 2015
- CR-HQN-2016-00164, Fukushima Project: Uninterruptable Power Supply Rated Battery Life, February 9, 2016
- CR-PLP-2015-02436, Cables do not Appear to Connect to the Generator, June 11, 2015
- CR-PLP-2015-02482, Tracking of NRC FLEX/SFPI Audit Follow-up Items, June 16, 2015
- CR-PLP-2015-05627, Broken Weld on "A" FLEX Generator, November 11, 2015
- CR-PLP-2015-05750, Breaker 11 was Found in Trip Free Condition, November 19, 2015
- CR-PLP-2016-00127, LI-2141 Spent Fuel Level Indicator Blank Screen, January 7, 2016
- CR-PLP-2016-01079, Uninterruptable Power Supply Battery Life Error, March 2, 2016
- CR-PLP-2016-01224, The Rating of the Generators in the FIP are Wrong, March 10, 2016
- CR-PLP-2016-01364, K-2 FLEX Diesel Generator Fuel Oil Level Low, March 19, 2016
- CR-PLP-2016-01655, LI-2141 Spent Fuel Level Indicator Blank Screen, April 5, 2016
- CR-PLP-2016-01740, Trend with LI-2141 Spent Fuel Level Indicator Blank Screen, April 12, 2016
- CR-PLP-2016-01902, LI-2141 Spent Fuel Level Indicator Time Incorrect, April 21, 2016
- CR-PLP-2016-02248, K-1 FLEX Diesel Generator Trailer Wiring Harness is Damaged, May 14, 2016
- CR-PLP-2016-02451, Satellite Phone Cords Failed, May 26, 2016
- CR-PLP-2016-02985, LI-2141 Spent Fuel Level Indicator Blank Screen, June 29, 2016
- CR-PLP-2016-03992, LI-2141 Spent Fuel Level Indicator Time Incorrect, August 25, 2016
- CR-PLP-2016-04564, NSRCs Declared Degraded but Operational due to the Inability of Two or More 4160VAC Portable Generators to Perform Load Sharing, September 26, 2016

Calculations

- EA-GOTHIC-AFW-01, Auxiliary Feedwater Pump Room Heat Up Analysis, Revision 0
- EA-EC46465-08, Freezing of Coolant Sources for FLEX Event, Revision 0
- EA-EC46465-14, T-2 Inventory Makeup Capability of AFW with T-81 Gravity Feed, Revision 0
- EA-EC46467-04, Sliding and Rocking Evaluation of FLEX Storage Building-A Equipment, Revision 1

Drawings

- B213781, 2500 kVA Transformer Outline Drawing for Graybar, Revision 0
- E-1 Sh. A, Single Line Meter and Relay Diagram, Revision 12
- E-44 Sh. 156, Lighting Panel Schedule Panel L-76, Revision 7
- E-44 Sh. 105, Lighting Panel Schedule Panel L-258, Revision 6

Miscellaneous Documents

- Enercon Report, Flex Portable Hose Failure Extent of Condition Review
- Letter of Agreement Between Entergy Nuclear Operations, Inc., as Agent for Entergy Nuclear Palisades, LLC, Owner of Palisades Nuclear Power Plant and Andrews University Airport Authority, September 15, 2014
- Letter to the NRC from Anthony J. Vitale, Response to NRC Request for Information Pursuant to 10 CFR 50.54(f) Regarding Recommendation 9.3, Emergency Preparedness – Staffing, Requested Information Items 1, 2, and 6 – Phase 2 Staffing Assessment, May 19, 2015
- Letter to the NRC from Anthony J. Vitale, Notification of Full Compliance with NRC Order EA-12-049, “Order Modifying Licenses with Regard to Requirements for Mitigation Strategies for Beyond-Design-Basis External Events,” December 16, 2015
- Letter to the NRC from Anthony J. Vitale, Notification of Full Compliance with NRC Order EA-12-049, “Order Modifying Licenses with Regard to Requirements for Mitigation Strategies for Beyond-Design-Basis External Events,” December 16, 2015
- Letter to Vice President, Operations at Entergy Nuclear Operations, Inc. from Mandy Halter, NRC/NRR, Palisades Nuclear Plant – Safety Evaluation Regarding Implementation of Mitigating Strategies and Reliable Spent Fuel Instrumentation Related to Orders EA–12–049 and EA–12–051 (CAC Nos. MF0768 and MF0769), August 22, 2016
- LO-HWNLO-2015-0001, Phase 2 Communications Assessment Fukushima Project, April 19, 2016
- M0204-0161, MOHR Vendor Manual SFPI Level Indication, Revision 0
- Memorandum of Understanding Between West Michigan Airport Authority and Entergy Nuclear Operations, Inc., as Agent for Entergy Nuclear Palisades, LLC, Owner of Palisades Nuclear Power Plant, September 15, 2014
- MSP/EMHSD Response Procedure #22 b, Emergency Operation Center Extended Loss AC Power Response Plan, August 2015
- Mutual Assistance Agreement Between DTE Energy Electric Company, Entergy Nuclear Palisades, LLC and Indiana Michigan Power
- PLP-RPT-13-00050, Turbine Driven Auxiliary Feedwater (TDAFW) Upgrade Evaluation for FLEX, Revision 0
- PLP-RPT-14-00030, Report of Geotechnical Exploration FLEX Equipment Storage Building, Revision 0
- PLP-RPT-15-00049, Palisades Final Integrated Plan for FLEX Implementation, Revision 0
- PLP-RPT-15-00049, Palisades Final Integrated Plan for FLEX Implementation, Revision 1
- Palisades Nuclear Plant FLEX Validation, September 28, 2015

- Palisades Nuclear Plant IPEEE, Revision 1
- Palisades Nuclear Plant NEI 12-01 / Phase 2 Staffing Assessment, Revision 1
- Palisades Nuclear Plant NEI 12-01 / Phase 2 Staffing Assessment, Revision 2
- SAFER Response Plan for Palisades Nuclear Plant, Revision 1
- Snapshot Assessment: Pre-NRC Fukushima Lessons Learned, Une 21, 2016
- WCAP-17601-P, Reactor Coolant System Response to the Extended Loss of AC Power Event for Westinghouse, Combustion Engineering, and Babcock & Wilcox NSSS Designs, Revision 0

Modifications

- EC 46465, FLEX Basis (Base/Parent EC), Revision 0
- EC 46466, Spent Fuel Pool Instrumentation, Revision 0
- EC 46467, Storage Buildings, Revision 0
- EC 47490, EP Communications, Revision 0
- EC 63992, Capacity of Turbine Building Uninterruptable Power Supply, Revision 0
- EC 66731, FLEX Hose Bend Radius Evaluation, Revision 0

Procedures

- AOP-26, Loss of Spent Fuel Pool Cooling, Revision 3
- AOP-30, Loss of Shutdown Cooling, Revision 2
- AOP-38, Acts of Nature, Revision 6
- ARP-7, Auxiliary Systems Scheme EK-11 (C-13), Revision 96
- EI-6.0, Palisades Nuclear Plant Emergency Implementing Procedure Rapid Dose Calculation, Revision 16
- EI-6.9, Palisades Nuclear Plant Emergency Implementing Procedure Automated Dose Assessment Program, Revision 8
- EN-OP-201, Diverse and Flexible Coping Strategies (FLEX) Fleet Program Document, Revision 2
- EN-OP-201-05, Palisades FLEX Program Document, Revision 1
- EN-OP-202, Diverse and Flexible Coping Strategies (FLEX) Program Document Bases, Revision 0
- EN-OU-103, Long Range Outage Planning, Revision 3
- EN-WM-105, Planning, Revision 16
- EN-WM-109, Scheduling, Revision 10
- EOP-1.0, Standard Post-Trip Actions, Revision 18
- EOP-2.0, Reactor Trip Recovery, Revision 14
- EOP-3.0, Station Blackout Recovery, Revision 17
- EOP 8.0, Loss of Offsite PWR – Forced Circulation Recovery, Revision 19
- EOP 9.0, PC-2 PCS Press Control PORVS PC-2 Tree D, Revision 19
- FIG-1, FLEX Generator Staging and Operation, Revision 1
- FIG-2, FLEX Pump Staging and Operations, Revision 0
- FIG-3, Alternate SFP Makeup and Cooling, Revision 0
- FIG-4, Low Pressure Feedwater, Revision 0
- FIG-5, FLEX T-77 Boration Blending, Revision 0
- FIG-7, FLEX PCS Injection, Revision 0
- FIG-8, Alternate Ventilation, Revision 0
- FIG-9, Backup ADV Nitrogen Station 9 Operation, Revision 0
- FIG-10, Fuel Oil Transfer, Revision 0
- FIG-11, Service Water – NSRC (Phase 3), Revision 0

- FIG-12, 4160 VAC Generator – NSRC (Phase 3), Revision 2
- FSG-1, Long Term Inventory Control, Revision 0
- FSG-4, ELAP DC Bus Load Shed and Management, Revision 0
- FSG-5, Initial Assessment and FLEX Equipment Staging, Revision 0
- FSG-5, Initial Assessment and FLEX Equipment Staging – Attachment 4, Ops Flowchart, Revision 0
- FSG-7, Loss of Vital Instrument or Control Power, Revision 1
- FSG-8, Alternate PCS Boration, Revision 0
- FSG-11, Alternate SFP Makeup and Cooling, Revision 0
- FSG-13, Transition from Flex Equipment, Revision 0
- FSG-14, Shutdown PCS Makeup, Revision 0
- FSG-15, Shutdown ELAP, Revision 0
- FSG-100, Beyond Design Bases External Event (BDBEE) with an Extended Loss of Offsite and Onsite Power (ELAP) Emergency Response, Revision 0
- FSG-101, BDBEE / EP Communications, Revision 1
- SOP-2A, Chemical and Volume Control System, Revision 86
- SOP-14, Service Water System, Revision 65
- Spent Fuel Pool Level Instrumentation (SFPI) Boric Acid Mitigation, January 14, 2014
- Spent Fuel Pool Level Instrumentation (SFPI) Channel Functional Check, January 14, 2014

Training Documents

- PLLP-NLO Training, FLEX Loader, Revision 0
- PLLP-OPS-FLEXOVER, FLEX Process & Equipment, Training Cycle 15B
- PLLP-OPS-15D-01, Palisades Operations Cycle 15D Kickoff
- PLLP-OPS-FLEXGAP, FLEX Process & Equipment, Cycle 15E GAP Training

Work Orders

- 00374145 04, FUK, EC-47345, BUS 19 Voltage & Phase Rotation Checks, October 4, 2015
- 00374147 04, FUK, EC-47345, BUS 20 Voltage & Phase Rotation Checks, September 29, 2015
- 00378594 16, FUK, (FLEX EC-46465) Verification of FLEX Pumps/Equip, August 26, 2015
- 00378594 17, FUK, (FLEX EC-46465) Verification of PH 2 Generator/Equip, August 27, 2015
- 00424932 01, FLEX Standby Periodic Maintenance (PM) - 6 Month Inspection - FEL-FLEX1B, April 19, 2016
- 00424934 01, FLEX Standby PM - 6 Month Functional - K-4-FLEX Generator, March 19, 2016
- 00424939 01, FLEX Standby PM - 6 Month Inspection - Tow Vehicle A, April 19, 2016
- 00424941 01, FLEX Standby PM - 6 Month Functional - C-910 Air Comp, April 19, 2016
- 52676484 01, FLEX Standby PM - 1 Yr Operational Test - P-1002 Pump (FSB B), April 19, 2016
- 52676487 01, FLEX Standby PM - 1 Yr Operational Test - K-1-FLEX Generator, April 19, 2016
- 52676489 01, FLEX Standby PM - 1 Yr Operational Test - K-2-FLEX Generator, April 19, 2016
- 52709100 01, Emergency Communications Test, Monthly, August 31, 2016

LIST OF ACRONYMS USED

ADAMS	Agencywide Documents Access Management System
CFR	Code of Federal Regulations
ELAP	Extended Loss of AC Power
EP	Emergency Preparedness
FLEX	Diverse and Flexible Coping Strategies
FSG	FLEX Support Guidelines
IMC	Inspection Manual Chapter
NRC	U.S. Nuclear Regulatory Commission
PARS	Publicly Available Records System
PM	Periodic Maintenance
SFP	Spent Fuel Pool
TI	Temporary Instruction

C. Arnone

-2-

In accordance with Title 10 of the *Code of Federal Regulations* (10 CFR) 2.390, "Public Inspections, Exemptions, Requests for Withholding," of the NRC's "Rules of Practice," a copy of this letter, its enclosure, and your response (if any) will be available electronically for public inspection in the NRC's Public Document Room or from the Publicly Available Records System (PARS) component of the NRC's Agencywide Documents Access and Management System (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA/

Ann Marie Stone, Team Leader
Technical Support Staff
Division of Reactor Projects

Docket No. 50-255
License No. DPR-20

Enclosure:
Inspection Report 05000255/2016008

cc: Distribution via LISTSERV®

DISTRIBUTION:

Jeremy Bowen
RidsNrrPMPalisades Resource
RidsNrrDorLp3-1 Resource
RidsNrrDirslrib Resource
Cynthia Pederson
Darrell Roberts
Richard Skokowski

Allan Barker
Carole Ariano
Linda Linn
DRPIII
DRSIII
ROPreports.Resource@nrc.gov
JLD_Regional.Resources@nrc.gov

ADAMS Accession Number: ML16337A098

☒ Publicly Available ☐ Non-Publicly Available ☐ Sensitive ☒ Non-Sensitive

OFFICE	RIII	RIII			
NAME	AStone for JBoettcher:tt	AStone			
DATE	12/02/2016	12/02/2016			

OFFICIAL RECORD COPY