

Part 21 (PAR)

Event # 52394

Rep Org: ENERCON		Notification Date / Time: 11/23/2016 11:56 (EST)	
Supplier: ENERCON		Event Date / Time: 09/28/2016 (EST)	
		Last Modification: 11/23/2016	
Region: 1	Docket #:		
City: KENNESAW	Agreement State: Yes		
County:	License #:		
State: GA			
NRC Notified by: NICK EGGEMEYER		Notifications: JAMES DWYER	R1DO
HQ Ops Officer: MARK ABRAMOVITZ		AARON McCRAW	R3DO
Emergency Class: NON EMERGENCY		PART 21/50.55 REACTORS	EMAIL
10 CFR Section:			
21.21(a)(2) INTERIM EVAL OF DEVIATION			

PART-21 NOTIFICATION - DESIGN BASIS ERRORS USING FLO-2D SOFTWARE

The following report was received via e-mail:

"This letter serves as an Interim Report in accordance with 10 CFR 21.21 pertaining to a potential defect associated with a design basis calculation delivered to First Energy Nuclear Operating Company's Perry Nuclear Power Plant. Subsequent to delivering this calculation, FLO-2D software errors were identified which resulted in erroneous outputs that affect the local intense precipitation calculation. These errors were discovered on September 28, 2016, at which time, ENERCON generated a Corrective Action Report (CAR) to address the issue. ENERCON has initiated a reevaluation of the calculation using the latest version of the software that will correct the errors in the calculation.

"An evaluation of the reportability of this issue in accordance with 10 CFR Part 21 is not able to be completed within the 60-day evaluation period due the need to verify and validate the latest version of the software and then complete all the analysis required for updating the calculation. This evaluation is being tracked by CAR 2016-0335 and will be completed no later than February 10, 2017.

"If you have any questions or need further clarifying information, please contact Nick Eggemeyer, Corporate Quality Assurance Manager, at (770) 590-2031."

IE19
NRK

Hoc, HOO X

From: Nick Eggemeyer <neggemeyer@enercon.com>
Sent: Wednesday, November 23, 2016 11:56 AM
To: Hoc, HOO X
Subject: [External_Sender] 10 CFR Part 21 Interim Report
Attachments: 10CFR Part 21 Interim Report - Perry Nuclear Plant Calculation Error.pdf

To: NRC Operations Center

Attached find a 10 CFR Part 21 Interim Report regarding a design basis calculation error using FLO-2D software.

Please acknowledge receipt of this email.

Best regards,

Nick Eggemeyer

Corporate Quality Assurance Manager
500 TownPark Lane
Kennesaw, GA 30144
Office: 770.590.2031
Cell: 678.800.3630



Please consider the environment before printing this e-mail



ENERCON

Excellence—Every project. Every day.

Timothy P. Cleary
Vice President
500 TownPark Lane
Kennesaw, GA 30144
678-354-8359 Office
910-547-2800 Mobile

November 23, 2016

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

SUBJECT: 10 CFR 21 Interim Report Regarding Design Basis Calculation Error Using
FLO-2D Software

This letter serves as an Interim Report in accordance with 10 CFR 21.21 pertaining to a potential defect associated with a design basis calculation delivered to First Energy Nuclear Operating Company's Perry Nuclear Power Plant. Subsequent to delivering this calculation, FLO-2D software errors were identified which resulted in erroneous outputs that affect the local intense precipitation calculation. These errors were discovered on September 28, 2016, at which time ENERCON generated a Corrective Action Report (CAR) to address the issue. ENERCON has initiated a reevaluation of the calculation using the latest version of the software that will correct the errors in the calculation.

An evaluation of the reportability of this issue in accordance with 10 CFR Part 21 is not able to be completed within the 60-day evaluation period due the need to verify and validate the latest version of the software and then complete all the analysis required for updating the calculation. This evaluation is being tracked by CAR 2016-0335 and will be completed no later than February 10, 2017.

If you have any questions or need further clarifying information, please contact Nick Eggemeyer, Corporate Quality Assurance Manager, at (770) 590-2031.

Respectfully,

Timothy P. Cleary
Vice President

Cc: John D. Richardson, President
Robert H. Bryan, Chief Operating Officer
Jim J. Gannon, Chief Nuclear Officer
Nick C. Eggemeyer, Corporate QA Manager