

**From:** Wanda D Craft (Generation - 6) <wanda.d.craft@dom.com>  
**Sent:** Thursday, January 19, 2017 4:09 PM  
**To:** Guzman, Richard  
**Subject:** [External\_Sender] Summary of Jan. 18, 2017 Discussion with Dominion, AREVA and the NRC on MPS2 RLBLOCA

**Categories:** Action

**Dominion**

Dana Knee  
Lauren Lopez  
Dave Bajumpaa  
Brian Mount  
Brian Vitiello  
Gabby Westerlind  
Jeff Langan  
Craig sly  
Wanda Craft

**AREVA**

Elisa Calvo Tone  
Andrei Burghilea  
Jerry Holm  
Rick Williamson

**NRC**

Josh Borromeo  
Rich Guzman

On May 25, 2016, Dominion Nuclear Connecticut (DNC) submitted a license amendment request (LAR) for Millstone Power Station Unit 2 (MPS2) that proposed to add the AREVA topical report EMF-2103(P)(A), "Realistic Large Break Loss of Coolant Accident (RLBLOCA) Methodology for Pressurized Water Reactors" to Technical Specification 6.9.1.8.b, Core Operating Limits Report," which lists the analytical methods used to determine the core operating limits. The LAR is in NRC review.

On January 18, 2017, DNC notified the NRC by telecon that AREVA had identified a minor error in the MPS2 RLBLOCA analysis. This email is a summary of the teleconference where preliminary information was shared with the NRC staff.

EMF-2103(P)(A), Revision 3, page A-32, provides proprietary guidance on the treatment of the form loss coefficient in the hot leg internal junctions. It was discovered that the MPS2 model deviates from the guidance. The specific deviation and the scope of error evaluation to determine the impact were explained to the NRC staff on January 18. The preliminary estimated effect is 0°F on the proposed analysis of record peak cladding temperature of 1615°F that was documented in the LAR dated May 25, 2016.

After formal evaluation by AREVA in accordance with their quality assurance program and notification to MPS2, DNC will follow the process for reporting errors and changes to ECCS Evaluation Models per the requirements of 10 CFR 50.46(a)(3)(iii).

Wanda D. Craft  
Nuclear Regulatory Affairs  
Dominion Resources Services, Inc  
(804) 273-4687  
tie-line 730-4687

---

**CONFIDENTIALITY NOTICE:** This electronic message contains information which may be legally confidential and or privileged and does not in any case represent a firm ENERGY COMMODITY bid or offer relating thereto which binds the sender without an additional express written confirmation to that effect. The information is intended solely for the individual or entity named above and access by anyone else is unauthorized. If you are not the intended recipient, any disclosure, copying, distribution, or use of the contents of this information is prohibited and may be unlawful. If you have received this electronic transmission in error, please reply immediately to the sender that you have received the message in error, and delete it. Thank you.