



Luminant

Thomas P. McCool
Site Vice President
Thomas.McCool@Luminant.com

Luminant Power
P O Box 1002
6322 North FM 56
Glen Rose, TX 76043

T 254 897 6042
C 817 776 0308
F 254 897 6652

CP-201700084
TXX-17009

Ref: 10 CFR 50.54(f)

January 26, 2017

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Director, Office of Nuclear Reactor Regulation
Washington, DC 20555-0001

SUBJECT: Comanche Peak Nuclear Power Plant (CPNPP)
Units 1 and 2, Docket Nos. 50-445 and 50-446, 72-74
Mitigating Strategies Assessment (MSA) Report for the New Seismic Hazard Information
NEI 12-06, Appendix H, Revision 2, H.4.1 Path 1: GMRS \leq SSE

REFERENCES:

1. Nuclear Energy Institute (NEI) guidance, NEI 12-06, Revision 2, "Diverse and Flexible Coping Strategies (FLEX) Implementation Guide, December 2015 (ML 16005A625)
2. U.S. Nuclear Regulatory Commission (NRC), JLD-ISG-2012-01, Revision 1, "Compliance with Order EA-12-049, Order Modifying Licenses with Regard to Requirements for Mitigating Strategies for Beyond-Design-Basis External Events", January 22, 2016 (ML 15357A163)
3. Luminant Letter logged TXX-14037 from R. Flores to the NRC dated March 27, 2014, Seismic Hazard and Screening Report (CEUS Sites), Response to NRC Request for Information Pursuant to 10 CFR 50.54(f) Regarding Recommendation 2.1 (ML14099A197)
4. NRC Letter from F. Vega to Rafael Flores (Luminant) dated January 22, 2016, "Comanche Peak Nuclear Power Plant, Units 1 and 2 - Staff Assessment of Information Provided Pursuant to Title 10 of the Code of Federal Regulations Part 50, Section 50.54(f), Seismic Hazard Reevaluations For Recommendation 2.1 Of the Near-Term Task Force Review Of Insights From The Fukushima Dai-Ichi Accident And Staff Closure Of Activities Associated With Recommendation 2.1, "Seismic" (CAC NOS. MF3937 and MF3938)" (ML16014A125)

Dear Sir or Madam:

The purpose of this letter is to provide the results of the assessment by Vistra Operations Company LLC ("Vistra OpCo") for Comanche Peak Nuclear Power Plant Units 1 and 2 (CPNPP) to determine if the FLEX strategies developed, implemented and maintained in accordance with NRC Order EA-12-049 can be implemented considering the impacts of the reevaluated seismic hazard. The assessment was performed in accordance with the guidance provided in Appendix H of NEI 12-06, Revision 2 (Reference 1) which was endorsed by the NRC (Reference 2).

A151
NMSS26
NRR
NMSS

The Mitigating Strategies Seismic Hazard Information (MSSHI) is CPNPP's reevaluated seismic hazard information developed using Probabilistic Seismic Hazard Analysis (PSHA). The MSSHI includes a performance-based Ground Motion Response Spectrum (GMRS), Uniform Hazard Response Spectra (UHRS) at various annual probabilities of exceedance, and a family of seismic hazard curves at various frequencies and fractiles developed at the CPNPP control point elevation. Vistra OpCo submitted the reevaluated seismic hazard information including the UHRS, GMRS and the hazard curves to the NRC on March 27, 2014 (Reference 3). The NRC staff concluded that the GMRS that was submitted adequately characterizes the reevaluated seismic hazard for the CPNPP site (Reference 4).

Consistent with H.4.1 of Reference 1, the CPNPP GMRS is bounded by the Safe Shutdown Earthquake (SSE) spectrum at frequencies 1 Hz and greater. The FLEX strategies were developed in consideration of the Current Licensing Basis SSE. Therefore, the FLEX strategies for CPNPP can be implemented as designed and no further seismic evaluations are necessary as noted in the NRC Staff Closure letter for CPNPP (Reference 4).

This letter contains no new regulatory commitments and no revision to existing regulatory commitments.


If you have any questions regarding this submittal, please contact Carl B. Corbin at (254) 897-0121 or carl.corbin@luminant.com.

I state under penalty of perjury that the foregoing is true and correct.

Executed on January 26, 2017.

Sincerely,

Vistra Operations Company LLC



Thomas E. McCool
Site Vice President

c -

Kriss Kennedy, Region IV
Gregory T. Bowman, NRR
Margaret M. Watford, NRR
Resident Inspectors, Comanche Peak