
REVISED RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION**APR1400 Design Certification****Korea Electric Power Corporation / Korea Hydro & Nuclear Power Co., LTD****Docket No. 52-046**

RAI No.: 433-8363

SRP Section: 19 – Probabilistic Risk Assessment and Severe Accident Evaluation
Section: 19

Application Section: 19

Date of RAI Issue: 03/08/2016

Question No. 19-70

10 CFR 50.44(c)(5) and SECY-93-087 require a deterministic analysis that demonstrates containment structural integrity under internal pressure loads. Regulatory Guide 1.216, Regulatory Position 3 discusses the methods acceptable to the staff to address the Commission's performance goal related to the prevention and mitigation of severe accidents. The use of the Factored Load Category (FLC) for concrete containments is acceptable to demonstrate the deterministic performance goal for the first 24 hours.

APR1400 design control document (DCD) Tier 2, Section 19.2.4, "Containment Performance Capability," does not provide a description of the finite element models of the containment. The staff reviewed the information contained in the DCD, and in supporting calculations 1-316-C304-006 "Containment Building Capacity Evaluation on Severe Accident (Global) and 1-316-C304-007 "Containment Building Capacity Evaluation on Severe Accident (Local)". The staff identified information that needs to be clarified and explained in the DCD to complete its evaluation. This information includes modeling details, description of computer codes, material properties and material modeling, loading and loading sequences, failure modes, and interpretation or results. The staff requests the applicant provide reference to the Severe Accident Report in the appropriate section of the DCD. In accordance with Regulatory Position 3 of RG 1.216, the applicant is requested to address the following at a level of detail consistent with 10 CFR 50.47 and include this information in the DCD:

1. A description of the global and local nonlinear finite element models. Include a description of computer codes. The description should discuss how the large penetrations were treated in the models. The discussion should also include the treatment of smaller penetrations and penetration closure components.
2. The accident temperature associated with the severe accidents conditions. The staff requests the applicant provide a basis for assuming the accident temperature. Additionally, provide an explanation of how accident temperatures were considered in

selecting the material properties in the analysis, specifically for concrete strength. Calculation 1-316-C304-006 describes the effects of temperatures on the material properties for concrete, steel reinforcement, pre-stressing tendons, and the steel liner that should be included in the DCD.

3. A description of the material modeling for the concrete containment in the DCD. These properties are currently described in calculation 1-316-C304-006 and include the stress-strain relationship used for steel corresponding to the accident temperature, the stress-strain relationship used for concrete corresponding to the accident temperature, and any other material properties important to the model.
4. An adequate technical justification for all simplifications and the applicability to the particular containment design and loading condition. Simplifications include assumptions made based upon the use of test results. The staff notes that test results are presented in Appendix E of the Severe Accident Report, and requests that these be incorporated into the DCD. As an example, address the appropriateness of a static analysis and whether dynamic response effects are important.
5. A description of the analysis results.

Response – (Rev. 3)

1. The three-dimensional finite element (FE) model for safety evaluation on severe accident is developed based on the design results (rebar arrangement) from structural analysis of the concrete containment. The FE code ABAQUS is used for the nonlinear analysis of the containment structure. The full FE model includes the entire prestressed concrete containment structure which consists of the concrete wall and dome, liner plate, rebars, and tendons. The solid and shell elements are used for concrete and liner plate, respectively, and the rebars and tendons were modeled as truss elements. In addition, the large, operating-type penetrations such as equipment hatch, personnel airlock, and main steam penetration are considered in the full FE model, but the electrical penetration assemblies and valve penetrations were excluded. With regard to the nonlinear finite element model, it will be reflected in DCD section 19.2.4.2.2 as shown in the Attachment.
2. As addressed in Calculation note “Containment Performance Analysis”, 1-035-N389-501, Rev.04, the accident temperature during the severe accident in viewpoint of Position 3 of RG 1.216 is determined by the following process:
 - Selection of more likely accident sequences: Based on the core damage frequency ranking from PRA Level 1 study, the top ten sequences are selected. Also a number of typical sequences which are important in deterministic approach are added in the calculation matrix, as listed in Table 2-1, page 6 of 1-035-N389-501, Rev. 4.
 - Evaluation of the plant response by using MAAP code: For the selected sequences the plant response are evaluated by using MAAP code. The pressure and temperature transient are determined in each case.

The maximum temperature during a severe accident is 350 °F and the degradation of material properties at this temperature is conservatively applied thru all analysis phases. The material degradation corresponding to the temperature is based on NUREC/CR-6906. In NUREC/CR-6906, the strength ratio of concrete and steel strength is as follows.

For concrete strength ratio, $S_{Rc} = \exp -(T/632)^{1.8}$ where T is in degrees °C.

For steel yield strength ratio, $S_{Rs} = \exp -((T-300)/300)^{1.9}$ where T is in degrees °C. If T is less than 340 °C, $S_{Rs} = 1.0$

Based on the NUREC/CR-6906, the compressive strength of concrete is 5,400 psi and 4,500 psi at 350 °F for containment external wall and basemat, respectively. For reference, the design compressive strength of concrete is 6,000 psi and 5,000 psi for containment external wall and basemat, respectively. In addition, for the reinforcing steel and prestressing tendon, the yield strength ratio is 1.0 because the severe accident temperature is less than 340 °C. The material degradation of liner steel (SA-516 Gr. 60) is based on the ASME Section II-D, the yield strength and tensile strength of liner steel are 27.9 ksi and 60 ksi at 350 °F, respectively. For reference, the design yield strength and tensile strength of liner steel are 32 ksi and 60 ksi, respectively. With regard to the material degradation corresponding to severe accident temperature, it will be reflected in DCD section 19.2.4.2.2 as shown in the Attachment.

3. Material nonlinear models for steel and concrete are constructed on the basis of the design code and a few references. For simulating the cracking behavior of concrete, the smeared crack model is adopted. The steel is assumed to be a linear elasto-plastic model. The stress-strain curves for the reinforcing steel and tendons are based on the ASME code-specified minimum yield strengths. An elastic-plastic and a piece-wise linear stress-strain relationship above yield stress is used for the reinforcing steel and tendons. As mention in Q.19-70 (2), the degradation of concrete and steel material properties corresponding to the maximum temperature during severe accident is conservatively applied thru all analysis phases. With regard to the material nonlinear models, it will be reflected in DCD section 19.2.4.2.2 as shown in the Attachment.
4. The sequences analyzed covered the most likely severe accident initiators for APR1400. The top ten sequences from the Level 1 PRA study as well as the representative deterministic sequences are covered. Dominant contribution of

containment pressurization in terms of Regulatory Position 3 is the generation of massive steam and non-condensable gases during the severe accident. These gas and steam production phenomenon increase the containment pressure gradually as presented in Figure 19.2.3-21 of the DCD. Therefore static analysis against the severe accident load is applicable to the containment response. DCD section 19.2.4.2.2 will be revised as shown in the Attachment.

5. In all severe accident scenarios, the liner plate does not reach the limit strain of KEPIC SNB-3720 which is same to ASME CC-3720. In addition, the crack penetration of concrete of containment does not occur and the rebar and tendon keep elastic status. With regard to the analysis results, it will be reflected in DCD section 19.2.4.2.2 as shown in the Attachment.

Impact on DCD

DCD section 19.2.4.2.2 will be revised, as indicated in the Attachment.

Impact on PRA

There is no impact on the PRA.

Impact on Technical Specifications

There is no impact on the Technical Specifications.

Impact on Technical/Topical/Environmental Reports

There is no impact on any Technical, Topical, or Environmental Report.

the complete reaction of 100 percent of the active fuel cladding with steam. Also, the hydrogen mitigation features are assumed to be unavailable. The hydrogen was then assumed to be burned completely with no heat transfer to heat sinks in the containment with initial containment atmospheric pressure at the highest value possible that would still allow for hydrogen to burn. The maximum pressure load on the containment structure is evaluated to be 7.0 kg/cm^2 (99.8 psia) under the AICC condition. Considering the safety margin of APR1400 containment, for the FLC, the pressure resulting from 100 percent metal water reaction of fuel cladding and resulting from uncontrolled hydrogen burning is determined as 8.7 kg/cm^2 (123.7 psia).

Replace this text with the text "A" in the next page.

19.2.4.2.2 Containment Pressurization Results

Figure 19.2.3-21 shows the containment pressure response for a large-break LOCA that results in the highest containment pressure at 24 hours following the onset of core damage. For this scenario, the containment pressure does not reach 8.7 kg/cm^2 (123.7 psia) for 24 hours after the onset of core damage.

19.2.4.2.3 Emergency Containment Spray Backup System Performance

For a provision against a beyond-design-basis accident where either two SC pumps and two CS pumps or the IRWST is unavailable, the ECSBS is provided as an alternative to the CSS.

The ECSBS is designed to protect the containment integrity against overpressure and prevent the uncontrollable release of radioactive materials into the environment. The emergency containment spray flow path is from external water sources (the reactor makeup water tank, demineralized water storage tank, fresh water tank, or the raw water tank), through the fire protection system line via the diesel-driven fire pump, to the ECSBS line emergency connection located at ground level near the auxiliary building.

The ECSBS flow rate provides sufficient heat removal to prevent containment pressure from exceeding 8.7 kg/cm^2 (123.7 psia). In order to evaluate the performance of ECSBS, analysis is performed using the MAAP code.

Sequences are analyzed assuming that ECSBS operation began 24 hours after the onset of core damage. Figure 19.2.3-21 shows the containment pressure response following the

A

Regarding the Regulatory Guide 1.216, Regulatory Position 3, accident sequences to be analyzed are selected in combination of top ten dominant sequences from Level 1 PRA study and deterministic sequences. In accordance with the design of APR1400, Cavity Flooding System (CFS) and ECSBS were included in the sequences. Among the selected sequences a large-break LOCA resulted in the highest pressure in containment at 24 hours following the onset of core damage. The peak pressure and temperature is [] and [], respectively, as shown in Figure 19.2.3-21. The massive generation of the steam and non-condensable gases during the severe accident has dominant contribution on the gradual and increment of pressure and temperature. The bounding pressure and temperature profile is then employed in the static finite element study of the containment. For the selected more likely accident sequences the highest peak pressure does not reach the severe accident load for FLC, [], for 24 hours after the onset of core damage.

Under these conditions, the loadings should not produce strains in the containment liner plate in excess of the limits established in ASME Code, Section III, Division 2, Subarticle CC-3720. Allowable strains for factored loads considering membrane only are 0.005 in compression and 0.003 in tension. Allowable strains for factored loads considering membrane and bending are 0.014 in compression and 0.010 in tension.

The three-dimensional finite element (FE) model for safety evaluation under severe accident is constructed based on the design results (rebar arrangements) of the structure. The FE code ABAQUS is used for the nonlinear analysis of the containment structure. The full FE model includes the entire prestressed concrete containment structure which consists of the concrete wall and dome, liner plate, rebars, and tendons. The solid and shell elements are used for concrete and liner plate, respectively, and the rebars and tendons were modeled as truss elements. In addition, the large, operating-type penetrations such as equipment hatch, personnel airlock, and main steam penetration are considered in the full FE model. Material nonlinear models for steel and concrete are constructed on the basis of the design code and a few references. For simulating the cracking behavior of concrete, the smeared crack model is adopted and tension stiffening effect is also taken into consideration. The stress-strain curves for the reinforcing steel and tendons are based on the ASME code-specified minimum yield strengths. An elastic-plastic and a piece-wise linear stress-strain relationship above yield stress is used for the reinforcing steel and tendons. The maximum temperature during severe accident is [] and the degradation of material properties at this temperature is conservatively applied thru all of analysis phases.

Based on the results of the analyses, the crack penetration of concrete of containment does not occur, and all of the tendons and rebars are still in the elastic stage. At the LLOCA scenario, the maximum strain of liner plate considering at the cylindrical wall base, mid-height wall, and penetration regions is [] and [] for compression and tension, respectively. At the LOFW scenario, the maximum strain of liner plate considering at the cylindrical wall base, mid-height wall, and penetration regions is [] and [] for compression and tension, respectively. At the SBO scenario, the maximum strain of liner plate considering at the cylindrical wall base, mid-height wall, and penetration regions is [] and [] for compression and tension, respectively. In all severe accident scenarios, the liner plate does not reach the allowable limit strain values of membrane only load and combined membrane and bending load.

Replace text 'A' with 'B' in the next page

B

RAI 433-8363 - Question 19-70_Rev.2

RAI 433-8363 - Question 19-70_Rev.3

Based on RG 1.216 Regulatory Position 3.1 a, selection of accident sequences based on a Level 1 probabilistic risk assessment (PRA) study is made. The more likely severe accident sequences to be analyzed for the containment performance are selected using a combination of deterministic and probabilistic approaches. The represented sequences which can account for more than 90 % of the cumulative core damage frequency (CDF) are selected from the Level 1 PRA results. In addition to the probabilistic approach, deterministic sequences based on dominant accident initiators such as station blackout (SBO), large break LOCA (LBLOCA), small break LOCA (SBLOCA), total loss of feedwater (TLOFW), and steam generator tube rupture (SGTR) are constructed in order to achieve a conservative accident progression.

and

Regarding RG 1.216 Regulatory Position 3.1 b, the selected sequences are analyzed with cavity flooding system (CFS) and emergency containment spray backup system (ECSBS) availability by using MAAP computer code. The bounding pressures and temperatures profile are then employed in the static finite element study of the containment. For the selected more likely accident sequences the highest peak pressure (110.9 psia) shown in Figure 19.2.3-21 does not reach the severe accident load for FLC, 8.7 kg/cm² (123.7 psia), for 24 hours after the onset of core damage.

With regard to RG 1.216 Regulatory Position 3.1 c, the three-dimensional finite element (FE) model for safety evaluation under severe accident is constructed based on the design results (rebar arrangements) of the structure. The finite element models of the containment uses the similar approach described in DCD Section 3.8.1.4.11 and 3.8.1.4.12. As the limitations described in RG 1.216 Regulatory Position 3.1 c, all of the material properties, based on the enveloped temperature which covers the expected accident temperatures for each severe accident scenario, is conservatively used. The full FE model includes the entire prestressed concrete containment structure which consists of the concrete wall and dome, liner plate, rebars, and tendons. The solid and shell elements are used for concrete and liner plate, respectively, and the rebars and tendons were modeled as truss elements. Also, the large, operating-type penetrations such as equipment hatch, personnel airlock, and main steam penetration are considered in the full FE model. An event which can cause the dynamic pressure transient inside the containment, such as the global hydrogen burning due to flame acceleration and deflagration-to-detonation transition is not expected during the severe accidents. Therefore, the dynamic effects are not included in calculating the response of containment. FE study using ABAQUS code predicts the maximum strain of liner plate considering at the cylindrical wall base, mid-height wall, and penetration regions is -9.128E-4 and 8.428E-4 for compression and tension, respectively at LLOCA scenario. At the LOFW scenario, the maximum strain of liner plate considering at the cylindrical wall base, mid-height wall, and penetration regions is -9.128E-4 and 7.051E-4 for compression and tension, respectively. At the SBO scenario, the maximum strain of liner plate considering at the cylindrical wall base, mid-height wall, and penetration regions is -9.128E-4 and 6.680E-4 for compression and tension, respectively. Based on the results of the analyses, the crack penetration of concrete of containment does not occur, and all of the tendons and rebars are still in the elastic stage. Allowable strains established in ASME Code, Section III, Division 2, Subarticle CC-3720 for factored loads considering membrane only are 0.005 in compression and 0.003 in tension. Allowable strains for factored loads considering membrane and bending are 0.014 in compression and 0.010 in tension. Based on the results of the analyses, during the severe accident sequences, the liner plate strains at the cylindrical wall base, mid-height wall, and penetration regions do not reach the allowable limit strain values of membrane only load and combined membrane and bending load.

The pressures and temperatures that occur after the initial 24 hours of the onset of core damage are enveloped by the maximum pressure and temperature, which occur during the initial 24-hour period. Therefore, the containment is capable of providing a barrier against the uncontrolled release of fission products for the more likely severe accident challenges, in accordance with RG 1.216 Regulatory Position 3.2 a.