



PRC
APERTURE
CARD

LIMIT SWITCH DEVELOPMENT				
	33	DMR POSN		FUNCTION
		FULL OPEN	FULL CLOSE	
1	A-I-B			SP
2	C-I-D			GRN LT
3	E-I-F			SP
4	G-I-H			SP
5	A-I-B			RED LT
6	C-I-D			SP
7	E-I-F			SP
8	G-I-H			SP

- NOTES:
1. ALL EQUIPMENT LOCATED AS NOTED.
 2. O-ASSOCIATED DAMPER OPENS WHEN SOV IS DE-ENERGIZED.
 3. C-ASSOCIATED DAMPER CLOSES WHEN SOV IS DE-ENERGIZED.
 4. LOGIC DIAG.- LSK-22-8F

NUCLEAR SAFETY RELATED
QA CAT I, II

AC ELEM DIAG-120 VAC MISC CKTS
YARD STRUCTURE VENTILATION
NINE MILE POINT NUCLEAR STATION-UNIT 2
NIAGARA MOHAWK POWER CORPORATION
STONE & WEBSTER ENGINEERING CORPORATION

12177-ESK-7HVY03

DESIGN CONTROL	DESIGN CONTROL	DESIGN CONTROL	DESIGN CONTROL	DESIGN CONTROL
ISSUE 2	ISSUE 2	ISSUE 2	ISSUE 2	ISSUE 2
6-4-92	6-4-92	6-4-92	6-4-92	6-4-92
FCN-003	FCN-003	FCN-003	FCN-003	FCN-003
JRM	JRM	JRM	JRM	JRM