

PRC APERTURE CARD

D

G. Boghosian
M. Schildroth
J. Dacanay
J. Schauf
A. Gross
E. Hubner
J. Carey

STONE & WEBSTER ENGINEERING CORPORATION
NINE MILE POINT NUCLEAR STATION - UNIT 2
NIAGARA MOHAWK POWER CORPORATION
J. O. 12177

MANUFACTURER'S DRAWING DATA FORM

✓ INSTRUCTIONS TO SUPPLIER (E2)
✓ COMMENTS AS NOTED
APPROVED
APPROVED AS REVISED
RELEASED FOR FABRICATION
RELEASED FOR MATERIAL PURCHASE
SUPPLIER TO RESUBMIT: REVISED PRINTS; REVISED MICROFILM APERTURE CARDS; FOR REVIEW; FOR RECORD; NONE REQUIRED
NOTES:

NAME: RESP. ENG. J. CAREY (E1); RESP. DES. ENG. B. RUSSELL (E1)

✓ INSTRUCTIONS TO DESIGN (E1)
I-O INFORMATION ONLY
P-L PRELIMINARY LAYOUT
P-S PRODUCTION STUDIES
✓ R&C REVIEW AND COMMENT
F-D FINAL DETAILS
NEW NEW
✓ REV. REVISED

DATE TO DESIGN (C) 1-9-81
REQUIRED RETURN DATE (E1)

(E1) ✓ FOR INFORMATION ONLY
RETURN TO SUPPLIER NOT REQUIRED

DESIGN ENGINEER'S DATE STAMP (D) IN: NOTED JAN 12 1981 C.A. LANE

INSTRUCTIONS TO DESIGN (CIRCLE) (E1): I-O P-L P-S R&C F-D NEW REV

DESIGN ENGINEER'S DATE STAMP (D) OUT: NOTED JAN 16 1981 C.A. LANE

INITIALS OF SELECTED REVIEWERS: See Sepia

RESPONSIBLE ENGINEER'S DATE STAMP (E2): NOTED APR 13 1981 J.O. CAREY

DESIGN GROUP ROUTING (D)

ROUTE ✓		REQUIRED PRINT	REQUIRED MAC	RVW *
	ARCHITECTURE			
	CIVIL			
	CONCRETE			
	STEEL			
	BUILDING SERVICE			
	INSTRUMENT			
	MECHANICAL			
	PIPE SUPPORT			
	STRESS			
	MACHINE DESIGN/VESSEL			
	ELECTRICAL			
	LIGHTING			
	MODEL SHOP			
	EXTENSION OFFICE			
	CONTROL			

NOTES: JAN 12 1981 C.A. LANE

3 SUPERSEDES S&W FILE NO. (E1) (25-34) (35-38): 0007 2120 01 036 A
REMARKS (C) (LIMIT TO 22 CHARACTERS & BLANKS) (53-74): T-1076 7.212-001-064A

2 S&W EQUIP. I.D. CODE (E1) (25-38): NSS
AREA DESIGNATION CODES (E1) (75-80): 0

MFR'S. DWG. NO. (C) (LIMIT TO 24 CHARACTERS & BLANKS) (37-80): 80T6152TY REV3
MFR'S. NAME (C) (LIMIT TO 20 CHARACTERS & BLANKS) (61-80): GENERAL ELECTRIC

1 DATE REC'D (C): 01 MONTH 07 DAY 81 (YR-29-30) DWG TYPE (E1): C (31) MAX DAYS IN DESIGN (E1): 21 (32-33)

FUNCTIONAL TITLE (E1) (LIMIT TO 44 CHARACTERS & BLANKS) (37-80): ELEM DIAG NUC STEAM SUPPLY SHUTOFF SYS SH 2 REF 8

DUP: S&W FILE NO. (E1) (11-20) (21-24): 0007 2120 01 036 B
JOB ORDER NO. 12177 00 (14-10)

(C) PROJECT CLERK
(D) RESP. DESIGN ENGINEER
(E1) RESP. ENGINEER - ON DWG RECEIPT
(E2) RESP. ENGINEER - AFTER DWG REVIEW
MAC - MICROFILM APERTURE CARD
* RVW - REVIEWER INITIALS

ATTACH TO MFR'S. DRAWING