



G. Boyghosian  
M. Schildroth  
J. Dacanay  
J. Schauf  
A. Gross  
E. Hubner  
J. Carey

PRC  
APERTURE  
CARD

VALVES MUST BE FULLY OPEN  
BEFORE RWCU PUMP STARTS.  
LIMIT SWITCH CONTACT 2  
SHOULD BE USED INSTEAD  
OF LIMIT SWITCH CONTACT 6.

D

ATTACH TO M