

50-220

## NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO:  
Mr. George LearFROM:  
Niagara Mohawk Power Corp.  
Syracuse, New York.  
Gerald K. RhodeDATE OF DOCUMENT  
5/2/77DATE RECEIVED  
5/5/77☒ LETTER  
☒ ORIGINAL  
☐ COPY  
☐ NOTORIZED  
☒ UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

15162ED

## DESCRIPTION

## ENCLOSURE

Ltr. furnishing info. regarding the Unit  
No. 1 Containment Integrated leakage Rate  
Testing Program....

DO NOT REMOVE

(1-P)

## PLANT NAME:

Nine Mile Point Unit No. 1

RJL

ACKNOWLEDGED

## SAFETY

## FOR ACTION/INFORMATION

## ENVIRO

ASSIGNED AD:		ASSIGNED AD:
BRANCH CHIEF:	Lear (S)	BRANCH CHIEF:
PROJECT MANAGER:	Nowicki	PROJECT MANAGER:
LIC. ASST. :	Parrish	LIC. ASST. :

## INTERNAL DISTRIBUTION

REG FILE	SYSTEMS SAFETY	PLANT SYSTEMS	SITE SAFETY & ENVIRONMENT
NRC PDR	HEINEMAN	TEDESCO	ENVIRO ANALYSTS
I & E (2)	SCHROEDER	BENAROYA	DENTON & MULLER
OELD		LAINAS	
GOSSICK & STAFF	ENGINEERING	IPPOLITO	ENVIRO TECH.
MIPC	MACARRY	KIRKWOOD	ERNST
CASE	BOSNAK		BALLARD
HANAUER	SIHWFIL	OPERATING REACTORS	SPANGLER
HARLESS	PAWLICKI	STELLO	
			SITE TECH.
PROJECT MANAGEMENT	REACTOR SAFETY	OPERATING TECH.	GAMMILL
BOYD	ROSS	EISENHUT	STEPP
P. COLLINS	NOVAK	SHAO	HULMAN
HOUSTON	ROSZTOCZY	BAER	
PETERSON	CHECK	BUTLER	SITE ANALYSIS
MELTZ		GRIMES	VOLLMER
HELTEMES	AT & I		BUNCH
SKOVHOLT	SALTZMAN		J. COLLINS
	RUTBERG		KREGER

## EXTERNAL DISTRIBUTION

## CONTROL NUMBER

LPDR: Oswego, NY	NAT. LAB:	BROOKHAVEN NAT. LAB.
TIC:	REG V. IE	ULRIKSON (ORNL)
NSIC:	LA PDR	
ASLB:	CONSULTANTS:	
ACRS 16 CYS HOLDING/SENT	AS CAT B	

771260226



NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

300 ERIE BOULEVARD WEST  
SYRACUSE, N.Y. 13202

May 2, 1977

Director of Nuclear Reactor Regulation  
Attention: Mr. George Lear, Chief  
Operating Reactors  
Branch #3

U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555



**REGULATORY DOCKET FILE COPY**

Re: Nine Mile Point Unit 1  
Docket No. 50-220  
DPR-63


Gentlemen:

During an April 5, 1977 meeting with members of your staff, the Nine Mile Point Unit 1 Containment Integrated Leakage Rate Testing Program was discussed. Your staff requested specific clarifying information concerning the 1975 Containment Test.

During the subject test, preliminary examination of the data indicated that leakage was exceeding the acceptance criteria. Upon inspection, it was found that tube leaks existed in two of the containment spray heat exchangers. The leaking tubes were plugged and a successful retest was made.

In order to prevent this occurrence from happening again, local testing of the containment spray heat exchangers will be performed at least once each operating cycle. As indicated in our letter of March 2, 1977, the next containment integrated leak rate test will be performed during the Fall 1978 refueling outage.

Very truly yours,  
NIAGARA MOHAWK POWER CORPORATION

  
Gerald K. Rhode  
Vice President - Engineering

CVM/sjz

771260226

RECEIVED DOCUMENT  
PROCESSING UNIT

1971 MAY 5 AM 11 50