

FEB 23 1978

Distribution:

NRC PDR (1) R. DeYoung I. Peltier  
 Local PDR (8) D. Vassallo E. Hylton  
 ✓ Docket File (8) F. Williams R. Mattson  
 LWR-1 File J. Stolz D. Ross  
 R. Boyd  
 General Electric Company  
 ATTN: Dr. G. G. Sherwood, Manager  
 Safety and Security  
 175 Curtner Avenue  
 San Jose, California 95114

J. Knight  
 R. Tedesco  
 H. Denton  
 V. Moore  
 R. Vollmer  
 M. Ernst  
 W. Gammill  
 ELD

bcc:  
 J. Buchanan, NSIC  
 T. Abernathy, TIC  
 ACRS- (16)

50-410

SUBJECT: MARK II CONTAINMENTS - REQUEST FOR ADDITIONAL INFORMATION

Gentlemen:

As a result of our on going review of your report, NEDM-20988, "Caorso Relief Valve Loads Tests - Test Plan," we have the following comments and significant areas of concern.

1. Effects of leaking SRV on quencher loads has been identified as an area of concern. The Caorso test plan, however, has not addressed this concern. It is our position that tests on leaking SRV should be conducted and that a test matrix addressing this concern should be provided for our review.
2. The test matrix shows that the parameters of interest will be repeated only once. We believe that this is not sufficient to demonstrate the repeatability of test data. We, therefore, suggest that additional tests be conducted to demonstrate repeatability.

It should be noted that our review to date has not considered fluid/structure interaction effects.

Enclosed is a request for additional information. We believe you were advised of this needed information in July 1977.

Sincerely,

Original Signed by  
 John F. Stolz

John F. Stolz, Chief  
 Light Water Reactors Branch No. 1  
 Division of Project Management

Enclosure:  
 As stated

cc: See following pages

OFFICE➤	LWR-1	LWR-1	DSS	DSS	DSS	
SURNAME➤	IPeltier	JStolz	CAnderson	Glaivas	RTedesco	
DATE➤	2/17/78	2/22/78	2/21/78	2/21/78	2/21/78	

837 53 837

[illegible][illegible]

1. The first step in the process of the investigation is the identification of the problem. This is done by the investigator who is assigned to the case. The investigator will then gather information about the problem and the people involved. This information will be used to develop a plan of action.

1. 1994年12月25日，在“九七”香港回归前夕，香港各界人士纷纷发表文章，就香港回归后的前途问题提出自己的看法。其中，有的文章认为，香港回归后，香港将失去原有的自由、民主、人权等自由港的地位，而将被纳入中国的政治体制，成为中国的普通省份。

[illegible]

1. A.  $\frac{1}{2}$  B.  $\frac{1}{3}$  C.  $\frac{1}{4}$  D.  $\frac{1}{5}$  E.  $\frac{1}{6}$

John F. Zola  
Original Signed by

2010

FEB 23 1978

Niagra Mohawk Power Corporation  
ATTN: Mr. Jerald K. Rhode  
Vice President Engineering  
300 Erie Boulevard West  
Syracuse New York 13202

Eugene B. Thomas, Jr.  
LeBoeuf, Lamb, Leiby & MacRae  
1757 N Street, N. W.  
Washington, D. C. 20036

Anthony Z. Roisman, Esq.  
Roisman, Kessler & Cashdan  
1025 15th Street, N. W.  
Washington, D. C. 20036

Mr. Richard Goldsmith  
Syracuse University  
College of Law  
E. I. White Hall Campus  
Syracuse, New York 13210

T. K. DeBoer, Director  
Technological Development Programs  
New York State Energy Office  
Swan Street Building  
Core 1 - 2nd Floor  
Empire State Plaza  
Albany, New York 12223



FEB 23 1978

Washington Public Power Supply System  
ATTN: Mr. Kneil O. Strand  
Managing Director  
3000 George Washington Way  
Richland Washington 99352

Joseph B. Knotts, Jr., Esq.  
Debevoise & Liberman  
700 Shoreham Building  
806 Fifteenth Street, N. W.  
Washington, D. C. 20005

Richard Q. Quigley, Esq.  
Washington Public Power Supply System  
P. O. Box 968  
Richland, Washington 99352



• •  
• •

FEB 23 1978

Pennsylvania Power and Light Company  
ATTN: Mr. Norman W. Curtis  
Vice President - Engineering  
and Construction  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Mr. Earle M. Mead  
Project Manager  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Gerald Charnoff, Esq.  
Shaw, Pittman, Potts, Trowbridge  
& Madden  
1800 M Street, N. W.  
Washington, D. C. 20036

Mr. William E. Barberich  
Licensing Engineer  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Mr. Robert J. Shovlin, Project  
Manager  
Susquehanna  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Hubert Barnes, Esq.  
Pennsylvania Power & Light Company  
901 Hamilton Street  
Allentown, Pennsylvania 18101

Edward M. Nagel, Esquire  
General Counsel and Secretary  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101



• •  
• •

•

•



FEB 23 1978

Commonwealth Edison Company  
ATTN: Mr. Byron Lee, Jr.  
Vice President  
P. O. Box 767  
Chicago, Illinois 60690

Richard E. Powell, Esq.  
Isham, Lincoln & Beale  
One First National Plaza  
2400  
Chicago, Illinois 60670



1  
2  
3  
4

FEB 23 1978

Northern Indiana Public Service Company  
ATTN: Mr. H. P. Lyle, Vice President  
Electric Production & Engineering  
5265 Holman Ave..  
Hammond, Indiana 46325

Meredith Hemphill, Jr. Esq.  
Assistant General Counsel  
Bethlehem Steel Corporation  
Martin Tower  
Bethlehem, Pennsylvania 18016

William H. Eichhorn, Esq.  
Eichhorn, Morrow & Eichhorn  
5243 Hohman Avenue  
Hammond, Indiana 46320

Edward W. Osann, Jr., Esq.  
Wolfe, Hubbard, Leydid, Voit & Osann, Ltd.  
Suite 4600  
One IBM Plaza  
Chicago, Illinois 60611

Marvin N. Benn, Esq.  
Special Assistant Attorney General  
134 North LaSalle Street  
Suite 2222  
Chicago, Illinois 60602

Robert J. Vollen, Esq.  
109 North Dearborn Street  
Chicago, Illinois 60602



• •  
• •

FEB 23 1978

The Cincinnati Gas & Electric Company  
ATTN: Mr. Earl A. Borgmann  
Vice President - Engineering  
P. O. Box 960  
Cincinnati, Ohio 45201

Mr. William J. Moran  
General Counsel  
The Cincinnati Gas & Electric Co.  
P. O. Box 960  
Cincinnati, Ohio 45201

Mr. William G. Porter, Jr.  
Porter, Stanley, Arthur, & Platt  
37 West Broad Street  
Columbus, Ohio 43215

Mr. Robert Killen, Chairman of the  
Board & Chief Executive Officer  
The Dayton Power & Light Company  
P. O. Box 1034  
Dayton, Ohio 45401

Mr. J. Robert Newlin, Counsel  
The Dayton Power & Light Company  
P. O. Box 1034  
Dayton, Ohio 45401

Mr. Stephen Schumacher  
Miami Valley Power Project  
P. O. Box 252  
Dayton, Ohio 45401

Ms. Augusta Price  
601 Stanley Avenue  
Cincinnati, Ohio 45226

Mr. James D. Flynn  
Manager, Licensing & Environmental Affairs  
The Cincinnati Gas & Electric Company  
P. O. Box 960  
Cincinnati, Ohio 45201

Mr. J. P. Fenstermaker  
Senior Vice President - Operations  
Columbus & Southern Ohio Electric Co.  
215 North Front Street  
Columbus, Ohio 43215

David B. Fankhauser, PhD  
3569 Nine Mile Road  
Cincinnati, Ohio 45230

Thomas A. Luebbers, Esq.  
Cincinnati City Solicitor  
Room 214 - City Hall  
Cincinnati, Ohio 45202

Troy B. Conner, Esq.  
Conner, Moore & Cober  
1747 Pennsylvania Ave. N. W.  
Washington, D. C. 20006



FEB 23 1978

Philadelphi Electric Company  
ATTN: Mr. Edward G. Bauer, Jr.  
Vice President and General  
Counsel  
2301 Market Street  
Philadelphia, Pennsylvania 19101

Eugene J. Bradley  
Philadelphia Electric Company  
Associate General Counsel  
2301 Market Street  
Philadelphia, Pennsylvania 19101

Troy B. Conner, Jr. Esq.  
Conner, Moore & Corber  
1747 Pennsylvania Avenue, N. W.  
Washington, D. C. 20006

W. William Anderson, Esq.  
Deputy Attorney General  
Room 512, Main Capitol Building  
Harrisburg, Pennsylvania 17120

Frank R. Clokey, Esq.  
Special Assistant Attorney General  
Room 218, Towne House Apartments  
P. O. Box 2063  
Harrisburg, Pennsylvania 17105

Honorable Lawrence Coughlin  
House of Representatives  
Congress of the United States  
Washington, D. C. 20515

Roger B. Reynolds, Jr., Esq.  
324 Swede Street  
Norristown, Pennsylvania 19401

Willard C. Hetzel, Esq.  
312 main Street  
East Greenville, Pennsylvania 18041

Lawrence Sager, Esq.  
Sager & Sager Associates  
45 High Street  
Pottstown, Pennsylvania 19464

Joseph A. Smyth  
Assistant County Solicitor  
County of Montgomery  
Courthouse  
Norristown, Pennsylvania 19404



.

.

.

.



FEB 23 1978

Long Island Lighting Company  
ATTN: Mr. Andrew W. Wofford  
Vice President  
175 East Old Country Road  
Hicksville, New York 11801

Edward M. Barrett, Esq.  
General Counsel  
Long Island Lighting Company  
250 Old Country Road  
Mineola, New York 11501

Edward J. Walsh, Esq.  
General Attorney  
Long Island Lighting Company  
250 Old Country Road  
Mineola, New York 11501

Mr. Thomas Burke  
Project Manager  
Shoreham Nuclear Power Station  
P. O. Box 618  
Wading River, New York 11792

Director, Technical Development Programs  
State of New York Energy Office  
Agency Building 2  
Empire State Plaza  
Albany, New York 12223

Haward L. Blau  
Blau and Cohn, P. C.  
380 North Broadway  
Jericho, New York 11753

Irving Like, Esq.  
Reilly, Like and Schnieder  
200 West Main Street  
Babylon, New York 11702

MUB Technical Associates  
366 California Avenue  
Suite 6  
Palo Alto, California 94306



Request for Additional Information  
General Electric Company  
Topical Report: NEDM-20988, Revision 2  
Test Plan - December, 1976

1. Effects of a leaking SRV on quencher loads has been identified as an area of concern. The Caorso test plan, however, does not address this concern. It is our position that tests on a leaking SRV should be conducted. Therefore, a test plan considering a leaking SRV should be provided for our review.
2. The Caorso test matrix indicates that most of the parameters of interest will be repeated only once. Tests performed either for ramshead (Quad City and Monticello) or for quencher (NEDE-11314-08) exhibited a great degree of data scatter. Therefore, we believe that the current Caorso test matrix is insufficient to determine the repeatability of the test data. We recommend additional tests be conducted for first actuation of a SRV and subsequent actuations of the same SRV to demonstrate repeatability. The number of tests should result in test data with statistical significance.
3. Based on our evaluation of previous SRV test data, we find that the SRV discharge time and duration between first actuation and subsequent actuation influence the quencher load due to subsequent actuation. Therefore, provide the value and the basis for the selection of the times for the Caorso tests.



4. Page 4-6 states that a complete understanding of the subsequent actuation effect requires data on pool temperature in the vicinity of the quencher, pipe temperature and pressure following valve closure, flow rate of air through the vacuum breaker and dynamics of back flow of water. We agree that the air temperature history inside the pipe could be important. However, insufficient information has been given in the test plan regarding the measurement of air temperature in the pipe. Clarify what measurements or calculations will be made to monitor this temperature.
  
5. The sensor failure rate was found to be quite high in the Monticello Plant test program. Sensors of the same manufacturer model used in the Monticello will also be used in the Caorso. In light of this experience, we believe that redundant instrumentation is needed in critical areas. For instance, redundant sensors should be provided in the following locations:
  - a. The vicinity of quencher A and the place by which combined loads from multiple SRV's actuation will be determined.
  - b. SRV line between elevation 51.612 and 45.770. In addition, level probes should be added between L1 and L12.



6. Submerged structure loads have been identified as a primary design load for the Mark II containment. We believe that the analytical program indicated in the Mark II owner group meeting which was held on February 16 and 17, 1977, is insufficient to support the design loads for submerged structure without experimental data. Therefore, we recommend that additional pressure sensors should be installed on support columns and downcomers to measure the drag load during SRV operation.
7. Provide the locations for pressure sensors Nos. 19, 23, 35, 36 and 37.

