

**AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL**  
(TEMPORARY FORM)

CONTROL NO: 898

FROM: Niagara Mohawk Power Corporation Syracuse, N. Y. 13202 Thomas J. Brosnan		DATE OF DOC: 2-2-73	DATE REC'D: 2-5-73	LTR: X	MEMO	RPT	OTHER
TO: Mr. Skovholt		ORIG: 1	CC	OTHER	SENT AEC PDR X SENT LOCAL PDR X		
CLASS: (U) PROP INFO		INPUT	NO CYS REC'D: 1	DOCKET NO: 50-220			

DESCRIPTION: Ltr re our 1-12-73 ltr....furnishing info re drywell vacuum breakers at the Nine Mile Point Unit No. 1

ENCLOSURES:

PLANT NAMES: Nine Mile Point # 1

**Do Not Remove  
ACKNOWLEDGED**

FOR ACTION/INFORMATION

2-6-73

AB

BUTLER(L) W/ Copies	SCHWENGER(L) W/ Copies	SCHEMEL(L) W/ Copies	KNIGHTON(E) W/ Copies
CLARK(L) W/ Copies	STOLZ(L) W/ Copies	ZIEMANN(L) W/6 Copies	YOUNGBLOOD(E) W/ Copies
GOLLER(L) W/ Copies	VASSALLO(L) W/ Copies	CHITWOOD(FM) W/ Copies	REGAN(E) W/ Copies
KNIEL(L) W/ Copies	H. DENTON W/ Copies	DICKER(E) W/ Copies	

INTERNAL DISTRIBUTION

REG FILE	TECH REVIEW	VOLLMER	HARLESS	WADE	E
AEC-PDR	HENDRIE	DENTON		SHAFFER	F & M
OGC, ROOM P-506A	SCHROEDER	GRIMES	F & M	BROWN	E
MUNIZING/STAFF	MACCARY	GAMMILL	SMILEY	G. WILLIAMS	E
CASE	KNIGHT(2)	KASTNER	NUSSBAUMER	E. GOULBOURNE	L
GIAMBUSSO	PAWLICKI	BALLARD		A/T IND	
BOYD-L(BWR)	SHAO	SPANGLER	LIC ASST.	BRATTMAN	J. RIESLAND
DEYOUNG-L(PWR)	KNUTH		SERVICE L	SALTZMAN	W. BUTLER
SKOVHOLT-L	STELLO	ENVIRO	MASON L		CLARK
P. COLLINS	MOORE	MULLER	WILSON L	PLANS	STOLZ
	HOUSTON	DICKER	MAIGRET L	MCDONALD	
REG OPR	TEDESCO	KNIGHTON	SMITH L	DUBE	
FILE & REGION (3)	LONG	YOUNGBLOOD	GEARIN L	INFO	
MORRIS	LAINAS	PROJ LEADER	DIGGS L	C. MILES	
STELLE	BENAROYA		TEETS L		
		REGAN	LEE L		

EXTERNAL DISTRIBUTION

1-LOCAL PDR Oswego, N. Y.	(1)(5)(9)-NATIONAL LAB'S	1-PDR-SAN/LA/NY
1-DTIE(ABERNATHY)	1-R. CARROLL-OC, GT-B227	1-GERALD LELLOUCHE
1-NSIC(BUCHANAN)	1-R. CATLIN, E-256-GT	BROOKHAVEN NAT. LAB
1-ASLB-YORE/SAYRE	1-CONSULANT'S	1-AGMED(WALTER KOESTER,
WOODWARD/H. ST.	NEWMARK/BLUME/AGABIAN	Rm C-427, GT)
16-CYS ACRS HOLDING SENT TO LIC ASST.		1-RD...MULLER...F-309GT
R. DIGGS ON 2-6-73		



## NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK300 ERIE BOULEVARD, WEST  
SYRACUSE, N. Y. 13202

February 2, 1973



Mr. Donald J. Skovholt  
Assistant Director for Operating Reactors  
Division of Licensing  
United States Atomic Energy Commission  
Washington, D. C. 20545


Re: Nine Mile Point Nuclear Station - Unit 1  
Provisional Operating License - DPR-17  
Docket No. 50-220

Dear Mr. Skovholt:


The following action has been initiated on the items set forth in your letter dated January 12, 1973 concerning the drywell vacuum breakers at our nuclear station:

- (1) On January 24, 1973, each vacuum breaker was inspected and ascertained to be closed. The position indicators in the main control room indicated closed as well as visual inspection of each breaker.
- (2) A report is being generated concerning Items 1-10 inclusively which should be mailed to you on or before March 13, 1973.
- (3) The tests to be performed on the vacuum breakers at the next scheduled refueling outage will be outlined as a portion of the report generated in (2) above. The results of those tests will be included in the subsequent semi-annual report.

Sincerely,



Thomas J. Brosnan  
Vice President and Chief Engineer



TJB:sn

