

DISTRIBUTION:

NCR PDR
 Local PDR
 ✓ Docket
 KR Goller
 TJ Carter
 Debevec
 ORB#3 rdg
 SATeets
 OELD
 IO&E (3)
 Lear
 ACRS (16)
 extra cps

JAN 23 1975

Docket No. 50-220

Niagara Mohawk Power Corporation
 ATTN: Mr. Philip D. Raymond
 Vice President - Engineering
 300 Erie Boulevard West
 Syracuse, New York 13202

Gentlemen:

We have completed a review of the General Electric Company proprietary topical report NEDE-10958, "General Electric BWR Thermal Analysis Basis (GETAB): Data, Correlation and Design Application" (NEDO-10958, is the non-proprietary version). Enclosed is our evaluation of this report.

As a result of our review, we have concluded that the above report provides an acceptable boiling transition correlation and an acceptable method of thermal analysis of the GE BWR 8x8 and 7x7 fuel assemblies.

In this regard, the revised GETAB-based Technical Specifications and supporting analyses for the Nine Mile Point Nuclear Station Unit 1 should be submitted no later than the submittal date of your ECCS re-evaluation required by the Order transmitted to you on December 27, 1974.

Sincerely,

Original Signed

George Lear, Chief
 Operating Reactors Branch #3
 Division of Reactor Licensing

Enclosure:
 Evaluation of Report

cc: See next page

*See Docket No. 50-237
 for enclosure.*

OFFICE>	ORB#3	ORB#3				
SURNAME>	Debevec/dg	Lear				Mr. H
DATE>	1/22 75	1/22 75				4

Niagara Mohawk Power Corporation

- 2 -

JAN 23 1975

cc: w/enclosure

Mr. Arvin E. Upton, Esquire
LeBoeuf, Lamb, Leiby and MacRae
1757 N Street, N. W.
Washington, D. C. 20036

Mr. Robert P. Jones, Supervisor
Town of Scriba
R. D. #4
Oswego, New York 13126

Miss Juanita Kersey, Librarian
Oswego City Library
120 E. Second Street
Oswego, New York 13126

Dr. William E. Seymour
Staff Coordinator
New York State Atomic Energy Council
New York State Department of Commerce
99 Washington, Street
Albany, New York 12210

OFFICE >						
SURNAME >						
DATE >						

1944

1945

1946

1947

1948

1949

1950

1951

1952