

**AEC CONTRIBUTION FOR PART 50 DOCKET MATERIAL**  
(TEMPORARY FORM)

CONTROL NO: 8915

FILE: Misc

FROM: Niagara Mohawk Power Corporation Syracuse, N. Y. 13202 Rubolph R. Schneider			DATE OF DOC 12-10-73	DATE REC'D 12-14-73	LTR X	MEMO	RPT	OTHER
TO: Mr. Skovholt			ORIG 1 signed	CC	OTHER	SENT AEC PDR X SENT LOCAL PDR X		
CLASS	UNCLASS	PROP INFO	INPUT	NO CYS REC'D 40		DOCKET NO: 50-220		
	XXX							

DESCRIPTION:  
Ltr re their 7-20-73 ltr.....furnishing info  
re drywell vacuum breakers at the Nine Mile  
Point Unit # 1.....

ENCLOSURES:

**ACKNOWLEDGED**  
**Do Not Remove**

PLANT NAME: Nine Mile Point Unit # 1

FOR ACTION/INFORMATION

12-14-73 AB

BUTLER(L)	SCHWENCER(L)	✓ ZIEMANN(L)	REGAN(E)
W/ Copies	W/ Copies	W/ 6 Copies	W/ Copies
CLARK(L)	STOLZ(L)	DICKER(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies
GOLLER(L)	VASSALLO(L)	KNIGHTON(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies
KNIEL(L)	SCHEMEL(L)	YOUNGBLOOD(E)	
W/ Copies	W/ Copies	W/ Copies	W/ Copies

**INTERNAL DISTRIBUTION**

✓ REG FILE	TECH REVIEW	DENTON	LIC ASST	A/T IND
✓ AEC PDR	HENDRIE	GRIMES		BRAITMAN
✓ OGC, ROOM P-506A	SCHROEDER	GAMMILL	DIGGS (L)	SALTZMAN
✓ MUNTZING/STAFF	MACCARY	KASTNER	GEARIN (L)	B. HURT
CASE	KNIGHT	BALLARD	GOULBOURNE (L)	PLANS
GIAMBUSSO	PAWLICKI	SPANGLER	LEE (L)	MCDONALD
BOYD	SHAO		MAIGRET (L)	DUBE
MOORE (L) (BWR)	STELLO	ENVIRO	SERVICE (L)	INFO
DEYOUNG (L) (PWR)	HOUSTON	MULLER	SHEPPARD (E)	✓ C. MILES
✓ SKOVHOLT (L)	NOVAK	DICKER	SMITH (L)	✓ J. RIESLAND
P. COLLINS	ROSS	KNIGHTON	TEETS (L)	✓ STOLZ
	IPPOLITO	YOUNGBLOOD	WADE (E)	✓ CLARK
REG OPR	✓ TEDESCO	REGAN	WILLIAMS (E)	✓ BUTLER
✓ FILE & REGION (2)	LONG	PROJECT LDR	WILSON (L)	
MORRIS	✓ LAINAS			
STEELE	BENAROYA	HARLESS		
	VOLLMER			

**EXTERNAL DISTRIBUTION**

✓ 1 - LOCAL PDR Oswego, N Y	(1) (2X10) NATIONAL LAB'S	1-PDR-SAN/LA/NY
✓ 1 - DTIE (ABERNATHY)	1-ASLBP (E/W Bldg, Rm 529)	1-GERALD LELLOUCHE
✓ 1 - NSIC (BUCHANAN)	1-W. PENNINGTON, Rm E-201 GT	BROOKHAVEN NAT. LAB
1 - ASLB (YORE/SAYRE/	1-CONSULTANT'S	1-AGMED (Ruth Gussman)
WOODARD/"H" ST.	NEWARK/BLUME/AGBABIAN	RM-B-127, GT.
✓ 16 - CYS ACRS MODING SENT TO LIC ASST.	1-GERALD ULRIKSON...ORNL	1-RD..MULLER..F-309 GT
R. DIGGS, ON 12-14-73		

THE UNITED STATES OF AMERICA  
DEPARTMENT OF THE INTERIOR  
BUREAU OF LAND MANAGEMENT

WATER RESOURCES DIVISION

WATER RESOURCES DIVISION  
BUREAU OF LAND MANAGEMENT  
WASHINGTON, D. C. 20250

WATER RESOURCES DIVISION

WATER RESOURCES DIVISION

WATER RESOURCES DIVISION

WATER RESOURCES DIVISION

WATER RESOURCES DIVISION

WATER RESOURCES DIVISION

WATER RESOURCES DIVISION

Regulatory


File Cy.

NIAGARA MOHAWK POWER CORPORATION

NIAGARA  MOHAWK

300 ERIE BOULEVARD WEST  
SYRACUSE, N.Y. 13202

December 10, 1973




Mr. Donald J. Skovholt  
Assistant Director for Reactor Operations  
Division of Reactor Licensing  
United States Atomic Energy Commission  
Washington, D. C. 20545

Re: Provisional Operating License: DPR-17  
Docket No.: 50-220


Dear Mr. Skovholt:

Regarding my letter of July 20, 1973 concerning the drywell vacuum breakers at Nine Mile Point Nuclear Station Unit #1 the following information is submitted:

1. Item 1 has been completed. A redundant alarm circuit has been installed and is operational. Both alarm circuits function on .05" or less of disc movement. Thus the two commitments made to assure system operability during the period of time required to install the redundant alarm circuit with the desired accuracy have been completed. Therefore the dial indicators have been removed and the operability test following a suppression chamber transient have been discontinued.
2. The Proposed Technical Specifications indicated in Item 4 of my July 20, 1973 letter are before the Safety Review and Audit Board (SR&AB) and will be submitted for commission review within one month.



Very truly yours,

  
Rudolph R. Schneider  
Vice President - Electric Operations

RRS:cm

REGISTERED MAIL -  
RETURN RECEIPT REQUEST

8915

