

MAY - 8 1974

Docket No. 50-220

Niagara Mohawk Power Corporation  
ATTN: Mr. R. R. Schneider  
Vice President - Electric Operations  
300 Erie Boulevard West  
Syracuse, New York 13202

Gentlemen:

In our letter dated October 1, 1973, we requested that you inspect Bergen-Paterson snubbers outside containment in the Nine Mile Point Unit No. 1 reactor every 30 days and report the results to us within 15 days after the inspection. In a letter dated March 6, 1974, you proposed to continue the inspections as requested, but only submit positive reports when defective units are found. These reports would be written within 10 days. If all units were found to be satisfactory, you proposed that no report would be written.

We have reviewed your proposal and find it satisfactory. Since you have inspected your Bergen-Paterson snubbers for several months and have not observed any defective units, elimination of negative reports will reduce unnecessary paperwork. However, the inspection results should be maintained and be available for inspection by Regulatory Operations should the detailed information be needed.

Sincerely,

Karl R. Goller  
Assistant Director  
for Operating Reactors  
Directorate of Licensing

cc: See next page

OFFICE>	<i>CD</i> L:ORB #2	L:ORB #2	L:ORB #2	L:ORB #2		
SURNAME>	JLSapir:rwg	CJDeBevec	DLZiemann	KRGoller		<i>misc</i>
DATE>	5/7/74	5/7/74	5/7/74	5/8/74		



Niagara Mohawk Power Corp.

- 2 -

MAY - 8 1974

cc: Arvin E. Upton, Esquire  
LeBoeuf, Lamb, Leiby & MacRae  
1757 N Street, N. W.  
Washington, D. C. 20036

Oswego City Library

Mr. Anthony Z. Roisman, Esquire  
Berlin, Roisman and Kessler  
1712 N Street, N. W.  
Washington, D. C. 20036

Distribution  
Docket File  
AEC PDR  
Local PDR  
Branch Reading  
DLZiemann  
TJCarter  
ACRS (16)  
RO [3]  
OGC  
RMDiggs  
JLSapir  
CJDeBevec

OFFICE >						
SURNAME >						
DATE >						



11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

11-11-11