

OCT 2 4 1975

Docket No. 50-220

Niagara Mohawk Power Corporation
ATTN: Mr. Gerald K. Rhode
Vice President - Engineering
300 Erie Boulevard West
Syracuse, New York 13202

Gentlemen:

RE: NINE MILE POINT UNIT 1

DISTRIBUTION:

NRC PDR
Local PDR
~~Docket~~
ORB#3 Rdg
KRGoller
TJCarter
Glear
JGuibert
CParrish
TBAbernathy
SVarga
DEisenhut
OELD
OI&E (3)
ACRS (16)
Gray file
WPaulson

Based on our review of the information submitted on your docket regarding the Mark I containment reevaluation program (up to and including the Mark I Containment Status Report dated July 31, 1975, submitted by the General Electric Company), we have identified additional information that is required to continue our review. The information required is listed in the enclosure and pertains to the functional operability of piping and components when subjected to (1) pool swell loads associated with a loss-of-coolant accident, and (2) loads from operation of the primary system pressure relief valves. The items listed in the enclosure should be addressed during the Long Term Program proposed by the Mark I Owners Group.

We anticipate that further information will be required based on our review of the Short Term Program report.

Please contact us if you desire clarification of the information required.

This request for generic information was approved by GAO under a blanket clearance number B-180225 (R0072); this clearance expires July 31, 1977.

Sincerely,

131

George Lear, Chief
Operating Reactors Branch #3
Division of Reactor Licensing

Enclosure:
Request for Additional
Information

A-3

cc: See next page

OFFICE	ORB#3	ORB#3				
SURNAME	JGuibert:kmf	Glear				
DATE	10/23/75	10/23/75				

2001 10 10

Niagara Mohawk Power Corporation - -

cc:

Arvin E. Upton, Esquire
LeBoeuf, Lamb, Leiby & MacRae
1757 N Street, N. W.
Washington, D. C. 20036

Anthony Z. Roisman, Esquire
Roisman, Kessler and Cashdan
1712 N Street, N. W.
Washington, D. C. 20036

Dr. William Seymour, Staff Coordinator
New York State Atomic Energy Council
New York State Department of Commerce
112 State Street
Albany, New York 12207

Oswego City Library
120 E. Second Street
Oswego, New York 13126

Mr. Robert P. Jones, Supervisor
Town of Scriba
R. D. #4
Oswego; New York 13126

ENCLOSURE

REQUEST FOR ADDITIONAL INFORMATION

1. Provide a list of piping and mechanical components which could be subjected to suppression pool hydrodynamic loadings or loadings from operation of the primary system pressure relief valves, including detailed drawings and functional description of such piping and components.
2. Provide a description of methods and procedures used to define the pool dynamic loads and relief valve actuation loads acting on the listed piping and components.
3. Provide a description of methods and procedures, either by analysis or by testing, being used to ensure design adequacy of the listed piping and components under pool dynamic loads or relief valve actuation loads.
4. Provide a description regarding how the pool dynamic loads or valve actuation loads being concurrently considered and combined with other operation or accident loads acting on the listed piping and components.
5. Identify design limits used for the listed piping and components under pool dynamic or relief valve actuation loads. If analysis or testing has been done, a summary of analysis or testing results and their comparison with design limits should be provided. If analysis or testing has not yet been done, a description of the future program to perform such testing or analysis should be provided.

