



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, D.C. 20555-0001

February 13, 2017

Mr. Mano Nazar
President and Chief Nuclear Officer
Nuclear Division
Florida Power & Light Co.
Mail Stop NT3/JW
15430 Endeavor Drive
Jupiter, FL 33478

**SUBJECT: ST. LUCIE PLANT, UNIT NO. 2 – CORRECTION TO AMENDMENT NO. 182
REGARDING THE USE OF AREVA FUEL (CAC NO. MF5495)**

Dear Mr. Nazar:

By letter dated April 19, 2016 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16063A120), the U.S. Nuclear Regulatory Commission issued Amendment No. 182 for the St. Lucie Plant, Unit No. 2 (St. Lucie 2), Renewed Facility Operating License (RFOL) No. NPF-16. This amendment modified the technical specifications (TSs) to allow the use of AREVA fuel at St. Lucie 2 in response to Florida Power & Light Company's application dated December 30, 2014, as supplemented by letters dated March 23, 2015; June 2, 2015; June 18, 2015; July 30, 2015; October 2, 2015; November 3, 2015; and December 8, 2015.

Specifically, updated RFOL No. NPF-16, pages 3 and 7, were included with Amendment No. 182, as were several TS pages. Prior to issuance of Amendment No. 182, Amendment No. 181 was issued on March 31, 2016 (ADAMS Accession No. ML15344A346), which added two pages to RFOL No. NPF-16, causing page 7 to become new page 9. It was discovered that Amendment No. 182 incorrectly numbered new page 9 as page 7. This error is editorial in nature, and correcting it does not affect the previously issued safety evaluation of the amendment.

Enclosed is the corrected page 9 for Amendment No. 182. Please use this page when making changes to RFOL No. NPF-16 related to Amendment No. 182.

If you have any questions regarding this matter, please contact me at (301) 415-1383 or Perry.Buckberg@nrc.gov.

Sincerely,



Perry H. Buckberg, Senior Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-389

Enclosure:
Corrected page 9 for Amendment
No. 182

cc w/enclosure: Distribution via Listserv

ENCLOSURE

**CORRECTED ST. LUCIE PLANT, UNIT NO. 2, RENEWED FACILITY OPERATING
LICENSE NO. NPF-16, PAGE 9**

**FOR LICENSE AMENDMENT NO. 182
DATED APRIL 19, 2016**

NRC dated December 9, 2003, and October 29, 2004, in response to Generic Letter 2003-01, or within the next 9 months if the time period since the most recent successful tracer gas test is greater than 3 years.

- (c) The first performance of the periodic measurement of CRE pressure, Specification 6.15.d, shall be within 36 months in a staggered test basis, plus the 138 days allowed by SR 4.0.2, as measured from November 13, 2006, which is the date of the most recent successful pressure measurement test, or within 138 days if not performed previously.

N. FATES3B Safety Analyses (Westinghouse fuel only)

FATES3B has been specifically approved for use for St. Lucie Unit 2 licensing basis analyses based on FPL maintaining the more restrictive operational/design radial power fall-off curve limits as specified in Attachment 4 to FPL Letter L-2012-121, dated March 31, 2012 as compared to the FATES3B analysis radial power fall-off curve limits. The radial power fall-off curve limits shall be verified each cycle as part of the Reload Safety Analysis Checklist (RSAC) process.

- 4. This renewed license is effective as of the date of issuance, and shall expire at midnight April 6, 2043.

FOR THE NUCLEAR REGULATORY COMMISSION

Original signed by

J. E. Dyer, Director

Office of Nuclear Reactor Regulation

Attachments:

- 1. Appendix A, Technical Specifications
- 2. Appendix B, Environmental Protection Plan
- 3. Appendix C, Antitrust Conditions
- 4. Appendix D, Antitrust Conditions

Date of Issuance: October 2, 2003

Renewed License No. NPF-16
Amendment No. 463, 484, 182

SUBJECT: ST. LUCIE PLANT, UNIT NO. 2 – CORRECTION TO AMENDMENT NO. 182
REGARDING THE USE OF AREVA FUEL (CAC NO. MF5495) DATED
FEBRUARY 13, 2017.

DISTRIBUTION:

Public
LPL2-2 R/F
RidsACRS_MailCTR Resource
RidsNrrPMStLucie Resource
RidsNrrDssStsb Resource

RidsNrrDlrRerb Resource
RidsNrrDorlLpl2-2 Resource
RidsNrrLABClayton Resource
RidsRgn2MailCenter Resource

ADAMS Accession Number: ML17039A525

OFFICE	DORL/LPL2-2/PM	DORL/LPL2-2/LA	DORL/LPL2-2/BC	DORL/LPL2-2/PM
NAME	PBuckberg	BClayton (LRonewicz for)	BBeasley	PBuckberg
DATE	2/9/2017	2/9/2017	2/13/2017	2/13/2017

OFFICIAL RECORD COPY