

**NRC-TVA Publicly-Noticed Meeting (2/13/2017) Topics for Discussion:
Clinch River Nuclear (CRN) ESP SSAR, Chapter 2 Sections 2.1, 2.2 and 2.3**

1. Discussion of, and approach to reconciling, the inconsistencies between the respective descriptions and depictions of the Exclusion Area Boundary (EAB) in the SSAR; Chapter 2 Subsection 2.1.1.2 and Figure 2.1.5 verses Subsection 2.3.4 and Figure 2.3.4.1.
2. Discussion of approach and rationale described in the SSAR, Chapter 2, Subsection 2.2.3.1.3.2 for screening out potential overexposures (at the CRN power block) to the hazardous chemicals anhydrous ammonia and chlorine during their road transport for control room habitability. A technical and historical perspective on getting finality on control room habitability at the at the ESP stage verses the COL stage will be clarified.