

October 17, 1978

Mr. Eldon J. Brunner, Chief  
Reactor Operations and Nuclear Support Branch  
United States Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, PA. 19406

RE: Docket No. 50-220  
Inspection Report 78-13

Dear Mr. Brunner:

This refers to the inspection conducted by Mr. W. Bannack of your office on September 5-8, 1978, at the Nine Mile Point Nuclear Station Unit #1. The following response is submitted to the alleged deficiencies detailed in Appendix A of your letter dated September 26, 1978:

Contrary to Technical Specifications 6.8.1, on September 7, 1978, it was determined that the requirements of APN-15 were not adhered to in the area of "Use Records" as follows:

- A calibration performed with a test instrument was not logged on its use record log.
- A calibration performed with a test instrument was logged on the wrong test instruments use record log.
- A deadweight tester, out for calibration, used as a standard in the performance of instrument calibrations had no use record log on file.
- A deadweight tester currently in use had no entries in its use record log.

RESPONSE

1. General Training covering Administrative Procedure APN-15, Procedure for Control and Calibration of Equipment used in Tests and Inspections, was administered to departmental personnel. This will be repeated at least once each year.

781115 0188



581112

2. Individual re-inforcement was made to involved personnel of the requirement for adherence to established procedures.
3. Increased surveillance of the situation has been established by independent on-site personnel.
4. Full compliance is now being achieved.

Very truly yours,

*R.R. Schneider*  
R.R. Schneider  
Vice President -  
Electric Production

mtm

371. 135H.16

7 6 5 4 3 2 1

