



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

July 16, 1979

Mr. Darrell G. Eisenhut, Acting Director
Division of Operating Reactors
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Dresden Station Unit 2
Systematic Evaluation Program
Seismic Review
NRC Docket No. 50-237

Dear Mr. Eisenhut:

The following is provided in response to the request for information in Enclosure 1 to Reference (a).

Item 1

Description and drawings from GEI-92807 for the Dresden 2 type control rod drive hydraulic control units and from GEK-39469B for the 7618500 hydraulic control units are enclosed to demonstrate the similarity of the units.

Item 2

The Dresden 2 A.C. motor control centers have been confirmed to be G.E. 7700 line. The A.C. motor control center specification and a General Electric drawing for MCC 25-1 are attached.

To date, Cutler-Hammer has been unable to supply any information on the Dresden 2 D.C. motor control centers to verify similarity. The D.C. motor control center specification, Cutler-Hammer's proposal, Cutler-Hammer drawings 94D9801ED745 Sheets 1 through 12, and four Cutler-Hammer instruction sheets are attached.

7907190563

A028
S 1/1

Note: Drawings
To Reg File


Mr. Darrell G. Eisenhut:

- 2 -

July 16, 1979

Please address any questions you may have concerning
this matter to this office.

Very truly yours,



Robert F. Janecek
Nuclear Licensing Administrator
Boiling Water Reactors

attachments