

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8207020170 DOC. DATE: 82/06/28 NOTARIZED: NO DOCKET #
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 AUTH. NAME AUTHOR AFFILIATION
 UHRIG, R. E. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 EISENHUT, D. G. Division of Licensing

SUBJECT: Application to amend App A of License DPR-67 by deleting requirements to test buried electrical cable periodically to detect potential environ damage. Class II fee encl.

DISTRIBUTION CODE: A0015 COPIES RECEIVED: LTR ___ ENCL ___ SIZE: 1+9
 TITLE: General Distribution for after Issuance of Operating License

NOTES: w/check: \$ 1,200.00

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	ORB #3 BC	01	7	7			
INTERNAL:	ELD/HDS2		1	0	NRR/DHFS DEPY08		1 1
	NRR/DL DIR		1	1	NRR/DL/ORAB		1 0
	NRR/DSI/RAB		1	1	<u>REG FILE</u> 04		1 1
	RGN2		1	1			
EXTERNAL:	ACRS	09	10	10	LPDR	03	1 1
	NRC PDR	02	1	1	NSIC	05	1 1
	NTIS		1	1			


1-1500
02000332

EISENHUT, D. G. Division of Licensing
RECIP. NAME FLORIDA POWER & LIGHT CO.
AUTH. NAME FLORIDA POWER & LIGHT CO.
FACIL. 50-232 26 LUCIE PLANT, UNIT 1, FLORIDA POWER & LIGHT CO.
ACCESSION NBR 850502170 DOC DATE: 85050228 NOTARIZED: NO

Application to amend App A of License DFR-67 by deleting
 requirements to test buried electrical cable periodically
 to detect potential invasion damage. (Class II fee encl.)

TITLE: General Distribution for after Issuance of Operating License
DISTRIBUTION CODE: A005 COPIES RECEIVED: LTR ENCL SIZE: 1

[illegible][illegible]



June 28, 1982
L-82-249

Office of Nuclear Reactor Regulation
Attention: Mr. Darrell G. Eisenhut, Director
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Eisenhut:

Re: St. Lucie Unit 1
Docket No. 50-335
Proposed License Amendment
Buried Electrical Cable

In accordance with 10CFR 50.90, Florida Power & Light Company submits herewith three signed originals and forty copies of a request to amend Appendix A of Facility Operating License DPR-67.

This amendment is submitted to delete the requirements to test buried electrical cable periodically to detect potential environmental damage. The ability of the cable to successfully withstand the environment they are in was presented to the ACRS by FPL as part of the St. Lucie Unit 2 Operating License review. The ACRS has concurred with our position.

The proposed amendment is described below and shown on the accompanying Technical Specification pages bearing the date of this letter in the lower right hand corner.

Pages 3/4 8-4, 3/4 8-5, 3/4 8-6

The requirements to test the buried cable have been deleted.

The proposed amendment has been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board.

Enclosed please find a check for \$1200 as required for a Class II Amendment.

Very truly yours,

E. F. Adomat
for Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/JEM/mbd

Attachment

8207020170 820628
PDR ADDCK 05000335
PDR

cc: J.P. O'Reilly, Region II
Harold F. Reis, Esquire

A001
w/attach:
\$1200.00