

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7907090256 DOC. DATE: 79/06/12 NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 SNOW, B. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 Office of Management and Program Analysis

SUBJECT: Forwards monthly operating rept for May 1979.

DISTRIBUTION CODE: A008S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+5
 TITLE: ANNUAL, SEMI-ANNUAL & MONTHLY OPERATING REPORTS (OL) STAG

NOTES: LCY: J. SHAPAKER, C. HOFMAYER

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTTR	ENCL		ID CODE/NAME	LTTR
ACTION:	05 BC ORB #2	6	6			
INTERNAL:	01 REG FILE	1	1	02 NRC PDR	1	1
	11 I & E	2	2	14 MPA	2	2
	16 DIR DOR	1	1	17 AD SYS/PROJ	1	1
	18 ENGR BR	1	1	19 REAC SAFT BR	1	1
	20 PLANT SYS BR	1	1	21 EEB	1	1
	22 CORE PERF BR	1	1	23 EFFL TR SYS	1	1
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	24 NATL LAB ORNL	1	1	25 BROOKHAVEN	1	1
	26 ACRS	15	15			

JUL 10 1979

THP
CEP

TOTAL NUMBER OF COPIES REQUIRED: LTTR 39 ENCL 39

R



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

TELEPHONE
AREA CODE 716 548-2700

GINNA STATION
June 12, 1979

REGULATORY DOCKET FILE COPY

Director, Office of Management Information and Program Control
U.S. NUCLEAR REGULATORY COMMISSION
Washington, DC 20555

Subject: Monthly Report for April 1979
Operating Status Information
R. E. Ginna Nuclear Power Plant Unit No. 1
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of May, 1979

Very truly yours,

Bruce A. Snow
Superintendent

BAS:kes/dOV
Attachments

A008
5 1/4

7907090256

11

100

OPERATING DATA REPORT

DOCKET NO. 50-244DATE June 8, 1979COMPLETED BY Lewis Depeu
LEWIS DEPEWTELEPHONE 1-716-546-2700
Ext. 291-205, at GinnaOPERATING STATUS

1. Unit Name: GINNA STATION, UNIT #1
2. Reporting Period: May, 1979
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470

Notes

Operated at 92% until 3rd condensate pump repair was completed, 5-3-79, then operated at 100% except for periodic tests.

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

9. Power Level to Which Restricted, If Any (Net MWe):

10. Reasons For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744	3,623	83,777.45
12. Number of Hours Reactor Was Critical	744	2,426.17	63,628.59
13. Reactor Reserve Shutdown Hours	0	22.91	1,569.42 *
14. Hours Generator On-Line	744	2,360.25	61,939.88
15. Unit Reserve Shutdown Hours	0	0	8.5 *
16. Gross Thermal Energy Generated (MWH)	1,111,296	3,374,712	82,304,626
17. Gross Electrical Energy Generated (MWH)	374,945	1,135,781	26,709,021
18. Net Electrical Energy Generated (MWH)	357,262	1,079,492	25,280,530
19. Unit Service Factor	100%	65.15%	74.29%
20. Unit Availability Factor	100%	65.15%	74.30%
21. Unit Capacity Factor (Using MDC Net)	102.17%	63.39%	67.09%
22. Unit Capacity Factor (Using DER Net)	102.17%	63.39%	67.09%
23. Unit Forced Outage Rate	0	0	9.9%
24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):	None		

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

* Cumulative Data Commencing January 1, 1975

7907090259

AVERAGE DAILY UNIT POWER UNIT

DOCKET NO. 50-244

UNIT #1, Ginna Station

DATE June 8, 1979

COMPLETED BY Lewis Depeu
LEWIS DEPEW

TELEPHONE 1-716-546-2700
Ext. 291-205, at Ginna

MONTH MAY, 1979

DAY AVERAGE DAILY POWER LEVEL (MWe-Net)

1	<u>452</u>
2	<u>452</u>
3	<u>469</u>
4	<u>487</u>
5	<u>487</u>
6	<u>486</u>
7	<u>487</u>
8	<u>487</u>
9	<u>488</u>
10	<u>487</u>
11	<u>486</u>
12	<u>486</u>
13	<u>392</u>
14	<u>485</u>
15	<u>486</u>
16	<u>485</u>

DAY AVERAGE DAILY POWER LEVEL (MWe-Net)

17	<u>485</u>
18	<u>485</u>
19	<u>486</u>
20	<u>486</u>
21	<u>486</u>
22	<u>486</u>
23	<u>484</u>
24	<u>484</u>
25	<u>486</u>
26	<u>486</u>
27	<u>487</u>
28	<u>486</u>
29	<u>487</u>
30	<u>487</u>
31	<u>487</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH MAY, 1979

DOCKET NO. 50-244
 UNIT NAME #1, Ginna Station
 DATE June 8, 1979
 COMPLETED BY Lewis Depeu
 LEWIS DEPEW
 TELEPHONE 1-716-546-2700
 Ext. 291-205, at Ginna

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
3	790409	F	572	A-B			HH	VALVEX	Annual overhaul of "A" condensate pump still in progress, "B" condensate pump discharge valve position limited condensate pressure and flow.
4	790513	S	16	B			HA		Turbine stop valve test.

1
 F: Forced
 S: Scheduled

2
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

4
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5
 Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244UNIT #1, Ginna StationDATE June 8, 1979COMPLETED BY Lewis Depeu
LEWIS DEPEUTELEPHONE 1-716-546-2700
Ext. 291-205, at GinnaMONTH MAY, 1979

Operation continued at 92% until completion of "A" condensate pump maintenance on May 3, 1979, then at 100% except for power reductions on May 13, 1979, for turbine stop valve test, and May 24, 1979, for auxiliary feedwater pump test.

GINNA STATION

MAINTENANCE REPORT FOR MAY, 1979

During May, normal inspection and minor maintenance was performed.
Major safety related maintenance included:

1. Repairs were made to a RHR pipe restraint. Initial construction welds were not completed, these welds were made.
2. Impeller clearances were checked on the motor driven fire pump. Clearances were reset to the manufacturer's recommended tolerances.

