

NEW
YORK
STATE

ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

LEON D. WHITE, JR.
VICE PRESIDENTTELEPHONE
AREA CODE 716 546-2700

October 30, 1979

Mr. Boyce H. Grier, Director
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Subject: IE Bulletin No. 79-24, Frozen Lines
R. E. Ginna Nuclear Power Plant, Unit #1
Docket No. 50-244

Dear Mr. Grier:

In response to Inspection and Enforcement Bulletin 79-24 concerning freeze protection of specific lines during extremely cold weather, the following information is provided.

1. Process lines - there are two lines which have sections that are not protected by heated buildings. These are the "B" Steam Generator Main Feedwater line and Main Steam line. In the ten years of plant operation, there has never been an indication of freezing; this includes some extended outages during the severe winter months.
2. Instrument lines - all lines are adequately protected within heated buildings.
3. Sample lines - all lines are adequately protected within heated buildings.

Very truly yours,

L. D. White, Jr.

7911230 371

Q

ccp
Ao₂

