

Attachment A

1. Make the following changes in the Technical Specifications.
  - a. Replace page ii with the attached revision
  - b. Add the attached page 4.17-1

8003130557



## TABLE OF CONTENTS (cont.)

	<u>Page</u>
4.0 SURVEILLANCE REQUIREMENTS	4.1-1
4.1 Operational Safety Review	4.1-1
4.2 Inservice Inspection	4.2-1
4.3 Reactor Vessel Material Surveillance Program	4.3-1
4.4 Containment Tests	4.4-1
4.5 Safety Injection, Containment Spray and Iodine Removal Systems Tests	4.5-1
4.6 Emergency Power System Periodic Tests	4.6-1
4.7 Main Steam Isolation Valves	4.7-1
4.8 Auxiliary Feedwater System	4.8-1
4.9 Reactivity Anomalies	4.9-1
4.10 Environmental Radiation Survey	4.10-1
4.11 Spent Fuel Pit Charcoal Adsorber Testing	4.11-1
4.12 Effluent Surveillance	4.12-1
4.13 Radioactive Material Source Leakage Test	4.13-1
4.14 Shock Suppressors (Snubbers)	4.14-1
4.15 Fire Suppression System Test	4.15-1
4.16 Overpressure Protection System	4.16-1
4.17 Secondary Water Chemistry Monitoring	4.17-1
5.0 DESIGN FEATURES	
5.1 Site	5.1-1
5.2 Containment Design Features	5.2-1
5.3 Reactor Design Features	5.3-1
5.4 Fuel Storage	5.4-1

#### 4.17 Secondary Water Chemistry Monitoring

##### Applicability

Applies to the monitoring of secondary system water chemistry.

##### Objective

To inhibit steam generator tube degradation.

##### Specifications

4.17.1 A program of secondary water chemistry monitoring shall include:

- a. Identification of a sampling schedule for the critical parameters and control points for these parameters;
- b. Identification of the procedures used to quantify parameters that are critical to control points;
- c. Identification of process sampling points;
- d. Procedure for the recording and management of data;
- e. Procedures defining corrective actions for off control point chemistry conditions; and
- f. A procedure identifying the authority responsible for the interpretation of the data, and the sequence and timing of administrative events required to initiate corrective action.

## Attachment B

By letter dated July 23, 1979 from Mr. D. L. Ziemann, Chief, Operating Reactors Branch No. 2, we were requested to propose a license amendment which would implement a secondary water chemistry monitoring program. The proposed Technical Specification is identical to the Model License Condition provided by the NRC and will provide an appropriate level of control over secondary water chemistry.

A program of secondary chemistry monitoring is currently in place, however, certain aspects of the administrative controls have not yet been formally instituted. Because of upcoming refueling outage, scheduled to begin March 28, and because of the expanded program of steam generator inspection and testing which will be carried out during and following the outage, we expect that complete implementation of the proposed requirements will not be accomplished until June 30, 1980. Therefore, we request that the proposed Technical Specification not be effective until that time.

The proposed change will not result in changes to plant effluents and will not result in any change in the authorized power level of the facility.



Attachment C

The proposed Technical Specification supersedes our Application for Amendment to Operating License dated November 1, 1976 (and submitted by letter dated November 15, 1976). Therefore, as identified in the letter dated July 23, 1979 from Mr. D. L. Ziemann, Chief, Operating Reactors Branch No. 2, and pursuant to 10CFR170.22, no fee is required.