

OPERATING DATA REPORT

DOCKET NO. 50-244

DATE April 10, 1980

COMPLETED BY Andrew E. McNamara

Andrew E. McNamara

TELEPHONE 1-315-524-4446

Ext. 293, at Ginna

OPERATING STATUS

1. Unit Name: GINNA STATION, UNIT #1
2. Reporting Period: March, 1980
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes The Reactor Power Level averaged 100% until 3/10, when problems with 5B Feedwater Heater necessitated a reduction to ~98%. Unit load coast-down commences on 3/17, unit refueling shutdown on 3/29.

9. Power Level to Which Restricted, If Any (Net MWe): _____

10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744	2,184	90,696
12. Number of Hours Reactor Was Critical	674.5	2,114.75	69,794.52
13. Reactor Reserve Shutdown Hours	0	0	1,621.57 *
14. Hours Generator On-Line	674.5	2,114.50	68,071.13
15. Unit Reserve Shutdown Hours	0	0	8.5 *
16. Gross Thermal Energy Generated (MWH)	935,736	3,118,656	91,394,458
17. Gross Electrical Energy Generated (MWH)	302,276	1,021,206	29,706,997
18. Net Electrical Energy Generated (MWH)	286,350	970,811	28,132,359
19. Unit Service Factor	90.66%	96.82%	75.05%
20. Unit Availability Factor	90.66%	96.82%	75.06%
21. Unit Capacity Factor (Using MDC Net)	81.89%	94.58%	68.41%
22. Unit Capacity Factor (Using DER Net)	81.89%	94.58%	68.41%
23. Unit Forced Outage Rate	0%	0%	9.63%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup: May 10, 1980

26. Units In Test Status (Prior to Commercial Operation): Forecast Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

* Cumulative total commencing January 1, 1975

AVERAGE DAILY UNIT POWER UNIT

DOCKET NO. 50-244

UNIT #1, Ginna Station

DATE April 10, 1980

COMPLETED BY Andrew E. McNamara
Andrew E. McNamara

TELEPHONE 1-315-524-4446
Ext. 293, at Ginna

MONTH March, 1980

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	469
2	472
3	472
4	473
5	474
6	475
7	476
8	476
9	473
10	469
11	464
12	464
13	463
14	464
15	464
16	464

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	463
18	458
19	453
20	432
21	377
22	361
23	355
24	348
25	306
26	285
27	285
28	284
29	36
30	0
31	0

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH March, 1980

DOCKET NO. 50-244
 UNIT NAME #1, Ginna Station
 DATE April 10, 1980
 COMPLETED BY Andrew E. McNamara
 Andrew E. McNamara
 TELEPHONE 1-315-524-4446,
 Ext. 293, at Ginna

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
1	800329	S	69.5*	C	1				Annual Refueling and Maintenance. * Shutdown hours in month of March only.

1
 F: Forced
 S: Scheduled

2
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

4
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5
 Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244

UNIT #1, Ginna Station

DATE April 10, 1980

COMPLETED BY Andrew E. McNamara
Andrew E. McNamara

TELEPHONE 1-315 524-4446
Ext. 293

MONTH March, 1980

The Reactor Power Level averaged 100% until March 10, when the Power Level was reduced to ~98%, due to problems with the 5B Feedwater Heater. It remained at this level until 3/17 when Unit Load Coastdown commenced. On 3/21 a further reduction was prompted by further problems with the 5B Feedwater Heater. Unit Shutdown for annual Refueling and Maintenance commenced on 3/29.

GINNA STATION

MAINTENANCE REPORT FOR MARCH, 1980

During March, normal inspections and minor maintenance were performed. Immediate major safety related maintenance was not required and all preventive maintenance was postponed until the Refueling Outage which commenced at the end of March.

