

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8006090317 DOC.DATE: 80/06/03 NOTARIZED: NO DOCKET #  
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244  
 AUTH.NAME AUTHOR AFFILIATION  
 SNOW,B.A. Rochester Gas & Electric Corp.  
 RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: RO 80-05:on 800603,during performance of procedure S-30.1,  
 breaker for A-loop accumulator discharge valve MDV-865  
 discovered in closed position.Cause not stated.Breaker  
 immediately placed in proper position.

DISTRIBUTION CODE: A002S COPIES RECEIVED:LTR 1 ENCL 0 SIZE: 1  
 TITLE: Incident Reports


NOTES: ICY: D. ALLISON, E. ADENSAM.

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
ACTION:	05 BC ORB #2	4 4		
INTERNAL:	01 REG FILE	1 1	02 NRC PDR	1 1
	09 I&E	2 2	11 MPA	3 3
	15 NOVAK/KNIEL	1 1	16 EEB	1 1
	17 AD FOR ENGR	1 1	18 PLANT SYS BR	1 1
	19 I&C SYS BR	1 1	20 AD PLANT SYS	1 1
	22 REAC SAFT BR	1 1	23 ENGR BR	1 1
	24 KREGER	1 1	25 PWR SYS BR	1 1
	26 AD/SITE ANAL	1 1	27 OPERA LIC BR	1 1
	28 ACDENT ANLYS	1 1	29 AUX SYS BR	1 1
	AD/ORP-DOR	1 1	AEOD	10 10
	BERLINGER,C.	3 3	DOUG MAY-TERA	1 1
	HANAVER,S.	1 1	JORDAN,E./IE	1 1
EXTERNAL:	03 LPDR	1 1	04 NSIC	1 1
	29 ACRS	16 16		

JUN 10 1980

TOTAL NUMBER OF COPIES REQUIRED: LTTR 62 ENCL 0





ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

Ginna Station  
June 3, 1980

TELEPHONE  
AREA CODE VIA 546-2700

Mr. Boyce H. Grier, Director  
U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region I  
631 Park Avenue  
King of Prussia, PA 19406

Subject: IER 80-05, Non-Compliance with Technical Specification  
Section 3.3.1.1.g Regarding Removal of A.C. Power From  
MDV-865

Dear Mr. Grier:

This is to confirm my telephone discussion with Mr. Don Johnson, on June 3, 1980 at approximately 0830 hours, to report Licensee Event Report 80-05. This event is reportable in accordance with Technical Specification Section 6.9.2.a.(2), "Operation of the unit or affected system when any parameter or operation subject to a limiting condition is less conservative than the least conservative aspect of the limiting condition for operation established in the Technical Specifications".

At 0645 hours, on June 3, 1980 and during the performance of procedure "S-30.1, Safety Injection Valve Position Verification", it was discovered that the breaker for the A-Loop Accumulator discharge valve MDV-865 was in the closed position. This is contrary to Technical Specification Section 3.3.1.1.g which requires that A.C. power be "off" to certain safeguard valves. The breaker was immediately placed to the proper position. Other valves and breakers in the procedure were found to be in proper alignment. It is to be noted that the valve MDV-865 was in the open position which is it's proper safeguards position.

*Bruce A. Snow*  
Bruce A. Snow  
Superintendent

A002  
S  
1/0

BAS:cll/53

cc: L. D. White, Jr.  
L. S. Lang  
C. H. Peck

T. R. Schuler  
J. T. St. Martin  
IER 80-05 File

8006090317

