

**REF**

CENTRAL FILES

ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

Ginna Station  
June 3, 1980

TELEPHONE  
AREA CODE VIA 526-2700

50-244

Mr. Boyce H. Grier, Director  
U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region I  
631 Park Avenue  
King of Prussia, PA 19406

Subject: IER 80-05, Non-Compliance with Technical Specification  
Section 3.3.1.1.g Regarding Removal of A.C. Power From  
MDV-865

Dear Mr. Grier:

This is to confirm my telephone discussion with Mr. Don Johnson, on June 3, 1980 at approximately 0830 hours, to report Licensee Event Report 80-05. This event is reportable in accordance with Technical Specification Section 6.9.2.a.(2), "Operation of the unit or affected system when any parameter or operation subject to a limiting condition is less conservative than the least conservative aspect of the limiting condition for operation established in the Technical Specifications".

At 0645 hours, on June 3, 1980 and during the performance of procedure "S-30.1, Safety Injection Valve Position Verification", it was discovered that the breaker for the A-Loop Accumulator discharge valve MDV-865 was in the closed position. This is contrary to Technical Specification Section 3.3.1.1.g which requires that A.C. power be "off" to certain safeguard valves. The breaker was immediately placed to the proper position. Other valves and breakers in the procedure were found to be in proper alignment. It is to be noted that the valve MDV-865 was in the open position which is its proper safeguards position.

*Bruce A. Snow*  
Bruce A. Snow  
Superintendent

BAS:c11/53

cc: L. D. White, Jr.  
L. S. Lang  
C. H. Peck

T. R. Schuler  
J. T. St. Martin  
IER 80-05 File

8006230

601

