

PARAG. 6

ROCHESTER GAS AND ELECTRIC CORPORATION

GINNA STATION

CONTROLLED COPY NUMBER 9

GINNA STATION
UNIT #1
COMPLETED

DATE:-

TIME:-

PROCEDURE NO. PT-37.5

REV. NO. 0

CONTAINMENT RECIRCULATION FANS MASS AIR FLOW CHECK

TECHNICAL REVIEW

PORC 3-24-80

TR Schulz
QC REVIEW

3-29-80
DATE

APPROVED FOR USE

J. Moon
for PLANT SUPERINTENDENT

3-31-80
DATE

QA X NON-QA _____ CATEGORY 1.0

REVIEWED BY: _____

THIS PROCEDURE CONTAINS 10 PAGES

8009160 582

PT-37.5CONTAINMENT RECIRCULATION FANS MASS AIR FLOW CHECK1.0 PURPOSE:

1.1 To determine total air flow through Containment Recirculation Fans.

2.0 TEST REQUIREMENTS:2.1 Determine mass air flow of each containment recirculation fan during normal operation and "A" & "C" fans during accident operation.3.0 REFERENCES:

3.1 Tech. Specs. Section 4.5.2.3.

4.0 INITIAL CONDITIONS:4.1 Ensure that all fans except that fan undergoing the flow check, are not operating.

4.2 This procedure is divided into 6 sections. Indicate which sections were used and mark remainder N/A.

4.2.1 "A" Containment Recirculation Fan Normal Conditions Mass Air Flow Check. _____4.2.2 "A" Containment Recirculation Fan Accident Conditions Mass Air Flow Check. _____4.2.3 "B" Containment Recirculation Fan Normal Conditions Mass Air Flow Check. _____4.2.4 "C" Containment Recirculation Fan Normal Conditions Mass Air Flow Check. _____4.2.5 "C" Containment Recirculation Fan Accident Conditions Mass Air Flow Check. _____4.2.6 "D" Containment Recirculation Fan Normal Conditions Mass Air Flow Check. _____

4.3 Test personnel are qualified in accordance with A-1102. _____

5.0 PRECAUTIONS:

5.1 Normal company safety precautions will be observed.



6.0 INSTRUCTIONS:6.1 "A" Containment Recirculation Fan Normal Conditions Mass Air Flow Check:

- 6.1.1 Ensure that only the "A" Containment Recirculation Fan is running. _____
- 6.1.2 Ensure that normal loop entry damper 1 F-LED (5873) is open. _____
- 6.1.3 Insert Pitot Tube and position end into air flow. _____
- 6.1.4 Record air flow measurements at points indicated on data sheet. _____
- 6.1.5 Perform calculations for total air flow. _____

6.2 "A" Containment Recirculation Fan Accident Conditions Mass Air Flow Check:

- 6.2.1 Ensure that only the "A" Containment Recirculation Fan is running. _____
- 6.2.2 Press in armature button of CF1A/L relay in Relay Racks (latch in type relay), verify the following:
 - 6.2.2.1 1F-LED damper (5873) assumes its fully closed position. _____
 - 6.2.2.2 1I-CID damper (5871) assumes its fully open position. _____
 - 6.2.2.3 1K-COD damper (5872) assumes its fully open position. _____
 - 6.2.2.4 Green indicating light (at M.C.B.) for charcoal dampers is extinguished. _____
- 6.2.3 Insert Pitot Tube and position end into air flow. _____
- 6.2.4 Record air flow measurements at points indicated on data sheet. _____
- 6.2.5 Perform calculations for total air flow. _____
- 6.2.6 Return "A" Containment Recirculation Fan Dampers to their normal position by pressing in reset push button and verify the following:
 - 6.2.6.1 1F-LED damper (5873) assumes its fully open position. _____
 - 6.2.6.2 1I-CID damper (5871) assumes its fully closed position. _____
 - 6.2.6.3 1K-COD damper (5872) assumes its fully closed position. _____
 - 6.2.6.4 Green indicating light (at M.C.B.) for charcoal dampers is illuminated. _____

6.3 "B" Containment Recirculation Fan Normal Conditions Mass Air Flow Check:

- 6.3.1 Ensure that only the "B" Containment Recirculation Fan is running. _____
- 6.3.2 Ensure that normal loop entry damper 1G-LED is open. _____
- 6.3.3 Insert Pitot Tube and position end into air flow. _____
- 6.3.4 Record air flow measurements at points indicated on data sheet. _____
- 6.3.5 Perform calculations for total air flow. _____
- 6.4 "C" Containment Recirculation Fan Normal Conditions Mass Air Flow Check:
- 6.4.1 Ensure that only the "C" Containment Recirculation Fan is running. _____
- 6.4.2 Ensure that normal loop entry damper 1H-LED (5875) is open. _____
- 6.4.3 Insert Pitot Tube and position end into air flow. _____
- 6.4.4 Record air flow measurements at points indicated on data sheet. _____
- 6.4.5 Perform calculations for total air flow. _____
- 6.5 "C" Containment Recirculation Fan Accident Conditions Mass Air Flow Check:
- 6.5.1 Ensure that only the "C" Containment Recirculation Fan is running. _____
- 6.5.2 Press in armature button of CF1C/L relay in Relay Racks (latch in type relay), verify the following:
- 6.5.2.1 1H-LED damper (5875) assumes its fully closed position. _____
- 6.5.2.2 1J-CID damper (5876) assumes its fully open position. _____
- 6.5.2.3 1L-COD damper (5874) assumes its fully open position. _____
- 6.5.2.4 Green indicating light (at M.C.B.) for charcoal dampers is extinguished. _____
- 6.5.3 Insert pitot tube and position end into air flow. _____
- 6.5.4 Record air flow measurements at points indicated on data sheet. _____
- 6.5.5 Perform calculations for total air flow. _____
- 6.5.6 Return "C" Containment Recirculation Fan Dampers to their normal position by pressing in reset push button and verify the following:
- 6.5.6.1 1H-LED damper (5875) assumes its fully open position. _____
- 6.5.6.2 1J-CID damper (5876) assumes its fully closed position. _____



- 6.5.6.3 1L-COD damper (5874) assumes its fully closed position. _____
- 6.5.6.4 Green indicating light (at M.C.B.) for charcoal dampers is illuminated. _____
- 6.6 "D" Containment Recirculation Fan Normal Conditions Mass Air Flow Check:
- 6.6.1 Ensure that only the "D" Containment Recirculation Fan is running. _____
- 6.6.2 Ensure that normal loop entry damper 1E-LED is open. _____
- 6.6.3 Insert Pitot Tube and position end into air flow. _____
- 6.6.4 Record air flow measurements at points indicated on data sheet. _____
- 6.6.5 Perform calculations for total air flow. _____

COMPLETED BY: _____

DATE COMPLETED: _____

SHIFT SUPERVISOR: _____

RESULTS AND TEST REVIEW: _____

DATE: _____

"A" CONTAINMENT RECIRCULATION FAN NORMAL CONDITIONSMASS AIR FLOW CHECK DATA SHEET

INCHES	TRAVERSE	
	#1	#2
1 1/16		
3 7/16		
6 1/8		
9 1/2		
14 3/8		
27 5/8		
32 1/2		
35 7/8		
38 9/16		
40 15/16		
TOTAL		

Tot. Traverse #1 10 = ave. traverse #1

Tot. Traverse #2 10 = ave. traverse #2

Total 2 = ΔP = "H₂O

$\left(\frac{\text{"H}_2\text{O}}{(12 \text{ in/ft})} \frac{144 \text{ in}^2/\text{ft}^2}{2.31 \text{ ft/H}_2\text{O}/\text{in}^2} \right) = \text{ } \text{ \#/ft}^2$

$$V = \sqrt{\frac{2g (\Delta P)}{e}} = \sqrt{\frac{(64.4 \text{ ft/sec}^2) (\text{ } \text{ \#/ft}^2)}{.075 \text{ \#/ft}^3}} = \text{ } \text{ ft/sec}$$

Area of 42" Duct = 9.6218 ft²

Q = AV = (9.6218 ft²) (ft/sec) (60 sec/min) = ft³/min

COMMENTS:

PERFORMED BY:

DATE:

"A" CONTAINMENT RECIRCULATION FAN ACCIDENT CONDITIONS

MASS AIR FLOW CHECK DATA SHEET

INCHES	TRAVERSE	
	#1	#2
1 1/16		
3 7/16		
6 1/8		
9 1/2		
14 3/8		
27 5/8		
32 1/2		
35 7/8		
38 9/16		
40 15/16		
TOTAL		

Tot. Traverse #1 $\frac{\quad}{10}$ = ave. traverse #1 $\frac{\quad}{\quad}$

Tot. Traverse #2 $\frac{\quad}{10}$ = ave. traverse #2 $\frac{\quad}{\quad}$

$$\text{Total } \frac{\quad}{2} = \frac{\quad}{\Delta P} = \quad \text{"H}_2\text{O}$$

$$\frac{(\text{"H}_2\text{O}) \ 144 \text{ in}^2/\text{ft}^2}{(12 \text{ in}/\text{ft}) \ 2.31 \text{ ft}/\text{H}_2\text{O}/\#/\text{in}^2} = \underline{\hspace{2cm}} \text{ \#/ft}^2$$

$$V = \sqrt{\frac{2g (\Delta P)}{e}} = \sqrt{\frac{(64.4 \text{ ft/sec}^2)(\text{---} \#/\text{ft}^2)}{.075 \#/\text{ft}^3}} =$$

$$\sqrt{\text{ft}^2/\text{sec}^2} = \text{ft/sec}$$

$$\text{Area of 42" Duct} = 9.6218 \text{ ft}^2$$

$$Q = AV = (9.6218 \text{ ft}^2) (\text{ft/sec}) (60 \text{ sec/min}) = \text{ft}^3/\text{min}$$

COMMENTS:

PERFORMED BY: _____

DATE:

"B" CONTAINMENT RECIRCULATION FAN NORMAL CONDITIONSMASS AIR FLOW CHECK DATA SHEET

INCHES	TRAVERSE	
	#1	#2
1 1/16		
3 7/16		
6 1/8		
9 1/2		
14 3/8		
27 5/8		
32 1/2		
35 7/8		
38 9/16		
40 15/16		
TOTAL		

Tot. Traverse #1 = ave. traverse #1
10

Tot. Traverse #2 = ave. traverse #2
10

Total = = "H₂O
2 ΔP

("H₂O) $\frac{144 \text{ in}^2/\text{ft}^2}{(12 \text{ in}/\text{ft})^2} \cdot \frac{2.31 \text{ ft}^3/\text{H}_2\text{O}/\text{in}^2}{\text{ft}^3/\text{in}^2} = \text{ } \text{ #/ft}^2$

$$V = \frac{\sqrt{2g (\Delta P)}}{e} = \frac{\sqrt{(64.4 \text{ ft}/\text{sec}^2) (\text{ } \text{ #/ft}^2)}}{\text{ } .075 \text{ #/ft}^3} = \text{ } \text{ ft}^2/\text{sec}^2 = \text{ } \text{ ft}/\text{sec}$$

Area of 42" Duct = 9.6218 ft²

$$Q = AV = (9.6218 \text{ ft}^2) (\text{ } \text{ ft}/\text{sec}) (60 \text{ sec}/\text{min}) = \text{ } \text{ ft}^3/\text{min}$$

COMMENTS:

PERFORMED BY:

DATE:

"C" CONTAINMENT RECIRCULATION FAN NORMAL CONDITIONS

MASS AIR FLOW CHECK DATA SHEET

INCHES	TRAVERSE	
	#1	#2
1 1/16		
3 7/16		
6 1/8		
9 1/2		
14 3/8		
27 5/8		
32 1/2		
35 7/8		
38 9/16		
40 15/16		
TOTAL		

Tot. Traverse #1 10 = ave. traverse #1

Tot. Traverse #2 10 = ave. traverse #2 10

$$\text{Total } \frac{\quad}{2} = \frac{\quad}{\Delta P} = \frac{\quad}{\quad} \text{ "H}_2\text{O}$$

$$\frac{(\text{"H}_2\text{O}) \ 144 \text{ in}^2/\text{ft}^2}{(12 \text{ in}/\text{ft})^2 \cdot 2.31 \text{ ft}/\text{H}_2\text{O}/\#/\text{in}^2} = \underline{\hspace{2cm}} \#/\text{ft}^2$$

$$V = \sqrt{\frac{2g(\Delta P)}{e}} = \sqrt{\frac{(64.4 \text{ ft/sec}^2)(\text{_____} \#/\text{ft}^2)}{.075 \#/\text{ft}^3}} = \sqrt{\text{_____} \text{ft}^2/\text{sec}^2} = \text{_____} \text{ft/sec}$$

Area of 42" Duct = 9.6218 ft²

$$Q = AV = (9.6218 \text{ ft}^2) (\text{ } \text{ft/sec}) (60 \text{ sec/min}) = \text{ } \text{ft}^3/\text{min}$$

COMMENTS:

PERFORMED BY: .

DATE: _____

"D" CONTAINMENT RECIRCULATION FAN NORMAL CONDITIONS

MASS AIR FLOW CHECK DATA SHEET

INCHES	TRAVERSE	
	#1	#2
1 1/16		
3 7/16		
6 1/8		
9 1/2		
14 3/8		
27 5/8		
32 1/2		
35 7/8		
38 9/16		
40 15/16		
TOTAL		

Tot. Traverse #1 10 = ave. traverse #1

Tot. Traverse #2 $\frac{\quad}{10}$ = ave. traverse #2 $\frac{\quad}{\quad}$

$$\text{Total } \frac{\quad}{2} = \frac{\quad}{\Delta P} = \frac{\quad}{\quad} \text{ "H}_2\text{O}$$

$$\frac{(\text{"H}_2\text{O}) \ 144 \text{ in}^2/\text{ft}^2}{(12 \text{ in}/\text{ft}) \ 2.31 \text{ ft}/\text{H}_2\text{O}/\#/\text{in}^2} = \underline{\hspace{2cm}} \text{ \#/ft}^2$$

$$v = \sqrt{\frac{2g(\Delta P)}{e}} = \sqrt{\frac{(64.4 \text{ ft/sec}^2)(\text{_____} \#/\text{ft}^2)}{.075 \#/\text{ft}^3}} = \sqrt{\text{_____} \text{ft}^2/\text{sec}^2} = \text{_____} \text{ft/sec}$$

Area of 42" Duct = 9.6218 ft²

$$Q = AV = (9.6218 \text{ ft}^2) (\quad \text{ft/sec}) (60 \text{ sec/min}) = \quad \text{ft}^3/\text{min}$$

COMMENTS:

PERFORMED BY:

DATE: _____

