




ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

LEON D. WHITE, JR.  
VICE PRESIDENT

TELEPHONE  
AREA CODE 716 546-2700

Central Files



August 29, 1980

Mr. Boyce H. Grier, Director  
U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Subject: IE Bulletin No. 80-15, "Possible Loss of Emergency Notification  
System (ENS) With Loss of Off-site Power"  
R. E. Ginna Nuclear Power Plant, Unit #1  
Docket No. 50-244

Dear Mr. Grier:

In response to Inspection and Enforcement Bulletin 80-15 dated June 18, 1980, concerning the Emergency Notification System, the following information is provided.

New York Telephone was contacted on June 25, 1980 and confirmed that the ENS Communication is powered through their equipment.

The system is powered by 48VDC in their Central Office in Ontario. Loss of off-site power would not affect most of the phones in this network. Because of the NRC special instructions for the phone requirements for the resident inspector, his extension of the ENS would be inoperable during loss of off-site power.

Since the system operates continuously on DC power, no test was conducted to verify all extensions would operate with loss of off-site power.

A change to procedure Administrative Order A-56 Communications Systems at Ginna Station has been initiated which will require one hour notification to the USNRC of system inoperability.

7

8010010 825





ROCHESTER GAS AND ELECTRIC CORP.

SHEET NO. 2

DATE August 29, 1980

TO Mr. Boyce H. Grier, Director

To assist in evaluating the value/impact of each Bulletin on licensees, manpower expended in conduct of the review and preparation of this report is approximately one manhour. No corrective actions were necessary.

Very truly yours,

L. D. White, Jr.

Subscribed and sworn to me  
on this 29 day of August 1980.

STEPHEN KOWBA  
NOTARY PUBLIC, State of N.Y., Monroe County  
My Commission Expires March 30, 1982

cc: Mr. Victor Stello, Jr., Director  
U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Washington, D. C. 20555

