ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9005290223 DOC.DATE: ~~90/04/30~~ NOTARIZED: NO DOCKET #
FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
AUTH.NAME AUTHOR AFFILIATION
DODGE,R.E. Rochester Gas & Electric Corp.
MECREDY,R.C. Rochester Gas & Electric Corp.
RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Apr 1990 for RE Ginna Nuclear Power Plant.W/900515 ltr.

DISTRIBUTION CODE: IE24D ~~COPIES~~ RECEIVED:LTR 1 ENCL 1 SIZE: 5
TITLE: Monthly Operating Report (per Tech Specs)

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL
	PD1-3 LA	3	3	PD1-3 PD	1	1
	JOHNSON,A	1	1			
INTERNAL:	AEOD/DOA	1	1	AEOD/DSP/TPAB	1	1
	IRM TECH ADV	2	2	NRR/DLPQ/LPEB10	1	1
	NRR/DOEA/OEAB11	1	1	REG FILE 01	1	1
	RGN1	1	1			
EXTERNAL:	EG&G STUART,V.A	1	1	LPDR	1	1
	NRC PDR	1	1	NSIC	1	1

R I D S / A D D S

R I D S / A D D S

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 17 ENCL 17

mk

ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

May 15, 1990

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for April, 1990
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of April, 1990.

Very truly yours,

Robert C. Mecredy
Division Manager
Nuclear Production

RCM/eeh

Attachments

cc: Mr. Thomas T. Martin NRC (1)

IE24
1/1

OPERATING DATA REPORT

DOCKET NO. 50-244
DATE May 15, 1990
COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE (315) 524-4446 ext. 396

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: APRIL 1990
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit was shutdown for the 1990 Annual Refueling and Maintenance Outage.

9. Power Level to Which Restricted, If Any (Net MWe):
10. Reasons For Restrictions, If Any:

		This Month	Yr.-to-Date	Cumulative
11.	Hours In Report Period	719**	2,879	179,465.45
12.	Number of Hours Reactor Was Critical	0	1,962.07	140,308.21
13.	Reactor Reserve Shutdown Hours	0	0	1,687.55 *
14.	Hours Generator On-Line	0	1,961.5	137,802.88
15.	Unit Reserve Shutdown Hours	0	0	8.5 *
16.	Gross Thermal Energy Generated (MWH)	0	2,926,224	194,548,674
17.	Gross Electrical Energy Generated (MWH)	0	987,813	64,021,158
18.	Net Electrical Energy Generated (MWH)	0	940,207	60,758,120
19.	Unit Service Factor	0	68.13	76.79
20.	Unit Availability Factor	0	68.15	79.12
21.	Unit Capacity Factor (Using MDC Net)	0	69.48	73.81
22.	Unit Capacity Factor (Using DER Net)	0	68.13	73.81
23.	Unit Forced Outage Rate	0	0	6.27

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup: May 7, 1990
26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY		
INITIAL ELECTRICITY		
COMMERCIAL OPERATION		

*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975
**EASTERN STANDARD TIME TO EASTERN DAYLIGHT SAVINGS TIME

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE May 15, 1990
COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH April, 1990

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1.	-4	17.	-2
2.	-4	18.	-2
3.	-4	19.	-2
4.	-4	20.	-2
5.	-4	21.	-2
6.	-4	22.	-3
7.	-4	23.	-3
8.	-4	24.	-2
9.	-3	25.	-2
10.	-3	26.	-3
11.	-3	27.	-3
12.	-3	28.	-4
13.	-3	29.	-8
14.	-2	30.	-8
15.	-2	31.	- 0 -
16.	-2		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

DOCKET NO. 50-244
UNIT NAME R.E. GINNA NUCLEAR POWER PLANT
DATE May 15, 1990
COMPLETED BY Robert E. Dodge
TELEPHONE 315-524-4446 x-396
Ginna Station

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH APRIL 1990

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
	4-90	A	719	C					The unit was shutdown for Annual Refueling and Maintenance Outage. The unit remained shutdown at the end of the report period.

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4
Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5
Exhibit 1 - Same Source

REV. 4/85 49-89

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE May 15, 1990
COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH April, 1990

The unit was shutdown for the Annual Refueling and Maintenance Outage. The unit remained shutdown at the end of the report period.