

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8807190046 DOC.DATE: 88/07/11 NOTARIZED: NO DOCKET #
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH.NAME AUTHOR AFFILIATION
 SNOW,B.A. Rochester Gas & Electric Corp.
 RECIP.NAME RECIPIENT AFFILIATION
 RUSSELL,W.T. Region 1, Ofc of the Director

SUBJECT: Advises that plant has no GE HFA-type latching relays, per
 NRC Bulletin 88-003, "Inadequate Latch Engagement...."

DISTRIBUTION CODE: IE11D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Bulletin Response (50 DKT)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL	
	PD1-3 LA		1		
	STAHL, C		1		
INTERNAL:	AEOD/DOA		1		
	AEOD/DSP/TPAB		1		
	NRR/DEST/ADE 8H		1		
	NRR/DEST/MEB 9H		1		
	NRR/DOEA/GCB 11		1		
	NRR/PMAS/ILRB12		1		
	<u>REG FILE</u> 02		1		
	RGN1 FILE 01		1		
EXTERNAL:	LPDR		1		
	NSIC		1		
	PD1-3 PD		1		
	AEOD/DSP		1		
	NRR RIVENBARK, G		1		
	NRR/DEST/ADS 7E		1		
	NRR/DOEA/EAB 11		1		
	NRR/DREP/EPB 10		1		
	NUDOCS-ABSTRACT		1		
	RES/DE/EIB		1		
	NRC PDR		1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 21 ENCL 0

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S

R

ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14602

July 11, 1988

Mr. William T. Russell
Regional Administrator
U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Subject: Response to NRC Bulletin 88-03
Inadequate Latch Engagement in HFA Type Latching Relays
Manufactured by General Electric (GE) Company
R. E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

Dear Mr. Russell:

In response to the instructions of NRC Bulletin 88-03, please be advised that R. E. Ginna Nuclear Power Plant does not have any HFA type latching relays subject to this bulletin.

Staff time required to prepare the requested documentation for this bulletin was approximately twelve hours.

Very truly yours,

Bruce A. Snow

Bruce A. Snow
Superintendent
Nuclear Production

xc: U.S. Nuclear Regulatory Commission (original)
Document Control Desk
Washington, D.C. 20555

Ginna Senior Resident Inspector

8807190046 880711
PDR ADCK 05000244
Q PNU

IEI
1/0