

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8812190387 DOC. DATE: 88/11/30 NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 MCNAMARA, A.E. Rochester Gas & Electric Corp.
 MECREDY, R.C. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Nov 1988 for RE Ginna Nuclear Power Plant. W/881215 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-3 LA	1 0	PD1-3 PD	5 5
	STAHL, C	1 0		
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	ARM TECH ADV	2 2	NRR/DLPQ/PEB 11	1 1
	NRR/DOEA/EAB 11	1 1	NRR/DREP/RPB 10	1 1
	NUDOCS-ABSTRACT	1 1	<u>REG FILE</u> 01	1 1
	RGN1	1 1		
EXTERNAL:	EG&G SIMPSON, F	1 1	EG&G WILLIAMS, S	1 1
	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 22 ENCL 20

R
I
D
S
/
A
D
S
/
A
D
D
S

OPERATING DATA REPORT

DOCKET NO. 50-244

DATE December 15, 1988

COMPLETED BY Andrew E. McNamara

Andrew E. McNamara

TELEPHONE 1(315)524-4446, Ext. 301

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: November, 1988
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470

Notes No outages or major power reductions were experienced in the report period. A minor reduction is detailed on Page 4.

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

9. Power Level to Which Restricted, If Any (Net MWe):

10. Reasons For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	720.00	8,040.00	166,680.00
12. Number of Hours Reactor Was Critical	720.00	6,935.14	130,953.61
13. Reactor Reserve Shutdown Hours	0.00	0.00	1,687.55*
14. Hours Generator On-Line	720.00	6,849.50	128,527.88
15. Unit Reserve Shutdown Hours	0.00	0.00	8.50*
16. Gross Thermal Energy Generated (MWH)	1,088,028	9,938,626	180,866,359
17. Gross Electrical Energy Generated (MWH)	370,073	3,341,760	59,424,345
18. Net Electrical Energy Generated (MWH)	352,458	3,176,323	56,387,607
19. Unit Service Factor	100.00%	85.19%	77.11%
20. Unit Availability Factor	100.00%	85.19%	77.12%
21. Unit Capacity Factor (Using MDC Net)	104.15%	84.06%	73.39%
22. Unit Capacity Factor (Using DER Net)	104.15%	84.06%	73.39%
23. Unit Forced Outage Rate	0.00%	4.70%	6.41%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

Annual Refueling and Maintenance Shutdown - March 17, 1989 -- 49-55 days

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

*Cumulative total commencing January 1, 1975.

8812190387 881130
PDR ADOCK 05000244
R PDC

REV. 4/85 49-88

IE24
11



[The text in this block is extremely faint and illegible, appearing as scattered black specks and noise across the page.]

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
 UNIT R.E. Ginna Nuclear Power Plant
 DATE December 15, 1988
 COMPLETED BY Andrew E. McNamara
 Andrew E. McNamara

TELEPHONE 1 (315) 524-4446
 Ext. 301 at Ginna

MONTH November, 1988

DAY AVERAGE DAILY POWER LEVEL
 (MWe-Net)

1.	<u>489</u>
2.	<u>489</u>
3.	<u>489</u>
4.	<u>489</u>
5.	<u>489</u>
6.	<u>490</u>
7.	<u>489</u>
8.	<u>489</u>
9.	<u>490</u>
10.	<u>490</u>
11.	<u>490</u>
12.	<u>490</u>
13.	<u>490</u>
14.	<u>487</u>
15.	<u>485</u>
16.	<u>488</u>

DAY AVERAGE DAILY POWER LEVEL
 (MWe-Net)

17.	<u>489</u>
18.	<u>489</u>
19.	<u>490</u>
20.	<u>490</u>
21.	<u>490</u>
22.	<u>490</u>
23.	<u>490</u>
24.	<u>490</u>
25.	<u>491</u>
26.	<u>491</u>
27.	<u>491</u>
28.	<u>491</u>
29.	<u>491</u>
30.	<u>491</u>
31.	<u>490</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.



NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
 UNIT R.E. Ginna Nuclear Power Plant
 DATE December 15, 1988
 COMPLETED BY Andrew E. McNamara
 Andrew E. McNamara
 TELEPHONE 1 (315) 524-4446
 EXT. 301 at Ginna

MONTH November, 1988

The reactor power level was maintained at 100% for the majority of the report period with no outages on major power reduction experienced. The one minor exception was a power level reduction to ~98% for a short period on November 15 to perform two periodic tests on the auxiliary feedwater system. The reduction was of short duration and the reactor power level was restored to 100% upon completion of the tests.



11-11-11
11-11-11
11-11-11

11-11-11

11-11-11

11-11-11

11-11-11

GINNA STATION
MAINTENANCE REPORT SUMMARY


OCTOBER, 1988

During the month of November, routine maintenance and inspections were completed. Major safety related work included:

- a. Snubber inspection per M-40
- b. Repaired broken pipe on R-21 P.I.
- c. Remove blockage in Boric Acid line
- d. Repaired tubing leak on Diesel Fire Pump
- e. Annual inspection on Tech. Support Center Diesel
- f. Replace Radiation Vac. Pump #R-10, 11, 12
- g. Annual inspection Fire Diesel Engine and Pump
- h. Rebuild Toxic Monitor Pump #2
- i. Annual minor inspection of "A" Service Water Pump
- j. Annual inspection of Security Diesel



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001



TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

December 15, 1988

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for November, 1988
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of November, 1988.

Very truly yours,

Robert C. Mecredy
General Manager
Nuclear Production

RCM/eeh

Attachments

cc: Mr. William T. Russell NRC (1)

IE24
11

