

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8905300140 DOC. DATE: 89/04/30 NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 DODGE, R.E. Rochester Gas & Electric Corp.
 MECREDY, R.C. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Apr 1989 for RE Ginna Nuclear
 Power Plant. W/890515 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-3 LA	4 4	PD1-3 PD	1 1
	JOHNSON, A	1 1		
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	IRM TECH ADV	2 2	NRR/DLPQ/PEB 10	1 1
	NRR/DOEA/EAB 11	1 1	NRR/DREP/RPB 10	1 1
	NUDOCS-ABSTRACT	1 1	<u>REG FILE 01</u>	1 1
	RGN1	1 1		
EXTERNAL:	EG&G SIMPSON, F	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 20

*Monthly Rpt
 cut*



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001



TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

May 15, 1989

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for April, 1989
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of April, 1989.


Very truly yours,

Robert C. Meckedy
General Manager
Nuclear Production

RCM/eeh

Attachments

cc: Mr. William T. Russell NRC (1)



IE24
11

OPERATING DATA REPORT

DOCKET NO. 50-244

DATE May 15, 1989

COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE 315-524-4446 x-396
Ginna Station

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT

2. Reporting Period: April, 1989

3. Licensed Thermal Power (MWt): 1520

4. Nameplate Rating (Gross MWe): 490

5. Design Electrical Rating (Net MWe): 470

6. Maximum Dependable Capacity (Gross MWe): 490

7. Maximum Dependable Capacity (Net MWe): 470

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

9. Power Level to Which Restricted, If Any (Net MWe):

10. Reasons For Restrictions, If Any:

Notes

The unit was shutdown for the 1989 Annual Refueling and Maintenance Outage.

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	719**	2,879	170,303
12. Number of Hours Reactor Was Critical	0	1,806.19	133,503.80
13. Reactor Reserve Shutdown Hours	0	0	1,687.55*
14. Hours Generator On-Line	0	1,796.75	131,068.63
15. Unit Reserve Shutdown Hours	0	0	8.5 *
16. Gross Thermal Energy Generated (MWH)	0	2,625,346	184,595,760
17. Gross Electrical Energy Generated (MWH)	0	889,282	60,688,611
18. Net Electrical Energy Generated (MWH)	0	845,455	57,589,913
19. Unit Service Factor	0	62.41%	76.96%
20. Unit Availability Factor	0	62.41%	76.97%
21. Unit Capacity Factor (Using MDC Net)	0	62.48%	73.33%
22. Unit Capacity Factor (Using DER Net)	0	62.48%	73.33%
23. Unit Forced Outage Rate	0	1.16%	6.31%
24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):			

25. If Shut Down At End Of Report Period, Estimated Date of Startup: May 26, 1989

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

* Cumulative total commencing January 1, 1975

**Eastern Standard Time to Eastern Daylight Savings Time



• • •

1. The first part of the document is a list of names and titles, including "The Hon. Mr. Justice" and "The Hon. Mr. Justice".

Journal of Management Studies, 19(1), 67-80.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
 UNIT R.E. Ginna Nuclear Power Plant
 DATE May 15, 1989
 COMPLETED BY Robert E. Dodge
 Robert E. Dodge

TELEPHONE 1 (315) 524-4446
 Ext. 396 at Ginna

MONTH April, 1989

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>-4</u>
2.	<u>-4</u>
3.	<u>-4</u>
4.	<u>-4</u>
5.	<u>-4</u>
6.	<u>-4</u>
7.	<u>-4</u>
8.	<u>-4</u>
9.	<u>-3</u>
10.	<u>-4</u>
11.	<u>-4</u>
12.	<u>-2</u>
13.	<u>-3</u>
14.	<u>-4</u>
15.	<u>-4</u>
16.	<u>-4</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>-4</u>
18.	<u>-4</u>
19.	<u>-4</u>
20.	<u>-4</u>
21.	<u>-4</u>
22.	<u>-4</u>
23.	<u>-4</u>
24.	<u>-4</u>
25.	<u>-4</u>
26.	<u>-4</u>
27.	<u>-4</u>
28.	<u>-4</u>
29.	<u>-4</u>
30.	<u>-4</u>
31.	<u></u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

Reporting negative net generations as required.



UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH APRIL, 1989

DOCKET NO. 50-244

UNIT NAME R.E. GINNA NUCLEAR POWER PLANT

DATE May 15, 1989

COMPLETED BY Robert E. Dodge

TELEPHONE 315-524-4446 x-396

Ginna Station

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
	4-89	S	719	C					The unit was shutdown for Annual Refueling and Maintenance Outage. The unit remained shutdown at the end of the report period.

1

F: Forced
S: Scheduled

2

Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3

Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5

Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE May 15, 1989
COMPLETED BY Robert E. Dodge
TELEPHONE 1 (315) 524-4446
EXT. 396 at Ginna

MONTH April, 1989

The unit was shutdown for the 1989 Annual Refueling and Maintenance Outage. The unit remained shutdown at the end of the report period.



11-11-11

11-11-11