

TABLE 3.5-7

Radiation Accident Monitoring Instrumentation

<u>Instrument</u>	<u>Minimum Channels Operable</u>	<u>Action</u>
1. Containment Area (R-29 and R-30)	2	1
2. Noble Gas Effluent Monitors		
i. Plant Vent (R-14A)	1	1
ii. A Main Steam Line (R-31)	1	1
iii. B Main Steam Line (R-32)	1	1
iv. Containment Purge (R-12A)	1*	1
v. Air Ejector (R-15A)	1	1

Action Statements

Action 1 - With the number of operable channels less than required by the Minimum Channels Operable requirements, either restore the inoperable channel(s) to operable status within 7 days of the event, or prepare and submit a Special Report to the Commission within 30 days following the event outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to operable status.

* only when the shutdown purge system flanges are removed.



Handwritten marks and scribbles in the top right corner.

Main body of the document containing faint, illegible text and scattered black specks.