

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8803020136 DOC.DATE: 88/01/31 NOTARIZED: NO DOCKET #
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH.NAME AUTHOR AFFILIATION
 MCNAMARA,A.E. Rochester Gas & Electric Corp.
 SNOW,B.A. Rochester Gas & Electric Corp.
 RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Jan 1988.W/880210 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 6
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244 D

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-3 LA	1 0	PD1-3 PD	5 5
	STAHL, C	1 0		
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	ARM TECH ADV	2 2	NRR/DLPQ/PEB11B	1 1
	NRR/DOEA/EAB11E	1 1	NRR/DREP/RPB10A	1 1
	NRR/PMAS/ILRB12	1 1	REG-FILE 01	1 1
	RGN1	1 1		
EXTERNAL:	EG&G GROH,M	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC	1 1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 21 ENCL 19

R
I
D
S
/
A
D
D
S

GINNA STATION

MAINTENANCE REPORT SUMMARY

JANUARY, 1988

During the month of January, routine maintenance and inspections were completed. Major safety related work included:

- a. MOVATS Testing - MOV-3996, MOV-4000A, and MOV-4000B
- b. SPING Monitor - P.M. Inspection
- c. "C" Charging Pump Vari-Drive C.M.
- d. Snubber Inspection per M-40

1224'1.

1944

OPERATING DATA REPORT

DOCKET NO. 50-244

DATE February 10, 1988

COMPLETED BY Andrew E. McNamara
Andrew E. McNamara

TELEPHONE 315-524-4446 x-301
Ginna Station

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: January, 1988
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:
9. Power Level to Which Restricted, If Any (Net MWe):
10. Reasons For Restrictions, If Any:

Notes

Unit coastdown towards the Annual Refueling and Maintenance shutdown commenced on January 8.

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744.00	744.00	159,384.00
12. Number of Hours Reactor Was Critical	744.00	744.00	124,762.47
13. Reactor Reserve Shutdown Hours	0	0	1,687.55*
14. Hours Generator On-Line	744.00	744.00	122,422.38
15. Unit Reserve Shutdown Hours	0	0	8.5 *
16. Gross Thermal Energy Generated (MWH)	1,029,730	1,029,730	171,957,463
17. Gross Electrical Energy Generated (MWH)	348,384	348,384	56,430,969
18. Net Electrical Energy Generated (MWH)	330,114	330,114	53,541,398
19. Unit Service Factor	100%	100%	76.81%
20. Unit Availability Factor	100%	100%	76.82%
21. Unit Capacity Factor (Using MDC Net)	94.40%	94.40%	72.94%
22. Unit Capacity Factor (Using DER Net)	94.40%	94.40%	72.94%
23. Unit Forced Outage Rate	0%	0%	6.47%
24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):			

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

*Cumulative total commencing January 1, 1975

REV. 4/85 43-39

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE February 10, 1988
COMPLETED BY Andrew E. McNamara
Andrew E. McNamara

TELEPHONE 1 (315) 524-4446
Ext. 301 at Ginna

MONTH January, 1988

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	492
2.	491
3.	491
4.	490
5.	489
6.	491
7.	490
8.	488
9.	485
10.	481
11.	473
12.	470
13.	465
14.	457
15.	453
16.	447

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	442
18.	437
19.	432
20.	426
21.	424
22.	414
23.	413
24.	410
25.	405
26.	398
27.	391
28.	388
29.	378
30.	376
31.	370

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH JANUARY, 1988

DOCKET NO. 50-244

UNIT NAME R.E. GINNA NUCLEAR POWER PLANT

DATE February 10, 1988

COMPLETED BY Andrew E. McNamara

Andrew E. McNamara

TELEPHONE 315-524-4446 x-301

GINNA Station

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
									No shutdowns to report. Coastdown towards the Annual Refueling and Maintenance Outage scheduled for February 5 commenced on January 8.

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4
Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5
Exhibit I - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
 UNIT R.E. Ginna Nuclear Power Plant
 DATE February 10, 1988
 COMPLETED BY Andrew E. McNamara
 Andrew E. McNamara
 TELEPHONE 1 (315) 524-4446
 EXT. 301 at Ginna

MONTH January, 1988

The reactor power level commenced decreasing from 100% on January 8, 1988, when coastdown toward the Annual Refueling and Maintenance Outage (scheduled for February 5, 1988) began. By January 31, 1988 the reactor power level was ~ 76%, with no problems encountered.

R

To: Bill Coveace

ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001

FILED 1988
NOV 20 1988 VIA 546 2:00

GINNA STATION
February 10, 1988

Director, Office of Management Information and Program Analysis
U.S. NUCLEAR REGULATORY COMMISSION
Washington, DC 20555

Subject: Monthly Report for January, 1988
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of January, 1988.

Very truly yours,

Bruce A. Snow
Bruce A. Snow

BAS/eeh

Attachments

cc: Mr. William T. Russell NRC (1)

DESIGNATED ORIGINAL
Certified By *Jan H. Schwartz*

IE24
11

10-10-68
10-10-68
10-10-68

10-10-68
10-10-68
10-10-68

10-10-68
10-10-68
10-10-68

10-10-68