

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8805040260 DDC DATE: 88/04/26 NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 SNOW, B. A. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 STAHL, C. NRC - No Detailed Affiliation Given

SUBJECT: Responds to 870820 SER re performance testing of plant safety & relief valves. Util agrees to develop & implement procedures defining timing & extent of required insps & maint, per NUREG-0737 Item II.D.1 requirements.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: Inservice Inspection/Testing/Relief from ASME Code

NOTES: License Exp date in accordance with 10CFR2.2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-3 LA	1	PD1-3 PD	5
	STAHL, C	1		
INTERNAL:	AEOD/DOA	1	AEOD/DSP/TPAB	1
	ARM/DAF/LFMB	1	NRR/DEST/MEB 9H	1
	NRR/DEST/MTB 9H	1	NRR/PMAS/ILRB12	1
	OGC 15-B-18	1	REG FILE 01	1
	RES/DE/EIB	1		
EXTERNAL:	EG&G ROCKHOLD, H	1	LPDR	1
	NL 007 HEMMING	1	NRC PDR	1
	NSIC	1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 21 ENCL 0



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001



TELEPHONE
AREA CODE 716 546-2700

April 26, 1988

U.S. Nuclear Regulatory Commission
Document Control Desk
Attn: Mr. Carl Stahle
PWR Project Directorate No. 1
Washington, D.C. 20555

Subject: Inspection and Maintenance of Safety Valves
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Stahle:

This letter is in response to the NRC's August 20, 1987 SER from Carl Stahle to Roger Kober, concerning performance testing of the Ginna safety and relief valves. In that SER, the NRC requested that RG&E commit to perform inspection and maintenance, as required to ensure the subsequent reliable operation of the safety valves, following a safety valve lift which involves a loop seal or water discharge.

RG&E agrees to develop and implement procedures defining the timing and extent of the required inspections and maintenance. These procedures will be developed during 1988, and implemented following the 1989 refueling outage.

Based on this commitment, the requirements of NUREG-0737 Item II.D.1 can be considered fully implemented, and this issue can be closed.

Very truly yours,

Bruce A. Snow
Superintendent
Nuclear Production

8805040260 880426
PDR ADDOCK 05000244
P PDR

P605 773 716
A047
1/0

